

Memorandum

To: Dennis Waters/Patco
CC: George L. Foster for the Six G's Coed LLC
From: Mike Nugent/Manager of Inspection Services
Date: 01/27/2004
Re: 563 Riverside St. (306 B001)

I have reviewed the plans for the above project and cannot issue the permit because of the following deficiencies:

- 1) There is no soils report as required by Section 1804.1 of the Building Code.
- 2) There is no Statement of Special Inspections as required by Section 1705. of the Building Code.
- 3) There are no construction documents for the masonry façade work.
- 4) The Planning Department has not signed off on the project.