

•
•
•
•
•
•
•

389 Congress St.Rm 315
Portland, ME 04101
Phone: (207)874-8700
Fax: (207)874-8716

facsimile transmittal


To: Dennis Waters **From:** Mike Nugent

Fax: 324-1643 **Date:** March 2, 2004

Phone: 324-5574 **Pages:** 1

Re: 563 Riverside St. (306 B001)

Urgent For Review Please Comment Please Reply Please Recycle



• • • • • • • • •
Omitted Structural/Code Compliance information:

- 1) Unbalanced and Drift snow load (Sections 1608.5 and 1608.6)
- 2) Deflection limits (Section 1608.5)
- 3) Load Combinations (Section 1613.1)
- 4) Flat roof snow load (Section 1608.3)
- 5) Seismic soil profile type (Section 1610.3.1)
- 6) Fire Classification of roof covering (Section 1506.0)

This is basically it for my review, After I get this info and Planning authorizes the issuance (after the performance guarantees are reviewed and approved etc.) The permit can be issued.



• •