

Protection Professionals

325 US Route 1
 Falmouth, ME 04105
 Ph 207-775-5755
 Fax 207-781-2064

Device List

No. 5246

List Date
5/1/2013

Bill To Name / Address
Regional Electric 186 Summer Street Auburn, ME 04210

Job Site
Central Kitchen - City of Portland 92 Waldron Way Portland, ME 04102

CHANGING THIS DEVICE LIST DOES NOT ALTER THE ORIGINAL ESTIMATE
Attach copy to Purchase Order for accounting

Estimate No.

Item	Description	Qty To Order	Qty Ordered
FC901-U3	Cerberus-Pro fire alarm panel, 50 points, S54433-C105-A1	1	
FH901-R3	S54433-B103-A4; 50 Point system red enclosure	1	
Bat 12-12	Battery 12 VOLTS 12 AMP/HOURS SLA-1105	2	
IM-RJ31XSET	IM-RJ31XSET	2	
OOH941	S54320-F8-A2, Dual Optical/Heat Detector	2	
500-094151	DB-11 Cerberus pro detector base	2	
FDCIO422	4 Input/4 output monitor module (sprinkler)	1	
500-034000	HTRI-M Mini-module (kitchen Ansul, pulls)	11	
06-SSU00672	Fire Document box 12 inches wide X 13.1 inches high X 2.25 inches deep, CAT 30 keyed	1	
500-648507FA	MANUAL PULL STATION DUAL ACTION KEY RESET CAST METAL	9	
AX-AL602ULADA	NAC power supply, 24 or 12 VDC, 6.5 amps, two Class A or four Class B at 2.5 amps/circuit, 1 amp Aux power	1	
Bat 12-7	12V 7AH Batteries	2	
500-636161	ZH-MC-R Horn/strobe, red, wall mount, Hi or Lo volume, 15cd, 30cd, 75cd, or 110cd	33	
500-636169	ZR-MC-R Strobe only, red, wall mount, 15cd, 30cd, 75cd, or 110cd	6	
500-636016	Horn/strobe, weatherproof, 75 candela, red, Hi,Lo or Med volume	2	
500-636137	WPBBS-R Backbox for AS series, red	2	
3261	Knox Box 3261 Hinged Door Black	1	
AES-7788F	AES 7788F Wireless UL/NFPA Transceiver	1	
1640	16.5 Volt AC 40 VA Class 2 Transformer	1	
Bat 12-7	12V 7AH Batteries SEC-1075	1	
D8004	UL TRANSFORMER KIT	1	
Misc Non-Inventory ...	Bypass switch	2	
GI-TSW01S	Tamper Switch for master boxes, bag of ten	1	
FDBZ492-HR	S54319-B23-A1 Duct detector with relay	1	
OOH941	S54320-F7-A2, Dual Optical/Heat Detector	1	

Ordered By: _____

Date: _____

Received By: _____

Date: _____

Protection Professionals

325 US Route 1
Falmouth, ME 04105
Ph 207-775-5755
Fax 207-781-2064

Device List

No. 5246

List Date
5/1/2013

Bill To Name / Address
Regional Electric 186 Summer Street Auburn, ME 04210

Job Site
Central Kitchen - City of Portland 92 Waldron Way Portland, ME 04102

CHANGING THIS DEVICE LIST DOES NOT ALTER THE ORIGINAL ESTIMATE
Attach copy to Purchase Order for accounting

Estimate No.

Item	Description	Qty To Order	Qty Ordered
FDBZ-RTL 500-649711	S54319-S27-A1, Remote test station for duct detectors ST-25 SAMPLING TUBE FOR DUCTS OVER 1' TO 3'	1 1	

Ordered By: _____

Date: _____

Received By: _____

Date: _____