



1717 STILLWATER AVENUE
VEAZIE, ME 04401
207-947-8334
FAX: 207-947-3580

1022 MINOT AVENUE
AUBURN, ME 04210
207-784-1388
FAX: 207-783-4039

(10/11/13) (2:00PM)
- Certificate of Occupancy Walk-Through -

- Electrical Inspector -
- Code Enforcement Officer -
- Fire Department -

Issues

- Electrical
- Conductor Identification on Disconnect (3 Red Wires?)
 - Junction Box Knockouts in Mech. Room
 - Empty Conduits passing through separation wall e Mech/Elec. Room

- Codes
- Drywall e separation wall between Mech/Elec. Rooms. Left Side needs Drywall Vertically up to deck if looking from Elec. Room side. There is a gap from where the wall stops to the metal exterior siding. Insulation currently fills this void (not rated).
 - Wants a cut sheet/product data for Foam Insulation used in Mech/Elec. Rooms.

- Fire
- Wants a new Cog Detector (existing one is smashed and batteries are missing)
 - Had some concern about chemical storage space. Room currently has no ceiling (open at the top).

PROJECT: <u>Kitchen</u> <u>City of Portland</u>	LOCATION: <u>99 Waldron Way</u>	CONTRACTOR/VENDOR: <u>L+L</u>	PROJECT #	DATE: <u>10 11 13</u>
--	---------------------------------	-------------------------------	-----------	---------------------------