DISTANCE TRAVELED: 52'-8"

APPLICABLE CODES:
IBC 2009 & NFPA 2009

OCCUPANCY: BUSINESS
CONSTRUCTION TYPE: III B (FULLY SPRINKLED)
TRAVEL DISTANCE TO FIRE EXTENGUISHER IS NOT TO EXCEED 75 FEET
MAXIMUM TRAVEL DISTANCE = 300 FEET
MAXIMUM COMMON PATH = 100 FEET

MODIFY AND EXTEND EXISTING SPRINKLER SYSTEM AS REQUIRED TO PROVIDE FULL FIRE SUPPRESSION COVERAGE TO ALL SPACES, IN ACCORDANCE WITH NFPA 13, STATE FIRE MARSHAL'S OFFICE, AND CITY OF PORTLAND, MAINE REQUIREMENTS.

FE — FIRE EXTINGUISHER

ADA CLEARANCES

WALL MOUNTED EXIT SIGN

EB — BATTERY PACK WITH EMERGENCY LAMPS AS SHOWN

REMOTE EMERGENCY LAMP LIGHT FIXTURES

F — WALL MOUNTED FIRE ALARM SYSTEM MANUAL PULL STATION

F — FIRE ALARM SYSTEM WALL MOUNTED AUDIO/VISUAL DEVICE

2 FIRST FLOOR CODE PLAN
1/8" = 1'-0"

1 FIRST FLOOR PLAN
1/8" = 1'-0"

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 11/06/14

LICENSED ARCHITECT
MICHAEL E. JOHANNING
No. 3067
STATE OF MAINE
10-03-14

MAG. NORTH
PROJECT NORTH

WBRC ARCHITECTS · ENGINEERS

PROJECT:
585 RIVERSIDE - CARPENTERS UNION RENO

SHEET TITLE:
FLOOR PLANS

SCALE:	1/8" = 1'-0"
WBRC CAD FILE:	
PROJECT No.	4003.00
JOB CAP/DRAW:	/RAD
PM:	MEJ
CHECKED BY:	MEJ
DATE:	10-02-2014
SHEET No.	AE101

© COPYRIGHT 2014 WBRC