

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

ERLICH MARK ETALS TRUSTEES

Located at

585 RIVERSIDE ST

PERMIT ID: 2014-02861

ISSUE DATE: 12/16/2014

CBL: 306 B006305

has permission to **For the installation of an HVAC System (Modine Gas-Fired, Power Vented Unit Heater).**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.	A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.
---	--

/s/ Benjamin Wallace Jr.

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Final Inspection

Final - Electric

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2014-02861	Date Applied For: 12/11/2014	CBL: 306 B006305
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same: Building contractors & construction services including classroom instruction in Bldg #3 - Condo Unit #5 (67 Rainmaker Drive) - Rainmaker Business Park		Proposed Project Description: For the installation of an HVAC System (Modine Gas-Fired, Power Vented Unit Heater).		
Dept: Zoning	Status: Approved	Reviewer: Tammy Munson	Approval Date: 12/12/2014	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
Dept: Building	Status: Approved w/Conditions	Reviewer: Tammy Munson	Approval Date: 12/12/2014	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) The installation must comply with the State of Maine Gas Regulations.				
Dept: Fire	Status: Approved w/Conditions	Reviewer: Benjamin Wallace Jr.	Approval Date: 12/15/2014	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) Installation shall comply with NFPA 211, Standard for Chimneys, Fireplaces, Vents, and Solid Fuel-Burning Appliances; NFPA 58, Liquefied Petroleum Gas Code; NFPA 1, Fire Code, NFPA 70, National Electrical Code; and the manufacturer's published instructions.				
2) Installation shall comply with City Code Chapter 10.				