389 Congress St.Rm 315 Portland, ME 04101 Phone: (207)874-8700 Fax: (207)874-8716

## facsimile transmittal

Го:	David Leasure	From:	Mike Nugent
ax:	797-8533	Date:	March 26, 2002
Phone:	797-8661	Pages:	7
Re:	68 Waldron Way (306 B018)	CC:	Marc Bergeron (fax) 781-4245
□ <b>Urg</b> er	nt □ For Review □ Please Comme	ent I	☑ Please Recycle
Notes:	• • • Please find attached a memo requesting a	statemen	• • • • t of special inspection. This permit
cannot be issued until this is received. I have begun a partial review and have the following			
questions:			
1. The potential occupancy load of the office section exceed 50, and the egress goes through a			
higher hazard adjoining space, conflict with Section 1006.2.1.			
2. Are there Penetrations other than the doors in the three hour assembly for HVAC etc?			
3	The large plans submitted were not stampe	ed and m	ust be.
4.	Because the roof pitch is less than 5 degree	es, the de	esign must be certified in compliance
with Section 7.3 of ASCE 7.			
5.	All mechanicals, alarms etc. must be stamp	ed and s	submitted prior to installation.
6.	Fire rating specs on all CMU's and other	ire rated	assemblies are needed.