

Memo

City of

Portland

To: Lou Wood

From: Jeanie Bourke

Date: 2/3/05

Re: 23/27 and 26/32 Jarita Court – Plan Review Checklist

Dear Lou:

As we discussed via telephone, here is the list of required submissions for the continuation of the review process. In addition to the specs for the 1hr fire rated/50 sound transmission partition, the following items are required.

1. Verification of sheetrock under stairs in pantry closet
2. Verification of window manufacturer and egress size
3. Show attic scuttles – minimum of 22” x 30” clear
4. Show minimum headroom requirement in stairways
5. Verification of the garage beam to be 1hr rated as well

Thank you,
Jeanie Bourke
Plan Reviewer/Code Officer
City of Portland
Inspections Division