

# ELECTRICAL PERMIT

## City of Portland, Me.



S/F

1

To the Chief Electrical Inspector, Portland Maine:  
The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the City of Portland Electrical Ordinance, National Electrical Code and the following specifications:

Date 8-29-08  
Permit # 764  
CBL# 309 D 048

LOCATION: 60 Aldworth St METER MAKE & # \_\_\_\_\_  
CMP ACCOUNT # \_\_\_\_\_ OWNER Ray Curtis  
TENANT Ray Curtis PHONE # 797 3507

### TOTAL EACH FEE

OUTLETS	1	Receptacles		Switches		Smoke Detector			.20	
FIXTURES		Incandescent		Fluorescent		Strips			.20	
SERVICES		Overhead		Underground		TTL AMPS	<800		15.00	
		Overhead		Underground			>800		25.00	
Temporary Service		Overhead		Underground		TTL AMPS			25.00	
									25.00	
METERS		(number of)							1.00	
MOTORS	1	(number of)							2.00	
RESID/COM		Electric units							1.00	
HEATING		oil/gas units		Interior		Exterior			5.00	
APPLIANCES		Ranges		Cook Tops		Wall Ovens			2.00	
		Insta-Hot		Water heaters		Fans			2.00	
		Dryers		Disposals		Dishwasher			2.00	
		Compactors		Spa		Washing Machine			2.00	
		Others (denote)							2.00	
	MISC. (number of)		Air Cond/win							3.00
			Air Cond/cent				Pools			10.00
		HVAC		EMS		Thermostat			5.00	
		Signs							10.00	
		Alarms/res							5.00	
		Alarms/com							15.00	
		Heavy Duty(CRKT)							2.00	
		Circus/Carnv							25.00	
		Alterations							5.00	
		Fire Repairs							15.00	
		E Lights							1.00	
		E Generators							20.00	
PANELS		Service		Remote		Main			4.00	
TRANSFORMER		0-25 Kva							5.00	
		25-200 Kva							8.00	
		Over 200 Kva							10.00	
						TOTAL AMOUNT DUE				
MINIMUM FEE/COMMERCIAL 45.00						MINIMUM FEE	35.00		35.00	

INSPECTION: Will be ready 8-29-08 or will call \_\_\_\_\_

CONTRACTORS NAME Peter Peterson MASTER LIC.# 40088320  
ADDRESS 833 Ocean Ave. LIMITED LIC.# (MS) 08/1/01  
TELEPHONE 794-6509 207-7681-0669

SIGNATURE OF CONTRACTOR Peter Peterson  
PETER PETERSON

ELECTRICAL INSTALLATIONS—

Permit Number \_\_\_\_\_

Location \_\_\_\_\_

Owner \_\_\_\_\_

Date of Permit \_\_\_\_\_

Final Inspection \_\_\_\_\_

By Inspector \_\_\_\_\_

INSPECTION: Service \_\_\_\_\_ by \_\_\_\_\_

Service called in \_\_\_\_\_

Closing-in \_\_\_\_\_ by \_\_\_\_\_

PROGRESS INSPECTIONS: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

\_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

\_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

\_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

\_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

\_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

DATE:

REMARKS:

MAGNETIC

9-1 CLAMP @ POOL BONDING = FERROUS METAL = WILL RUST  
~~9-1~~ APPEARS THAT ELECTRICIAN = JOCKNEYMAN, VERY  
UNCOOPERATIVE, INSULTING & THREATENED  
TO ASSAULT ME IF HE EVER BETS ME  
ALONE. SKW