

# Fire Suppression System Design Specifications

## Notes

## System Materials

Item Number	Description	Quantity
87-120016-001	ADP Nozzle	5
87-120019-001	R Nozzle	2
WK-282664-000	ML-360 Link 360 F (182 C), ML, Unpaint	1
87-120018-001	GRW Nozzle	2
WK-282666-000	ML-500 Link 500 F (260 C), ML, Orange	2
60-120006-001	WHDR-400M Cylinder/Valve, 4 Gallon	2
60-120099-001	Universal Control Head Assembly	1
60-120110-001	Remote Manual Release, Combination	1
60-120071-001	3/4" NPT Mechanical Gas Valve	1
60-120064-001	Universal Link Detector Housing Kit (A+)	3



Designed & Installed by:  
Firesafe Equipment  
PO Box 1355  
Auburn, ME 04211  
207-784-7525

For:  
TACO TRIO