

PERMIT ISSUED

City of Portland, Maine - Building or Use Permit Application
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 01-1551AN Issue Date: 7 CBL: 311 A006001

Location of Construction: 653 Riverside St	Owner Name: Porter Drywall Inc	Owner Address: 655 Riverside St CITY OF PORTLAND	Phone:
Business Name: n/a	Contractor Name: Air Temp	Contractor Address: 11 Wallace Ave South Portland	Phone: 2077742300
Lessee/Buyer's Name n/a	Phone: n/a	Permit Type: HVAC	Zone:

Past Use: Commercial / Pharmacy	Proposed Use: Commercial / Install 1,000 gallon York Oil Tank	Permit Fee: \$30.00	Cost of Work: \$0.00	CEO District: 1
Proposed Project Description: Install Gas Heating System		FIRE DEPT: <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied	INSPECTION: Use Group: Type: <i>BOCA '93</i> <i>March '93</i> <i>Maine State Old SF Rules</i>	
		Signature: <i>JHM</i>	Signature: <i>DC</i>	

PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)

Action: Approved Approved w/Conditions Denied

Signature: Date:

Permit Taken By: gg	Date Applied For: 12/19/2001	Zoning Approval	
------------------------	---------------------------------	------------------------	--

<ol style="list-style-type: none"> This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules. Building permits do not include plumbing, septic or electrical work. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work.. 	Special Zone or Reviews <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan Maj <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/> Date:	Zoning Appeal <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied Date:	Historic Preservation <input type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied Date:
---	---	---	---

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT ADDRESS DATE PHONE


RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE DATE PHONE



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT

311-A 006



To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 653 Riverside St. Use of Building Pharmacy Date 12/19/01
 Name and address of owner of appliance Parter Paywall (Ken Parter)
655 Riverside St. Portland
 Installer's name and address AIRTEMP 11 Wallace Ave.
S. Portland, ME 04106 Telephone 774-2300

Location of appliance:

- Basement
- Attic
- Floor
- Roof

Type of Fuel:

- Gas
- Oil
- Solid

Appliance Name: YORK

U.L. Approved Yes No

Will appliance be installed in accordance with the manufacture's installation instructions? Yes No

IF NO Explain: _____

The Type of License of Installer:

- Master Plumber # _____
- Solid Fuel # _____
- Oil # _____
- Gas # PNT 1977
- Other _____

Type of Chimney:

Masonry Lined
Factory built _____

Metal
Factory Built U.L. Listing # _____

Direct Vent
Type PVC UL# _____

Type of Fuel Tank

- Oil
- Gas

Size of Tank 1,000 gal.

Number of Tanks 1

Distance from Tank to Center of Flame 50+ feet.

Approved

Fire: [Signature]
 Ele.: _____
 Bldg.: _____

Approved with Conditions

See attached letter or requirement

Signature of Installer [Signature] Peter Lewis

DEC 19 2001

Application ID Number: 1-1551

Delete Save Close

Department: Building

Status: Pending

Reviewer: Dave Caddell

Comments:

Approval Date

Given On Date: 12/26/2001

OK to Issue Permit Name: Dave Caddell Date: 01/04/2002 Date 2: 01/04/2002

Conditions Section:

Add New Condition From

Add New Condition

Delete Condition

Installation shall comply with BOCA Mechanical Code 1993 and State of Maine Oil and Solid Fuel Board Laws and Rules

Create Date: 12/26/2001 By: gg Update Date: 01/04/2002 By: dgc