

DAILY CONSTRUCTION REPORT

Project: Phoenix Welding
Client: SRG Engineering
Client Rep: Steve Grant
General Contractor: Patco Construction

Project No.: 05-1252
Date: February 27, 2006
Temp. Range: 10's
Weather: overcast and windy

General Observations, Discussions, Etc. Continued: S.W. Cole notified Rick Storey (Storey Brothers Trucking & Excavation) during visits that the in-place compaction was less than 95%, no representative from Patco Construction was present during S.W. Coles visits.

Following S.W. Cole's site visit phone call conversations were had with Steve Grant (SRG Engineering) and Ron Mercier (Patco Construction) discussing the in-place density results and the backfill material being used by Storey Brothers.