



TYPICAL HIGH BAY MOUNTING DETAIL

WAREHOUSE PHASE I LIGHTING PLAN  
1/16" = 1'-0"

- NOTES:
1. ALL WAREHOUSE FIXTURES TYPE "A" & "A1" MOUNTED BETWEEN STRUCTURAL FRAMING ATTACH TO PERLINS CENTERED IN AISLES AND ALTERNATELY CIRCUITED AS SHOWN AND ALL 2 POLE CIRCUITS RUN TO 20AMP-2POLE APPROVED SWITCHING CIRCUIT BREAKERS. ALL WIRING SHALL BE 30AMP #10 THIN-3/4" MINIMUM TO EACH FIXTURE, UNLESS NOTED OTHERWISE.
  2. ALL FIXTURES INDICATED BY N.L. SHALL BE ON NIGHT LIGHTING CIRCUIT 39, 41 PANEL "LP-1".
  3. ALL EMERGENCY BATTERY UNITS AND EXIT LIGHT/COMB BATTERY UNITS IN WAREHOUSE SHALL BE CONNECT TO PANEL "LP-1" CIR #42. MOUNT ALL BATTERY UNITS IN OPEN AREAS IN BAR JOIST AND DIRECT HEADS AT EGRESS ROUTES.
  4. EMERGENCY BATTERY UNITS WITHIN PHASE II NEW CANOPY SHALL BE EQUIPPED WITH THERMAL JACKET WITHIN BATTERY CABINET SURROUNDING BATTERIES, APPROVED FOR O?
  5. ALL BRANCH CIRCUIT WIRING TO ALL TYPE "C" & "C1" FIXTURES SHALL BE WEATHERPROOF 3#10-3/4" CONDUIT MINIMUM.
  6. COORDINATE EXACT PLACEMENT OF CIRCULATION FANS WITH HVAC CONTRACTOR AND LIGHTING. SEE DWG. E-3 FOR FAN LOCATIONS.
  7. CONNECT EMERGENCY BATTERY UNITS TO CONSTANT 120VOLT LIGHTING CIRCUIT WITHIN AREAS SERVED 3#10-3/4" TO EACH.

S.S.E.T. SOUTH SHORE ENGINEERING TEAM INC.  
ELECTRICAL & MECHANICAL ENGINEERS - Phone: 781-331-4660 - Fax: 781-829-4405 - E-mail: SSETINC@AOL.COM  
720 WASHINGTON STREET - HANOVER, MA - COLLEGE PARK - YALE BUILDING

DION & SOKOL INC ARCHITECTS

WAREHOUSE OVERALL LIGHTING PLAN PHASE I  
WAREHOUSE FACILITY  
HARVEY INDUSTRIES 401 RIVERSIDE ST. PORTLAND, ME

project no.	01-20
drawn	EAB
checked	CJW/JPS
dated	01-21-2003

E-2

revisions: