

# Memorandum

**To:** Robert Dion

**From:** Mike Nugent/Manager of Inspection Services

**Date:** 04/10/2003

**Re:** Harvey Industries, 401 Riverside St. (313 F039) app#030147

A review of the submissions for the above permit is partially complete. I have the following questions/comments:

- 1) Roof Snow Load is shown as 35 psf, please explain the methodology.
- 2) The S1 use group is not proposed to be fire separated from the from the B/M use group and it exceeds 10% of the floor area, Please provide a code justification. (see Section 302.1.2).
- 3) Please explain why the break room (mezzanine) is not open as required by 505.4.