Date: 10/14/13

Approved as Submitted
Approved as Noted
Approved with Conditions

RESERVED FOR CITY STAMP

FIRE ALARM PLAN

SCALE: 1/8"=1'-0"

SHEET NOTES:

1. ADDRESSABLE MONITOR MODULE(S) PROVIDED TO MONITOR ALL WATER FLOW, PRESSURE SWITCHES, TAMPER SWITCHES AND POST INDICATING VALVES ASSOCIATED WITH THE FIRE SPRINKLER SYSTEM. INSTALLING CONTRACTOR SHALL FIELD VERIFY EXACT MOUNTING, CIRCUITING AND PROGRAMMING REQUIREMENTS. FIELD VERIFY EXACT QUANTITY AND LOCATION(S).

REVISION	DESCRIPTION	DATE
0	ISSUED FOR REVIEW & APPROVAL	8/8/2013
1	UPDATED FA SYSTEM PER NEW FLOOR PLAN	9/13/2013
2	D TO E SIZE DRAWING	9/16/2013

CUNNINGHAM
Security Systems
10 Princes Point Road, Yarmouth, Maine 04096
Office: 207.846.3350 • Fax: 207.846.6080

649 WARREN AVENUE BUILDING
649 WARREN AVENUE
PORTLAND, MAINE 04103
FIRE ALARM PLAN

DRAWN	JPB UNICAD JOB #13441
CHECKED	WAYNE B. HAWS NICET IV 90496
DATE	8/7/2013
REVISION	2
SCALE	1/8"=1'-0"

shop drawings created by:
5744 W. 4600 So.
Hooper, UT 84315
Office: 801.985.0410
UNICAD Inc.
www.unicad.net
Fire Alarm Design & Drafting Services

FA-2