

ATLANTIC ENGINEERING

529 MORGAN BAY ROAD - SURRY, MAINE 04684
PHONE 207-667-3013 FAX 207-667-3013

February 19, 2008

Re: Structural Inspection
Hammond Lumber Company
300 Riverside Street Project
Portland, Maine

Mr. Matt Masse *MM*
Hammond Lumber Company
P.O. Box 500
Belgrade, Maine 04917

MAR 27 2008

Dear Matt,

I visited your new location on 300 Riverside Street in Portland today and performed a structural inspection of the following buildings:

The main warehouse and its sales office – Nat. Store Fixtures' project #202246


The bulk storage shed – National Store Fixtures' project #202340

I found that the buildings have been erected in accordance with the drawings and specifications provided by National Store Fixtures.

I have also checked the calculations for the "Versa-Lam header for the lumber storage mezzanine between column lines 16 & 17 @ row E. The header is composed of three 1.75"x11.88" Versa-Lam members and spans 15'-1". This member can safely support the intended 100psf live load intended on the mezzanine.

If you have any questions, do not hesitate to contact me. My e-mail address is damegraw@roadrunner.com.

Sincerely,


Daniel A. McGraw, P.E.
Me. # 2854

316-A-1
damegraw@rr.com

cc: Chris Walsh

A Division of Atlantic Enterprises, Inc.