

LUMINAIRE SCHEDULE

PROVIDE LUMINAIRES COMPLETE WITH ACCESSORIES TO MEET JOB CONDITIONS

BASIC LETTER DESIGNATIONS				
MOUNTING	INCANDESCENT	FLUORESCENT	H.I.D.	EXIT SIGNS
CEILING SURFACE	C	FC	MC	EC
CEILING RECESSED	R	FR	MR	ER
WALL	W	FW	MW	EW
SUSPENDED AS DIRECTED BY ARCH.	S	FS	MS	ES

TYPE	LAMPS		MANUFACTURER & CATALOG No.	MOUNTING	REMARKS
	No.	TYPE			
EX1	-	LED	SIGMATEX INC. # CRR-BB-1-G-C-BA-4-DG	UNIVERSAL	SINGLE FACE. *** ARROWS PER PLAN. 1" # MOUNTING PER PLAN.
EX2	-	LED	SIGMATEX INC. # CRR-BB-2-G-C-BA-4-DG	UNIVERSAL	DOUBLE FACE. *** ARROWS PER PLAN. 1" # MOUNTING PER PLAN.
L1	1	35W MR16/SP	B-K LIGHTING # NS-3-SAP-12-11	EXTERIOR GROUND	FLOOD LIGHT
L2	1	20W MR16/SP	B-K LIGHTING # SF-24-L-MR-FR-6-SAP-12-11-B-PP75-120	LANDSCAPE MINIPOLE	LANDSCAPE PATH LIGHT
LA	1	35W MH/TE	LUMIERE # 6000-MH37F16-120-WFL7-ANSS-CP-NLS-TRL-LVR-6	LANDSCAPE INGROUND	LANDSCAPE UPLIGHT
LB	1	35W MH/TE	ERCO # 85029.023	SURFACE EXTERIOR	EXTERIOR SURFACE CYLINDER
LD	1	35W MH/TE	ERCO # 85029.023	RECESSED EXTERIOR	EXTERIOR RECESSED FLOOD
PA	5	23W CF/35K	REJUVINATION GARFIELD	PENDENT	24" DIAMETER CUSTOM DECORATIVE PENDENT. ONE LAMP WIRED TO EMERGENCY
PB	2	32W T8/35K	CORELITE # SB-W-6-27R-1-C-120-4-C-48-IB-X	PENDENT	INTERCOM INDIRECT/DIRRECT, PROVIDE OVERALL LENGTHS PER PLAN
PD	2	32W T8/35K	METALUX # DM-233-UNV-EB81-UJ	PENDENT	PENDENT INDUSTRIAL STRIP
RD	2	32W T8/35K	NEORAY # 71-273-X-SB-582	WALL SURFACE	LINEAR FLUORESCENT PERIMETER WALL WASH. EMERGENCY PACK. PROVIDE OVERALL LENGTHS PER PLAN
RF	1	32W CFTT/35K	PORTFOLIO # CLW6132E-649H-WF-HB26	RECESSED	RECESSED LENSED WALL WASHER
RG	1	32W CFTT/35K	PORTFOLIO # CLH42E-618H-WF-HB26	RECESSED	RECESSED LENSED DOWN LIGHT
RH	1	32W CFTT/35K	PORTFOLIO # CH42E-615H-WF-HB26	RECESSED	RECESSED DOWN LIGHT
RJ	1	54W T5 HO/35K	LINEAR #RC23-D-1ETSHO-120-SBL-SS-BW-NO-4"	RECESSED	RECESSED LINEAR FLUORESCENT
RJA	1	54W T5 HO/35K	LINEAR #RC23-D-1ETSHO-120-SBL-SS-BW-NO-4"	RECESSED	RECESSED LINEAR FLUORESCENT
SA	1	54W T5 HO/35K	VODE LIGHTING LLC # WG-01-5A-CA-03-IB-A1-0-4-0-4-0-1	SURFACE	STACK LIGHT - MOUNT LUMINAIRES DIRECTLY TO CAST IRON FRAME WITHOUT ARMS
SC	2	32W T8/35K	METALUX # WS-232-120-EB81-UJ	SURFACE	4"x4" WRAPAROUND LENSED FLUORESCENT
SE	1	20W MH/T4	RSA # GES70-PM1356-20-15-AL-120	CEILING SURFACE	DIRECT FLUORESCENT
SF	1	21W T8/35K	COOPER #MS-2875-120-K12-EB51	SURFACE	UNDER CABINET LUMINAIRE
SFA	1	14W T8/35K	COOPER #MS-1475-120-K12-EB51	SURFACE	UNDER CABINET LUMINAIRE
SH	1	23W CF/35K	MARION #W618	SURFACE	HISTORIC REPRODUCTION WALL SCONCE
SJ	4	23W CF/35K	GRANT COURT #AA3426	SURFACE	HISTORIC REPRODUCTION GLOBE
TA	1	20W MH/T4	RSA # TEK1FTPA1XX-PM2356-20-15-WH-120	SURFACE	SURFACE TRACK, PROVIDE TRACK HEAD QUANTITY PER PLANS
WA	2	32W T5 HO/35K	NEORAY # 220W-1x1T9H-4-LEB-SL-582	WALL SURFACE	STAIR WALL SCONCE
WC	1	100W A19F	ADRA # ANWBAM-150-G	SURFACE	ELEVATOR PIT LIGHT
WE	1	70W MH/ED17	LUMARK # MH-710-120-EM-BK	SURFACE	WALL MOUNT METAL HALIDE
WD	1	54W T5 HO/35K	ELP #154 T-SCLLP-120	SURFACE	CONTINUOUS COVE
WEA	1	21W T5 HO/35K	ELP #121 T-SCLLP-120	SURFACE	CONTINUOUS COVE

* VERIFY CEILING TYPE WITH ARCHITECTURAL REFLECTED CEILING PLANS AND ROOM FINISH SCHEDULE.

TO BE UPDATED

ELECTRICAL SYMBOL LIST

SUBSCRIPTS ASSOCIATED WITH EXISTING ELECTRICAL EQUIPMENT

- "E" EXISTING TO REMAIN.
 - "R" EXISTING TO BE REMOVED.
 - "B" EXISTING TO BE BLANKED.
 - "RL" EXISTING TO BE RELOCATED. (REFER TO DRAWINGS FOR NEW LOCATION) EXTEND CONDUIT AND WIRING REQUIRED TO RECONNECT EXISTING EQUIPMENT.
 - "NL" NEW LOCATION OF RELOCATED EQUIPMENT. (REFER TO DRAWINGS) PROVIDE NEW CONDUIT AND WIRING REQUIRED TO RECONNECT EXISTING EQUIPMENT.
 - "RR" EXISTING EQUIPMENT REMOVED AND REPLACED WITH NEW EQUIPMENT. CONNECT TO EXISTING BRANCH CIRCUIT WIRING.
- INDICATES NO ELECTRICAL WORK UNLESS ROOM IS AFFECTED BY APPLICATION OF GENERAL ALTERATION NOTES.
- "PL" DENOTES OUTLET DEVICE WITH PLATE ONLY.

GENERAL NOTES

- UNLESS NOTED OTHERWISE, WHEREVER DESIGNATION "EMPTY CONDUIT" IS INDICATED ADJACENT TO TITLE OF A PARTICULAR SYSTEM, WORK OF THIS CONTRACT SHALL INCLUDE INSTALLATION OF EMPTY CONDUIT (WITH NYLON PULL CORD) AND BACK BOXES FOR THAT PARTICULAR SYSTEM ONLY. ANY SYSTEMS ARE SHOWN FOR INFORMATIONAL PURPOSES ONLY, AND WILL BE FURNISHED AND INSTALLED BY OTHERS.
- GENERAL DEMOLITION WORK SHALL BE DONE BY THE GENERAL CONTRACTOR. COORDINATE ALL WORK CONCERNING REMOVAL OF EXISTING EQUIPMENT, CONDUIT AND WIRING. DEENERGIZE ALL CIRCUITS.
- EXISTING CONDUIT IN CONCRETE CAN BE RE-USED IF POSSIBLE.
- IN EXISTING PORTION OF BUILDING, WALLS, FLOORS AND CEILINGS SHALL BE CHANNLED AND PATCHED BY GENERAL CONTRACTOR FOR INSTALLATION OF OUTLET BOXES, BACK BOXES AND CONDUIT. EXPOSED CONDUITS OR WIRING WILL NOT BE ACCEPTED.

SOUND/INTERCOM SYSTEM

- SPEAKER - FLUSH CEILING MOUNTED.
- S SPEAKER - FLUSH WALL MOUNTED UP 7'-6" A.F.F.
- S SPEAKER - SURFACE MOUNTED TO STRUCTURE.
- T TRUMPET SPEAKER.
- V VOLUME CONTROL - FLUSH WALL MOUNTED UP 5'-0" A.F.F.
- P PRIVACY SWITCH - FLUSH WALL MOUNTED UP 5'-0" A.F.F.
- M MICROPHONE OUTLET - OUTLET WALL MOUNTED UP 18" A.F.F.
- P PROJECTOR OUTLET - FLUSH WALL MOUNTED UP 18" A.F.F.
- C PROJECTOR CONTROL OUTLET.
- L LOCAL AMPLIFIER - FLUSH WALL MOUNTED.
- P TELEPHONE POWER PACK.
- A ASSISTED LISTENING SYSTEM ANTENNA.
- E ELECTRIC DOOR RELEASE LOCK/RELEASE.
- I INTERCOM DESK PHONE - CENTERLINE 18" A.F.F.
- I INTERCOM WALL PHONE - 4'-6" A.F.F.
- I INTERCOM - FLOOR MOUNTED.
- M MICROPHONE OUTLET - FLUSH MOUNTED IN FLOOR BOX.
- M MONITOR SPEAKER - FLUSH CEILING MOUNTED.
- PG PAGING PHONE OUTLET - CENTERLINE 18" A.F.F.

INTRUSION ALARM SYSTEM

- CARD READER - 4'-6" A.F.F.
- M1 MOTION ALARM DETECTOR - CEILING FLUSH MOUNTED. (NUMERAL DENOTES ZONE NO.)
- M2 MOTION ALARM DETECTOR - WALL SURFACE MOUNTED CENTERLINE 7'-6" A.F.F. (UNLESS OTHERWISE NOTED OR AS DIRECTED BY ARCHITECT)
- M3 PROXIMITY MOTION SENSOR.
- M4 ELECTRIC DOOR STRIKE.
- M5 CCTV CAMERA - "PTZ" INDICATES WITH PAN/ZOOM/TILT CONTROL.
- M6 REQUEST TO EXIT SWITCH - 4'-6" A.F.F.
- M7 MAGNETIC DOOR CONTACT - FLUSH MOUNTED IN HEAD OF DOOR FRAME. NUMERAL INDICATES ZONE NUMBER.

MISCELLANEOUS

- PANELBOARD.
- TERMINAL STRIP CABINET.
- DISCONNECT SWITCH - FUSED.
- DISCONNECT SWITCH - UNFUSED.
- ENCLOSED CIRCUIT BREAKER.
- DRY TYPE TRANSFORMER - NUMERAL INDICATES SIZE. REFER TO SCHEDULE.
- DRY TYPE TRANSFORMER FOR NON-LINEAR LOADS - NUMERAL INDICATES SIZE. REFER TO SCHEDULE.
- PHOTOCELL.
- JUNCTION BOX - CEILING MOUNTED.
- JUNCTION BOX - WALL MOUNTED.
- PUSHBUTTON WITH GUARD, PROVIDE NAMEPLATE "EMERGENCY SHUT-OFF" AND 2"X2" TO SHUNT TRIP IN MAIN CIRCUIT BREAKER.
- TIME SWITCH.
- EMERGENCY GENERATOR REMOTE ANNUNCIATOR. 5'-0" A.F.F.
- REMOTE LIGHTING PANIC CONTROL SWITCH - CENTERLINE UP 48" A.F.F.
- EMERGENCY GENERATOR SHUT DOWN.
- UNINTERRUPTABLE POWER SUPPLY.
- CONTACTOR.
- ELAPSED TIME CONTROLLER - CENTERLINE UP 4'-6" A.F.F.
- HAIR (OR HAND) DRYER OUTLET - WALL RECESSED, MOUNTING HEIGHT AS DIRECTED BY ARCHITECT.
- ELAPSED TIME INDICATOR - CENTERLINE 7'-6" A.F.F.
- BY-PASS RELAY. SEE DETAIL. NUMERAL INDICATES NUMBER OF POLES.
- TELEVISION OUTLET - CABLE OR MATV. REFER TO SPECIFICATIONS.
- LIMIT SWITCH.
- FIRE PUMP REMOTE ANNUNCIATOR. WIRED BY ELECTRICAL.
- AQUASTAT - FURNISHED BY OTHERS. WIRED BY ELECTRICAL.
- BUS DUCT.
- CT CABLE TRAY.
- HP HANDICAP PUSHBUTTON.

MOTOR CONTROLS

(REFER TO SPECIFICATIONS FOR STARTER REQUIREMENTS)

- MOTOR OUTLET - NUMERAL INDICATES HP.
- MANUAL MOTOR STARTER WITH THERMAL ELEMENT.
- MANUAL MOTOR STARTER WITH THERMAL ELEMENT & PILOT LIGHT.
- VARIABLE FREQUENCY DRIVE - WIRED BY ELECTRICAL.
- TWO-SPEED MAGNETIC ACROSS THE LINE MOTOR STARTER.
- COMBINATION MAGNETIC MOTOR STARTER WITH H.O.A. SELECTOR SWITCH, PILOT LIGHT AND FUSED SWITCH.
- COMBINATION MAGNETIC MOTOR STARTER WITH STOP-START PUSHBUTTONS, PILOT LIGHT AND FUSED SWITCH.
- COMBINATION MAGNETIC STARTER WITH PILOT LIGHT (LESS CONTROLS) AND UNFUSED SWITCH.
- FURNISHED BY OTHERS - INSTALLED BY ELECTRICAL.
- STOP/START PUSHBUTTON STATION WITH PILOT LIGHT.
- R- L RAISE/LOWER/OFF PUSHBUTTON STATION WITH PILOT LIGHT.

TELECOMMUNICATIONS SYSTEMS

CENTERLINE 18" A.F.F. EXCEPT AS NOTED. (NOTE: REFER TO RISER DIAGRAM FOR REQUIREMENTS)

- VOICE/VIDEO OUTLET - CENTERLINE 18" A.F.F.
- VOICE/VIDEO OUTLET - CENTERLINE 4'-6" A.F.F.
- VOICE/VIDEO OUTLET - MOUNTED ABOVE COUNTER OR BACK SPLASH.
- VOICE/VIDEO/VIDEO OUTLET.
- TELEPHONE OUTLET.
- TELEPHONE OUTLET FOR WALL PHONE - 4'-6" A.F.F.
- TELEPHONE OUTLET WALL PHONE - 4'-6" A.F.F. - "P" DENOTES PAY PHONE TELEPHONE CO.
- MASTER TELEPHONE OUTLET.

DOOR SIGNAL SYSTEM

- DB PUSHBUTTON FOR DOOR BUZZER SYSTEM.
- DOOR BELL.
- LOW VOLTAGE TRANSFORMER.

CLOSING SIGNALING SYSTEM

- BUZZER FOR CLOSING SIGNALING SYSTEM.
- CS PUSHBUTTON FOR CLOSING SIGNALING SYSTEM. SYSTEM.

LUMINAIRE AND OUTLET

- LUMINAIRE TYPE
- SWITCH CONTROL
- BRANCH CIRCUIT DESIGNATION.
- CEILING SURFACE MOUNTED.
- CEILING RECESSED MOUNTED.
- WALL MOUNTED.
- DIRECTIONAL
- FLUORESCENT.
- ILLUMINATED EXIT SIGN.
- INTEGRAL EMERGENCY BALLAST.
- TRACK LIGHTING.
- EMERGENCY BATTERY REMOTE LIGHTING HEADS.
- EMERGENCY LIGHTING BATTERY UNIT WITH HEADS.
- EMERGENCY BATTERY UNIT.
- REMOTE BALLAST.

TOGGLE SWITCHES

- CENTERLINE 4'-6" ABOVE FINISHED FLOOR (A.F.F.) REFER TO SPECIFICATIONS FOR MANUFACTURER AND CATALOG NUMBER. "X" INDICATES KEY OPERATED.)
- SINGLE POLE.
 - TWO POLE.
 - THREE WAY.
 - MULTI-GANGED.
 - MOMENTARY CONTACT SWITCH.
 - SINGLE POLE WITH PILOT LIGHT.
 - 600 WATT INCANDESCENT DIMMER.
 - 1,000 WATT INCANDESCENT DIMMER.
 - 2,000 WATT INCANDESCENT DIMMER.
 - FLUORESCENT DIMMER.
 - OCCUPANCY SENSOR WALL MOUNTED - REFER TO SCHEDULE.
 - OCCUPANCY SENSOR CEILING MOUNTED - REFER TO SCHEDULE.
 - LIGHTING CONTROL RELAY.

RECEPTACLES

CENTERLINE 18" A.F.F. EXCEPT AS NOTED. (REFER TO SPECIFICATIONS FOR MANUFACTURER AND CATALOG NUMBER) (NUMERAL INDICATES CIRCUIT NUMBER)

- 3 DUPLEX.
- DUPLEX - MOUNTED 4'-0" A.F.F.
- DUPLEX WIRED TO EMERGENCY. (RED DEVICE)
- DUPLEX - MOUNTED ABOVE COUNTER OR BACK SPLASH.
- DOUBLE DUPLEX.
- DUPLEX WITH GROUND FAULT PROTECTION.
- DUPLEX - PEDESTAL MOUNTED.
- DUPLEX - WEATHERPROOF TYPE.

HEAVY DUTY RECEPTACLE

SINGLE HEAVY DUTY RECEPTACLE WITH CORD AND CAP. - 36" A.F.F. EXCEPT AS NOTED

- 20A-125V, 2P, 3W, (5-20R)
- 30A-125V, 2P, 3W, (5-30R) (2P10 TO 30A-1P)
- 50A-125V, 2P, 3W, (5-50R) (288 TO 50A-1P)
- 20A-250V, 2P, 3W, (6-20R) (TO 20A-2P)
- 30A-250V, 2P, 3W, (6-30R) (2P10 TO 30A-2P)

RACEWAYS AND WIRING

(REFER TO SPECIFICATIONS FOR GROUND WIRES NOT SHOWN ON DRAWINGS) (REFER TO SPECIFICATIONS FOR WIRE AND HOMERUN REQUIREMENTS)

- HOMERUN TO PANEL "LH1"; CIRCUITS 1 AND 3. DIAGONAL LINES INDICATE NUMBER OF CONDUCTORS WHEN MORE THAN TWO.
- RUN CONCEALED.
- TURNING UP.
- TURNING DOWN.
- RUN UNDERGROUND, MINIMUM 30" BELOW FINISHED GRADE OR UNDER FLOOR SLAB.
- FLEXIBLE METAL CONDUIT.
- FEEDER IDENTITY NUMBER - REFER TO SCHEDULE.

MULTI-OUTLET ASSEMBLIES

VERIFY MOUNTING HEIGHTS WITH ARCHITECTURAL DWGS.

- WIREMOLD 2, 100 SERIES WITH 20A-125V SINGLE OUTLETS MOUNTED 6" O.C. ALTERNATELY WIRED.
- W3 WIREMOLD 3,000. REFER TO FLOOR PLANS FOR REQUIRED OUTLETS.
- W4 WIREMOLD 4,000 WITH BARRIER. REFER TO PLANS FOR REQUIRED OUTLETS.
- W6 WIREMOLD 6,000 WITH BARRIER. REFER TO FLOOR PLANS FOR REQUIRED OUTLETS.

DRAWING LIST

DWG. No.	DRAWING NAME	SHEET No.
E-1	ELECTRICAL SYMBOL LIST, NOTES, AND SCHEDULES	1 of 10
E-2	SITE PLAN - ELECTRICAL	2 of 10
E-3	BASEMENT AND GARDEN FLOOR - LIGHTING	3 of 10
E-3a	BASEMENT AND GARDEN FLOOR - POWER AND SYSTEMS	4 of 10
E-4	FIRST AND MEZZANINE PLAN - LIGHTING	5 of 10
E-4a	FIRST AND MEZZANINE PLAN - POWER AND SYSTEMS	6 of 10
E-5	SECOND AND PENTHOUSE PLAN - LIGHTING	7 of 10
E-5a	SECOND AND PENTHOUSE PLAN - POWER AND SYSTEMS	8 of 10
E-6	ELECTRICAL ONE-LINE DIAGRAM AND SCHEDULES	9 of 10
E-7	DIAGRAMS AND DETAILS	10 of 10

MECHANICAL EQUIPMENT SCHEDULE

MARK	DESCRIPTION	CHARACTERISTICS	VOLTS	PH.	CIRCUIT BREAKER	WIRE AND CONDUIT	ELECTRICAL CONNECTIONS						REMARKS	
							VFD	VP	QTY. SUPPLY	QTY. RETURN				
AC-1	AIR COOLED CONDENSING UNIT	CONDENSER: 1/6 HP COMPRESSOR: 9.6 FLA	208	3	20A-3P	3#12, 1#12GND, 3/4" C.	-	-	-	-	-	-	-	-
AC-2	AIR COOLED LIQUID CHILLER	COMP.: 4 @ 39.4 RLA COND.: 4 @ 4.1 FLA	208	3	225A-3P	3#30, 1#4GND, 2" C.	-	-	-	-	-	-	-	-
AC-3	AIR HANDLING UNIT	10 HP	208	3	70A-3P	3#8, 1#8GND, 1" C.	-	-	-	-	-	-	-	-
AC-4	AIR HANDLING UNIT	SUPPLY FAN 3 HP	208	3	15A-3P	3#12, 1#12GND, 3/4" C.	-	-	-	-	-	-	-	-
AC-5	AIR HANDLING UNIT	RETURN FAN 3 HP	208	3	15A-3P	3#12, 1#12GND, 3/4" C.	-	-	-	-	-	-	-	-
AC-6	AIR HANDLING UNIT	3 HP	208	3	20A-3P	3#12, 1#12GND, 3/4" C.	-	-	-	-	-	-	-	-
AC-7	BOILER	5 FLA	120	1	20A-1P	2#12, 1#12GND, 3/4" C.	-	-	-	-	-	-	-	-
AC-8	BOILER	5 FLA	120	1	20A-1P	2#12, 1#12GND, 3/4" C.	-	-	-	-	-	-	-	-
AC-9	CONDENSATE PUMP	1/40 HP	120	1	20A-1P	2#12, 1#12GND, 3/4" C.	-	-	-	-	-	-	-	-
AC-10	CABINET UNIT HEATER	1/10 HP	120	1	20A-1P	2#12, 1#12GND, 3/4" C.	-	-	-	-	-	-	-	-
AC-11	CABINET UNIT HEATER	1/10 HP	120	1	20A-1P	2#12, 1#12GND, 3/4" C.	-	-	-	-	-	-	-	-
AC-12	DUPLEX SEWAGE EJECTOR	(2) @ 11/2 HP	208	3	20A-3P	3#12, 1#12GND, 3/4" C.	-	-	-	-	-	-	-	-
AC-13	ELECTRIC DUCT HEATER	5 KW	208	3	20A-3P	3#12, 1#12GND, 3/4" C.	-	-	-	-	-	-	-	-
AC-14	ELECTRIC DUCT HEATER	5 KW	208	3	20A-3P	3#12, 1#12GND, 3/4" C.	-	-	-	-	-	-	-	-
AC-15	ELECTRIC DUCT HEATER	5 KW	208	3	20A-3P	3#12, 1#12GND, 3/4" C.	-	-	-	-	-	-	-	-
AC-16	ENERGY RECOVERY WHEEL	1/6 HP	208	1	15A-2P	2#12, 1#12GND, 3/4" C.	-	-	-	-	-	-	-	-
AC-17	WATER HEATER	4.5 KW	208	1	30A-2P	2#10, 1#10GND, 3/4" C.	-	-	-	-	-	-	-	-
AC-18	WATER HEATER	1.5 KW	120	1	40A-1P	2#12, 1#12GND, 3/4" C.	-	-	-	-	-	-	-	-
AC-19	FAN	5 HP	208	3	20A-3P	3#8, 1#10GND, 3/4" C.	-	-	-	-	-	-	-	-
AC-20	FAN	3/4 HP	208	3	15A-3P	3#12, 1#12GND, 3/4" C.	-	-	-	-	-	-	-	-
AC-21	FAN	1/3 HP	120	1	20A-1P	2#12, 1#12GND, 3/4" C.	-	-	-	-	-	-	-	-
AC-22	FAN	1/6 HP	120	1	20A-1P	2#12, 1#12GND, 3/4" C.	-	-	-	-	-	-	-	-
AC-23	FAN COIL UNIT	(1) 1/6 HP	120	1	20A-1P	2#12, 1#12GND, 3/4" C.	-	-	-	-	-	-	-	-
AC-24	FAN COIL UNIT	(2) @ 1/16 HP	120	1	20A-1P	2								