

. . . Fire Protection by Computer Design

EASTERN FIRE PROTECTION
AUBURN, MAINE
207-784-1507

Job Name : AMERICAN TIRE DIST
Drawing : 1 OF 2
Location : PORTLAND, ME
Remote Area : SYSTEM#4
Contract : AU-5258-15
Data File : 5258 AMERICAN TIRE SYSTEM 4.WXF

HYDRAULIC CALCULATIONS
for

Project name: AMERICAN TIRE DIST
Location: PORTLAND, ME
Drawing no: 1 OF 2
Date: 1-19-15

Design

Remote area number: SYSTEM#4
Remote area location: SYSTEM#4 ROOF
Occupancy classification:
Density: 25 PSI - Gpm/SqFt
Area of application: 12 HEADS - SqFt
Coverage per sprinkler: N/A - SqFt
Type of sprinklers calculated: TYCO 25.2 ESFR PENDENT
No. of sprinklers calculated: 12
In-rack demand: - GPM
Hose streams: 250 - GPM
Total water required (including hose streams): 1922.37 - GPM @ 125.527 - Psi
Type of system: WET
Volume of dry or preaction system: N/A - Gal

Water supply information

Date: 12-12-14
Location: FIRE PUMP TEST
Source: EASTERN FIRE PROTECTION

Name of contractor: EASTERN FIRE PROTECTION
Address: AUBURN, MAINE
Phone number: 207-784-1507
Name of designer: GRD

Authority having jurisdiction: MAINE STATE FIRE MARSHAL


Notes: (Include peaking information or gridded systems here.) TOTAL SYSTEM DEMAND AND PRESSURE INDICATED AT DISCHARGE FLANGE OF FIRE PUMP

Water Supply Curve C

EASTERN FIRE PROTECTION
AMERICAN TIRE DIST

Page 2
Date

City Water Supply: C1 - Static Pressure : 90 C2 - Residual Pressure: 79 C2 - Residual Flow : 3078 City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow A1 - Adjusted Static: 92.166 A2 - Adj Resid : 85.759 @ 1500 A3 - Adj Resid : 78.602 @ 2250	Pump Data: P1 - Pump Churn Pressure : 70.8 P2 - Pump Rated Pressure : 60 P2 - Pump Rated Flow : 1500 P3 - Pump Pressure @ Max Flow : 39 P3 - Pump Max Flow : 2250 City Residual Flow @ 0 = 9587.40 City Residual Flow @ 20 = 8369.59 City Water @ 150% of Pump = 83.84	Demand: D1 - Elevation : 11.984 D2 - System Flow : 1672.37 D2 - System Pressure : 125.527 Hose (Demand) : 250 D3 - System Demand : 1922.37 Safety Margin : 5.527
-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------



Fittings Used Summary

EASTERN FIRE PROTECTION
AMERICAN TIRE DIST

Page 3
Date

Fitting Legend		1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24	
Aty	Alarm Tyco AV-1								14		23		24	23								
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	13
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40	40
L	NFPA 13 Long Turn Elbow	0.5	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40	40
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65						
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	121
Zca	Colt C200 Horz Butt	Fitting generates a Fixed Loss Based on Flow																				

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

SUPPLY ANALYSIS

Node at Source	Static Pressure	Residual Pressure	Flow	Available Pressure	Total Demand	Required Pressure
PO	See Information on Pump Curve			131.054	1922.37	125.527
TEST	90.0	79	3078.0	85.395	1922.37	85.395

NODE ANALYSIS

Node Tag	Elevation	Node Type	Pressure at Node	Discharge at Node	Notes
701	127.83		78.54		
702	127.83		78.55		
703	127.83		78.56		
704	127.83		78.57		
705	127.83		78.6		
706	127.83		78.62		
707	127.83		78.63		
600	132.67	25.2	25.0	126.0	
601	132.67	25.2	25.98	128.43	
602	132.67	25.2	29.55	137.0	
604	132.67	25.2	43.03	165.3	
603	132.67		46.05		
605	132.67	25.2	25.17	126.42	
606	132.67	25.2	26.15	128.86	
607	132.67	25.2	29.75	137.45	
609	132.67	25.2	43.31	165.83	
608	132.67		46.35		
610	132.67	25.2	25.03	126.08	
611	132.67	25.2	26.01	128.51	
612	132.67	25.2	29.59	137.08	
614	132.67	25.2	43.08	165.4	
613	132.67		46.11		
691A	132.67		75.4		
950	132.67		75.64		
692A	132.67		75.64		
951	132.67		75.69		
952	132.67		75.71		
953	132.67		75.73		
954	132.67		75.74		
693A	132.67		75.74		
955	132.67		75.76		
956	132.67		75.77		
957	132.67		75.78		
702A	132.67		75.81		
958	132.67		75.97		
694A	132.67		75.97		
959	132.67		76.02		
960	132.67		76.05		

NODE ANALYSIS (cont.)

Node Tag	Elevation	Node Type	Pressure at Node	Discharge at Node	Notes
961	132.67		76.08		
695A	132.67		76.29		
696A	132.67		76.58		
697A	132.67		76.79		
698A	132.67		76.89		
706A	132.67		76.79		
699	130.67		78.6		
699A	132.67		77.52		
700	130.67		78.84		
700A	132.67		77.71		
680	130.67		73.55		
681	130.67		73.55		
682	130.67		73.63		
691	130.67		76.09		
692	130.67		76.46		
693	130.67		76.58		
694	130.67		76.78		
695	130.67		77.13		
696	130.67		77.46		
697	130.67		77.66		
698	130.67		77.81		
684	130.67		73.82		
685	130.67		77.76		
A	130.67		78.88		
TR4	130.67		82.58		
BR4	101.0		99.99		
UG3	100.0		106.82		
UG4	100.0		102.26	250.0	
50	100.0		107.3		
FLG	100.0		110.24		
PO	100.0		125.53		
PI	100.0		82.03		
BASE	100.0		83.5		
TEST	105.0		85.4		

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
701 to 702	127.830 127.830		29.38 29.38	4 4.26	0.0 0.0	11.250 0.0	120 0.0003	78.543 0.003		Vel = 0.66	
702 to 703	127.830 127.830		27.71 57.09	4 4.26	0.0 0.0	10.000 10.000	120 0.0010	78.546 0.010		Vel = 1.29	
703 to 704	127.830 127.830		18.53 75.62	4 4.26	0.0 0.0	11.250 11.250	120 0.0016	78.556 0.018		Vel = 1.70	
704 to 705	127.830 127.830		11.52 87.14	4 4.26	0.0 0.0	11.330 11.330	120 0.0022	78.574 0.025		Vel = 1.96	
705 to 706	127.830 127.830		-7.41 79.73	4 4.26	0.0 0.0	11.250 11.250	120 0.0018	78.599 0.020		Vel = 1.79	
706 to 707	127.830 127.830		-17.16 62.57	4 4.26	0.0 0.0	10.000 10.000	120 0.0012	78.619 0.012		Vel = 1.41	
707 to 708	127.830 0		-29.76 32.81	4 4.26	0.0 0.0	11.250 11.250	120 0.0004	78.631 0.004		Vel = 0.74	
708			0.0 32.81					133.998		K Factor = 2.83	
600 to 601	132.67 132.67	25.20	126.00 126.0	2 2.157	0.0 0.0	8.330 0.0	120 0.1170	25.000 0.975		Vel = 11.06	
601 to 602	132.67 132.67	25.20	128.43 254.43	2 2.157	0.0 0.0	8.330 8.330	120 0.4297	25.975 3.579		Vel = 22.34	
602 to 603	132.67 132.670	25.20	137.00 391.43	2 2.157	T 0.0	12.307 12.307	120 0.9533	29.554 16.498		Vel = 34.37	
603			0.0 391.43					46.052		K Factor = 57.68	
604 to 603	132.670 132.670	25.20	165.30 165.3	2 2.157	T 0.0	12.307 12.307	120 0.1935	43.027 0.025		Vel = 14.51	
603 to 680	132.670 130.670		391.43 556.73	2 2.157	T 0.0	12.307 12.307	120 1.8292	46.052 0.866		Vel = 48.88	
680			0.0 556.73					73.546		K Factor = 64.92	
605 to 606	132.67 132.670	25.20	126.42 126.42	2 2.157	0.0 0.0	8.330 8.330	120 0.1178	25.168 0.981		Vel = 11.10	

Final Calculations - Hazen-Williams

EASTERN FIRE PROTECTION
AMERICAN TIRE DIST

Page 7
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
606 to 607	132.670 132.67	25.20	128.86 255.28	2		0.0 0.0	8.330 0.0	120 0.4323	26.149 0.0 3.601			Vel = 22.41
607 to 608	132.67 132.670	25.20	137.45 392.73	2	T	12.307 0.0	5.000 12.307	120 0.9591	29.750 0.0 16.600			Vel = 34.48
608			0.0 392.73						46.350			K Factor = 57.69
609 to 608	132.670 132.670	25.20	165.84 165.84	2	T	12.307 0.0	3.330 12.307 15.637	120 0.1947	43.306 0.0 3.044			Vel = 14.56
608 to 681	132.670 130.670		392.73 558.57	2	T	12.307 0.0	2.000 12.307 14.307	120 1.8404	46.350 0.866 26.330			Vel = 49.04
681			0.0 558.57						73.546			K Factor = 65.13
610 to 611	132.67 132.670	25.20	126.08 126.08	2		0.0 0.0	8.330 0.0	120 0.1172	25.031 0.0 0.976			Vel = 11.07
611 to 612	132.670 132.67	25.20	128.51 254.59	2		0.0 0.0	8.330 0.0	120 0.4301	26.007 0.0 3.583			Vel = 22.35
612 to 613	132.67 132.670	25.20	137.08 391.67	2	T	12.307 0.0	5.000 12.307 17.307	120 0.9544	29.590 0.0 16.518			Vel = 34.39
613			0.0 391.67						46.108			K Factor = 57.68
614 to 613	132.670 132.670	25.20	165.40 165.4	2	T	12.307 0.0	3.330 12.307 15.637	120 0.1937	43.079 0.0 3.029			Vel = 14.52
613 to 682	132.670 130.670		391.67 557.07	2	T	12.307 0.0	2.250 12.307 14.557	120 1.8312	46.108 0.866 26.657			Vel = 48.91
682			0.0 557.07						73.631			K Factor = 64.92
691A to 691	132.670 130.670		-29.38 -29.38	2	E T	6.153 12.307	4.000 18.460	120 -0.0079	75.403 0.866 -0.178			Vel = 2.58
691			0.0 -29.38						76.091			K Factor = -3.37
691A to 701	132.670 127.830		29.38 29.38	2	2I 2T	8.615 24.613	98.500 33.228	120 0.0079	75.403 2.096 1.044			Vel = 2.58
701			0.0 29.38						78.543			K Factor = 3.32

Final Calculations - Hazen-Williams

EASTERN FIRE PROTECTION
AMERICAN TIRE DIST

Page 8
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
950 to 692A	132.670 132.670	.0	0.0	2	T	12.307 0.0	3.500 12.307	120	75.640 0.0			
692A to 692	132.670 130.670		0.0	2.157		0.0	15.807	0	0.0	Vel = 0		
692A to 692	132.670 130.670		-16.83	2	T	12.307 0.0	2.500 12.307	120	75.640 0.866			
692 to 692			-16.83			0.0	14.807	-0.0028	-0.042	Vel = 1.48		
692A to 951	132.670 132.670		0.0			0.0			76.464	K Factor = -1.92		
692A to 951	132.670 132.670		16.83	2	T	12.307 0.0	4.830 12.307	120	75.640 0.0			
951 to 952	132.670 132.670		16.83	2.157		0.0	17.137	0.0028	0.048	Vel = 1.48		
951 to 952	132.670 132.670		0.0	2		0.0	8.000	120	75.688			
952 to 953	132.670 132.670		16.83	2.157		0.0	8.000	0.0028	0.022	Vel = 1.48		
952 to 953	132.670 132.670		0.0	2		0.0	8.000	120	75.710			
953 to 702A	132.670 132.670		16.83	2.157		0.0	8.000	0.0029	0.023	Vel = 1.48		
953 to 702A	132.670 132.670		0.0	2	I T	4.307 12.307	11.670 16.614	120	75.733 0.0			
702A to 702A			16.83	2.157		0.0	28.284	0.0028	0.080	Vel = 1.48		
702A to 954			0.0			0.0			75.813	K Factor = 1.93		
702A to 954			16.83									
954 to 693A	132.670 132.670	.0	0.0	2	T	12.307 0.0	3.500 12.307	120	75.737 0.0			
693A to 693	132.670 130.670		0.0	2.157		0.0	15.807	0	0.0	Vel = 0		
693A to 693	132.670 130.670		-10.88	2	T	12.307 0.0	2.500 12.307	120	75.737 0.866			
693 to 693			-10.88	2.157		0.0	14.807	-0.0013	-0.019	Vel = 0.96		
693A to 955	132.670 132.670		0.0			0.0			76.584	K Factor = -1.24		
693A to 955	132.670 132.670		-10.88									
693A to 955	132.670 132.670		10.88	2	T	12.307 0.0	4.830 12.307	120	75.737 0.0			
955 to 956	132.670 132.670		10.88	2.157		0.0	17.137	0.0013	0.022	Vel = 0.96		
955 to 956	132.670 132.670		0.0	2		0.0	8.000	120	75.759			
956 to 957	132.670 132.670		10.88	2.157		0.0	8.000	0.0012	0.010	Vel = 0.96		
956 to 957	132.670 132.670		0.0	2		0.0	8.000	120	75.769			
957 to 702A	132.670 132.670		10.88	2.157		0.0	8.000	0.0012	0.010	Vel = 0.96		
957 to 702A	132.670 132.670		0.0	2	I T	4.307 12.307	10.500 16.614	120	75.779 0.0			
702A to 702	132.670 127.830		10.88	2.157		0.0	27.114	0.0013	0.034	Vel = 0.96		
702A to 702	132.670 127.830		16.83	2	2T	24.613 0.0	65.000 24.613	120	75.813 2.096			
702 to 702			27.71	2.157		0.0	89.613	0.0071	0.637	Vel = 2.43		

Final Calculations - Hazen-Williams

EASTERN FIRE PROTECTION
AMERICAN TIRE DIST

Page 9
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
702			0.0 27.71						78.546		K Factor = 3.13	
958 to 694A	132.670 132.670	.0	0.0	2	T	12.307 0.0	3.500 12.307	120	75.966 0.0			
694A to 694	132.670 130.670		0.0	2.157		0.0	15.807	0	0.0		Vel = 0	
694A to 694	132.670 130.670		-18.52	2	T	12.307 0.0	2.500 12.307	120	75.966 0.866			
694			0.0 -18.52						76.782		K Factor = -2.11	
694A to 959	132.670 132.670		18.52	2	T	12.307 0.0	4.830 12.307	120	75.966 0.0			
959 to 960	132.670 132.670		18.52	2.157		0.0	17.137	0.0034	0.058		Vel = 1.63	
959 to 960	132.670 132.670		0.0	2		0.0	8.000	120	76.024 0.0			
960 to 961	132.670 132.670		18.52	2.157		0.0	8.000	0.0032	0.026		Vel = 1.63	
960 to 961	132.670 132.670		0.0	2		0.0	8.000	120	76.050 0.0			
961 to 703	132.670 127.830		18.52	2.157		0.0	8.000	0.0035	0.028		Vel = 1.63	
961 to 703	132.670 127.830		0.0	2	2I 2T	8.615 24.613	80.000 33.228	120	76.078 2.096			
703			0.0 18.52				113.228	0.0034	0.382		Vel = 1.63	
703			0.0 18.52						78.556		K Factor = 2.09	
695A to 695	132.670 130.670		-11.52	2	E T	6.153 12.307	6.000 18.460	120	76.294 0.866			
695			0.0 -11.52				24.460	-0.0014	-0.034		Vel = 1.01	
695			0.0 -11.52						77.126		K Factor = -1.31	
695A to 704	132.670 127.830		11.52	2	2I 2T	8.615 24.613	98.250 33.228	120	76.294 2.096			
704			11.52	2.157		0.0	131.478	0.0014	0.184		Vel = 1.01	
704			0.0 11.52						78.574		K Factor = 1.30	
696A to 696	132.670 130.670		7.40	2	E T	6.153 12.307	6.000 18.460	120	76.584 0.866			
696			7.4	2.157		0.0	24.460	0.0006	0.015		Vel = 0.65	
696			0.0 7.40						77.465		K Factor = 0.84	
696A to 705	132.670 127.830		-7.40	2	2I 2T	8.615 24.613	98.500 33.228	120	76.584 2.096			
705			-7.4	2.157		0.0	131.728	-0.0006	-0.081		Vel = 0.65	
705			0.0 -7.40						78.599		K Factor = -0.83	
697A to 697	132.670 130.670		2.58	2	T	12.307 0.0	2.250 12.307	120	76.790 0.866			
697			2.58	2.157		0.0	14.557	0.0001	0.002		Vel = 0.23	

Final Calculations - Hazen-Williams

EASTERN FIRE PROTECTION
AMERICAN TIRE DIST

Page 10
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
697			0.0 2.58					77.658		K Factor = 0.29	
697A to 706A	132.670 132.670		-2.58	2	I T	4.307 12.307	34.250 16.614	120	76.790 0.0		
			-2.58	2.157		0.0	50.864	-0.0001	-0.004	Vel = 0.23	
706A			0.0 -2.58					76.786		K Factor = -0.29	
698A to 698	132.670 130.670		14.58	2	E T	6.153 12.307	5.500 18.460	120	76.892 0.866		
			14.58	2.157		0.0	23.960	0.0022	0.052	Vel = 1.28	
698			0.0 14.58					77.810		K Factor = 1.65	
698A to 706A	132.670 132.670		-14.58	2	I T	4.307 12.307	32.500 16.614	120	76.892 0.0		
			-14.58	2.157		0.0	49.114	-0.0022	-0.106	Vel = 1.28	
706A to 706	132.670 127.830		-2.58	2	2T	24.613 0.0	65.000 24.613	120	76.786 2.096		
			-17.16	2.157		0.0	89.613	-0.0029	-0.263	Vel = 1.51	
706			0.0 -17.16					78.619		K Factor = -1.94	
699 to 699A	130.670 132.670		-29.76	2	2T	24.613 0.0	2.500 24.613	120	78.601 -0.866		
			-29.76	2.157		0.0	27.113	-0.0081	-0.220	Vel = 2.61	
699A to 707	132.670 127.830		0.0	2	2T	24.613 0.0	96.250 24.613	120	77.515 2.096		
			-29.76	2.157		0.0	120.863	-0.0081	-0.980	Vel = 2.61	
707			0.0 -29.76					78.631		K Factor = -3.36	
700 to 700A	130.670 132.670		-32.81	2	2T	24.613 0.0	2.500 24.613	120	78.842 -0.866		
			-32.81	2.157		0.0	27.113	-0.0097	-0.263	Vel = 2.88	
700A to 708	132.670 0		0.0	2	2T	24.613 0.0	96.250 24.613	120	77.713 57.459		
			-32.81	2.157		0.0	120.863	-0.0097	-1.174	Vel = 2.88	
708			0.0 -32.81					133.998		K Factor = -2.83	
680 to 681	130.670 130.670		9.18	6		0.0 0.0	8.000 0.0	120	73.546 0.0		
			9.18	6.357		0.0	8.000	0	0.0	Vel = 0.09	
681 to 682	130.670 130.670		558.57	6		0.0 0.0	8.670 0.0	120	73.546 0.0		
			567.75	6.357		0.0	8.670	0.0098	0.085	Vel = 5.74	
682 to 691	130.670 130.670		557.07	6		0.0 0.0	70.750 0.0	120	73.631 0.0		
			1124.82	6.357		0.0	70.750	0.0348	2.460	Vel = 11.37	

Final Calculations - Hazen-Williams

EASTERN FIRE PROTECTION
AMERICAN TIRE DIST

Page 11
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
691 to 692	130.670 130.670		-29.39 1095.43	6 6.357	0.0 0.0	11.250 0.0	120 0.0332	76.091 0.0			
692 to 693	130.670 130.670		-16.82 1078.61	6 6.357	0.0 0.0	3.750 0.0	120 0.0320	76.464 0.120		Vel = 11.07	
693 to 694	130.670 130.670		-10.88 1067.73	6 6.357	0.0 0.0	6.250 0.0	120 0.0317	76.584 0.198		Vel = 10.90	
694 to 695	130.670 130.670		-18.53 1049.2	6 6.357	0.0 0.0	11.250 0.0	120 0.0306	76.782 0.344		Vel = 10.79	
695 to 696	130.670 130.670		-11.52 1037.68	6 6.357	0.0 0.0	11.330 0.0	120 0.0299	77.126 0.339		Vel = 10.61	
696 to 697	130.670 130.670		7.41 1045.09	6 6.357	0.0 0.0	6.330 0.0	120 0.0305	77.465 0.193		Vel = 10.56	
697 to 698	130.670 130.670		2.58 1047.67	6 6.357	0.0 0.0	5.000 0.0	120 0.0304	77.658 0.152		Vel = 10.59	
698 to A	130.670 130.670		14.58 1062.25	6 6.357	0.0 0.0	12.573 0.0	120 0.0313	77.810 0.0		Vel = 10.74	
A			0.0 1062.25					78.876		K Factor = 119.61	
680 to 684	130.670 130.670		547.55 547.55	6 6.357	21 0.0	25.147 0.0	120 0.0092	73.546 0.0		Vel = 5.53	
684 to 685	130.670 130.670		0.0 547.55	4 4.26	0.0 0.0	61.000 0.0	120 0.0645	73.822 3.934		Vel = 12.33	
685 to 699	130.670 130.670		0.0 547.55	6 6.357	0.0 0.0	92.000 0.0	120 0.0092	77.756 0.0		Vel = 5.53	
699 to 700	130.670 130.670		29.76 577.31	6 6.357	0.0 0.0	12.573 0.0	120 0.0101	78.601 0.241		Vel = 5.84	
700 to A	130.670 130.670		32.81 610.12	6 6.357	0.0 0.0	3.000 0.0	120 0.0113	78.842 0.034		Vel = 6.17	
A to TR4	130.670 130.670		1062.25 1672.37	6 6.357	21 0.0	25.147 0.0	120 0.0724	78.876 0.0		Vel = 16.91	
TR4 to BR4	130.670 101		0.0 1672.37	6 6.357	Aty G 0.0	30.176 3.772 0.0	120 0.0724	82.581 12.850 4.560		Vel = 16.91	

Final Calculations - Hazen-Williams

EASTERN FIRE PROTECTION
AMERICAN TIRE DIST

Page 12
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
BR4 to UG4	101 100		0.0 1672.37	8 7.98	E T G	27.183 52.855 6.041	30.000 86.077 116.077	150 0.0158	99.991 0.433 1.839		Vel = 10.73	
UG4			0.0 1672.37						102.263		K Factor = 165.38	
UG3 to 50	100 100		614.24 614.24	8 7.98	T	52.855 0.0 0.0	140.000 52.855 192.855	150 0.0025	106.822 0.0 0.479		Vel = 3.94	
50			0.0 614.24						107.301		K Factor = 59.30	
UG3 to UG4	100 100		-614.24 -614.24	8 7.98	6L 3G	117.791 18.122 0.0	1700.000 135.913 1835.913	150 -0.0025	106.822 0.0 -4.559		Vel = 3.94	
UG4 to 50	100 100	H250	1922.37 1308.13	8 7.98	2T 2L G	105.71 39.264 6.041	350.000 151.014 501.014	150 0.0101	102.263 0.0 5.038		Vel = 8.39	
50 to FLG	100 100		614.24 1922.37	8 7.98	2E T G	54.365 52.855 6.041	30.000 113.260 143.260	150 0.0205	107.301 0.0 2.937		Vel = 12.33	
FLG to PO	100 100		0.0 1922.37	8 8.249	S B 6l Zca	52.853 14.094 91.611 0.0	149.000 158.558 307.558	120 0.0264	110.238 7.183 8.106		* * Fixed Loss = 7.183 Vel = 11.54	
PO			0.0 1922.37						125.527		K Factor = 171.58	
System Demand Pressure									125.527			
Safety Margin									5.527			
Continuation Pressure									131.054			
Pressure @ Pump Outlet									131.054			
Pressure From Pump Curve									-49.026			
Pressure @ Pump Inlet									82.028			
PI to BASE	100 100		0.0 1922.37	8 8.249	G T	4.698 41.108 0.0	10.000 45.806 55.806	120 0.0264	82.028 0.0 1.471		Vel = 11.54	
BASE to TEST	100 105		0.0 1922.37	8 7.98	2L T G	39.264 52.855 6.041	100.000 98.159 198.159	150 0.0205	83.499 -2.166 4.062		Vel = 12.33	
TEST			0.0 1922.37						85.395		K Factor = 208.03	