

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK CITY OF PORTLAND

BUILDING DEPARTMENT


PERMIT

Permit Number: 100101

Please Read Application And Notes, If Any, Attached

This is to certify that DAVISON/BISSON LLC /Sprinkler System
has permission to Install Fire Suppression System Permit
AT 238 RIVERSIDE ST CB# 316 B002001

provided that the person or persons, firm or corporation accounting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of buildings and structures, and of the application on file in this department.



Apply to Public Works for street line and grade if nature of work requires such information.

Notification of inspection must be given and written permission procured before this building or part thereof is lathed or otherwise red-in. 24 HOUR NOTICE IS REQUIRED.

A certificate of occupancy must be procured by owner before this building or part thereof is occupied.

OTHER REQUIRED APPROVALS

Fire Dept. CAPT. R. Gauthier

Health Dept. FEB 23 2010

Appeal Board

Other

CITY OF PORTLAND

[Signature] 2/23/10
Director - Building & Inspection Services

PENALTY FOR REMOVING THIS CARD

City of Portland, Maine - Building or Use Permit Application

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 10-0101	Issue Date:	CBL: 316 B002001
-----------------------	-------------	---------------------

Location of Construction: 238 RIVERSIDE ST	Owner Name: DAVISON/BISSON LLC	Owner Address: 1111 LISBON ST	Phone:
Business Name:	Contractor Name: Sprinkler System, Inc	Contractor Address: P.O. Box 1285 Lewiston	Phone 2077820104
Lessee/Buyer's Name	Phone:	Permit Type: Fire Suppression System	Zone: B-4

Past Use: Commercial -PPG Paint - connected w/ permit# 091054 - Laker's Collision #09-0399	Proposed Use: Lockers Collision Commercial -PPG Paint - Install Fire Suppression System Permit	Permit Fee: \$50.00	Cost of Work: \$3,000.00	CEO District: 5
		FIRE DEPT: <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied * See Conditions	INSPECTION: Use Group: S-1/B Type Sprinkler IBC-2003 Signature: JMB 2/22/10	

Proposed Project Description:
Install Fire Suppression System Permit

Signature: *(KB)*
PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)
Action: Approved Approved w/Conditions Denied
Signature: _____ Date: _____

Permit Taken By: Idobson
Date Applied For: 02/04/2010

Zoning Approval

- This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules.
- Building permits do not include plumbing, septic or electrical work.
- Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

Special Zone or Reviews

Shoreland
 Wetland
 Flood Zone
 Subdivision
 Site Plan

Maj Minor MM

Date: 2/4/10 *AKB*

Zoning Appeal


Variance
 Miscellaneous
 Conditional Use
 Interpretation
 Approved
 Denied

Date: _____

Historic Preservation

Not in District or Landmark
 Does Not Require Review
 Requires Review
 Approved
 Approved w/Conditions
 Denied

Date: _____



CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE		DATE	PHONE

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 10-0101	Date Applied For: 02/04/2010	CBL: 316 B002001
------------------------------	--	----------------------------

Location of Construction: 238 RIVERSIDE ST	Owner Name: DAVISON/BISSON LLC	Owner Address: 1111 LISBON ST	Phone:
Business Name:	Contractor Name: Sprinkler System, Inc	Contractor Address: P.O. Box 1285 Lewiston	Phone: (207) 782-0104
Lessee/Buyer's Name	Phone:	Permit Type: Fire Suppression System	

Proposed Use: Commercial -PPG Paint & Lockards- connected w/ permit# 091054 & 090399 - Install Fire Suppression System Permit	Proposed Project Description: Install Fire Suppression System Permit
---	--

Dept: Zoning	Status: Approved with Conditions	Reviewer: Ann Machado	Approval Date: 02/04/2010
Note:			Ok to Issue: <input checked="" type="checkbox"/>
1) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.			
Dept: Building	Status: Approved with Conditions	Reviewer: Jeanine Bourke	Approval Date: 02/22/2010
Note:			Ok to Issue: <input checked="" type="checkbox"/>
1) Sprinkler systems to be designed and installed per IBC 2003 standards Sec. 903.3.1			
Dept: Fire	Status: Approved with Conditions	Reviewer: Capt Keith Gautreau	Approval Date: 02/12/2010
Note:			Ok to Issue: <input checked="" type="checkbox"/>
1) The Fire alarm and Sprinkler systems shall be reviewed by a licensed contractor[s] for code compliance. Compliance letters are required.			
2) The sprinkler system shall be installed in accordance with NFPA 13.			
3) Application requires State Fire Marshal approval.			
4) Fire department connection type and location shall be approved in writing by fire prevention bureau.			
5) System acceptance and commissioning must be co-ordinated with alarm and suppression system contractors and the Fire Department. Call 874-8703 to schedule.			



Fire Suppression System Permit

If you or the property owner owes real estate or property taxes or user charges on any property within the city, payment arrangements must be made before permits of any kind are accepted.

Installation address: 232-254 Riverside St. CBL: _____

Exact location: (within structure) Rear building - entire structure

Type of occupancy(s) (NFPA & ICC): Light Hazard / Ordinary Hazard Group 2

Building owner: Lockard's Collision

Managing Supervisor: Scott E. Garland License No: 278

Supervisor phone: 775-1521 E-mail: scottssi@maine.cc.com

Installing contractor: Sprinkler Systems Inc. License No: 093

Contractor phone: 775-1521 E-mail: Krissi@maine.cc.com

The suppression work to be done will be: New: Renovation: Addition to existing system:

This is an amendment to an existing permit: Yes: No: Permit no: _____

NFPA Standard will this system is designed to: NFPA #13 Edition: 2007

*Non-NFPA systems are not approved for use within the City of Portland.

Attach all design information and complete approved submittals as may be required by the State Fire Marshal's Office.

Contractor shall verify location and type of all FDCs shall be approved in writing by the Fire Prevention Bureau.

<p>COST OF WORK: <u>\$3,000</u></p> <p>PERMIT FEE: <u>\$50.</u></p> <p>(\$10 PER \$1,000 + \$30 FOR THE FIRST \$1,000)</p>
--

Download a new copy of this document from www.portlandmaine.gov for every submittal. Submit all information to the Building Inspections Department, 389 Congress Street, Room 315, Portland, Maine 04101.

Prior to acceptance of any fire protection system, a complete commissioning and acceptance test must be coordinated with all fire system contractors and the Fire Department, and proper documentation of such test(s) provided.

All installation(s) must comply with NFPA and the Fire Department Technical Standard(s).

RECEIVED

Applicant signature: _____ Date: 2-4-10

FEB - 4 2010

Dept. of Building Inspections
City of Portland Maine



State of Maine
Department of Public Safety



Fire Sprinkler System Permit

8712

Lockards Collision

Located at: 238-254 Riverside St
In the Town of: Portland
Occupancy/Use: Autobody Shop and Offices
Type of System: NFPA 13

RECEIVED

FEB - 4 2010

Permission is hereby given to:

Sprinkler Systems, Inc.
PO Box 1285
Lewiston, ME 042431285
Contractor License # 93

Dept. of Building Inspections
City of Portland Maine

according to plans submittal filed with the Licensing and Inspections Unit and are now approved. This application form/plans are filed under log # 2091268 , and no departure from application form/plans shall be made without prior approval in writing. This permit is issued under the provisions of Title 32, Chapter 20, Section 12004-I. Nothing herein shall excuse the holder of this permit for failure to comply with local ordinances, zoning laws, or other pertinent legal restrictions. Each permit issued shall be displayed/available at the site of construction.

This permit was issued on 7/22/2009 for a fee paid of \$100.00
This permit will expire at midnight on Monday, January 18, 2010

Anne H. Jordan
Commissioner

Fire Department Connection Location/Type per Local Fire Department

Within 30 days of the completion of a new fire sprinkler system or an addition to an existing fire sprinkler system, a fire sprinkler system contractor shall provide to the Licensing and Inspections Unit a copy of this permit signed and dated by the certified responsible managing supervisor representing that the fire sprinkler system has been installed according to specifications of the approved plan to the best of the supervisor's knowledge, information, and belief. This requirement is part of the sprinkler law, and neglect of this duty is grounds to not renew the contractor's license to do work in the State of Maine. All sprinkler licenses expire June 30th every year.

Job completed, tested and verified on date of _____

RMS for this job: Garland Scott E.

RMS Signature: _____



State of Maine
Department of Public Safety



Fire Sprinkler System Permit

8712

Lockards Collision

Located at: 238-254 Riverside St
 In the Town of: Portland
 Occupancy/Use: Autobody Shop and Offices
 Type of System: NFPA 13

Permission is hereby given to:

Sprinkler Systems, Inc.
 PO Box 1285
 Lewiston, ME 042431285
 Contractor License # 93

according to plans submittal filed with the Licensing and Inspections Unit and are now approved. This application form/plans are filed under log # **2091268**, and no departure from application form/plans shall be made without prior approval in writing. This permit is issued under the provisions of Title 32, Chapter 20, Section 12004-I. Nothing herein shall excuse the holder of this permit for failure to comply with local ordinances, zoning laws, or other pertinent legal restrictions. Each permit issued shall be displayed/available at the site of construction.

This permit was issued on **7/22/2009** for a fee paid of **\$100.00**
 This permit will expire at midnight on *Monday, January 18, 2010*

Anne H. Jordan
 Commissioner


Fire Department Connection Location/Type per Local Fire Department

Within 30 days of the completion of a new fire sprinkler system or an addition to an existing fire sprinkler system, a fire sprinkler system contractor shall provide to the Licensing and Inspections Unit a copy of this permit signed and dated by the certified responsible managing supervisor representing that the fire sprinkler system has been installed according to specifications of the approved plan to the best of the supervisor's knowledge, information, and belief. This requirement is part of the sprinkler law, and neglect of this duty is grounds to not renew the contractor's license to do work in the State of Maine. All sprinkler licenses expire June 30th every year.

Job completed, tested and verified on date of _____

RMS for this job: Garland Scott E.

RMS Signature: _____



RECEIVED

FEB - 4 2010

... Fire Protection by Computer Design

Dept. of Building Inspections
City of Portland Maine

Sprinkler Systems, Inc.
2-4 Avon Street
P.O. Box 1285
Lewiston, Maine 04240
207-782-0104

Job Name : LOCKARDS COLLISION
Building : OFFICE ADDITION
Location : 238-254 RIVERSIDE STREET, PORTLAND, ME 04102
System : 1 OF 1
Contract : 09002
Data File : LOCKARDSAUTO1.WXF

Hydraulic Design Information Sheet

Name - LOCKARDS COLLISION Date - 7-8-2009
 Location - 238-254 RIVERSIDE STREET, PORTLAND, ME 04102
 Building - OFFICE ADDITION System No. - 1 OF 1
 Contractor - PM CONSTRUCTION Contract No. - 09002
 Calculated By - KRISTOPHER J. FISH Drawing No. - 1 OF 1
 Construction: () Combustible (X) Non-Combustible Ceiling Height - 8-0
 Occupancy - ORDINARY HAZARD GROUP 2, 130 SF

S (X) NFPA 13 () Lt. Haz. Ord.Haz.Gp. () 1 (X) 2 () 3 () Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve
 S Other
 T Specific Ruling Made By Date

M Area of Sprinkler Operation - ENTIRE System Type Sprinkler/Nozzle
 Density - .2 () Wet Make RELIABLE
 D Area Per Sprinkler - 111 SF (X) Dry Model F1FR
 E Elevation at Highest Outlet - 74.208 () Deluge Size 1/2X1/2
 S Hose Allowance - Inside () Preaction K-Factor 5.6
 I Rack Sprinkler Allowance () Other Temp.Rat.155 DEG
 G Hose Allowance - Outside - 250 GPM AT X1
 N Note DESIGN AREA #1 - PARTS STORAGE ROOM

Calculation Flow Required - 410.394 Press Required - 39.732 AT TEST
 Summary C-Factor Used: 100 Overhead 140 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:
 A Date of Test - 9-8-2004 Cap. -
 T Time of Test - Rated Cap.- Elev.-
 E Static Press - 82 @ Press -
 R Residual Press - 78 Elev. - Well
 Flow - 1393 Proof Flow
 S Elevation - 54.5

U
 P Location - WATER FLOWED FROM HYD #1263 ON RIVERSIDE CT FROM A 12" DEAD END
 P CITY MAIN. TEST GUAGES READ FROM HYD #1264 ON RIVERSIDE ST
 L Source of Information - PORTLAND WATER DISTRICT
 Y

C Commodity Class Location
 O Storage Ht. Area Aisle W.
 M Storage Method: Solid Piled % Palletized % Rack
 M
 S R () Single Row () Conven. Pallet () Auto. Storage () Encap.
 T A () Double Row () Slave Pallet () Solid Shelf () Non
 O C () Mult. Row () Open Shelf
 R K Flue Spacing Clearance:Storage to Ceiling
 A Longitudinal Transverse
 G
 E Horizontal Barriers Provided:

Fittings Used Summary

Sprinkler Systems, Inc.
 LOCKARDS COLLISION

Fitting Legend Abbrev. Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
D Generic Dry Pipe Valve	0	0	0	0	0	0	9.5	17	0	28	0	47	0	0	0	0	0	0	0	0
E 90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T 90' Flow Thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
W Generic Wafer Check Vlv	0	0	0	0	0	0	0	0	0	10.3	0	13.1	31.8	35.8	27.4	0	0	0	0	0

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Pressure / Flow Summary - STANDARD

Sprinkler Systems, Inc.
 LOCKARDS COLLISION

Page 4
 Date 07-08-2009

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
TYP1	0.0	5.6	15.72	na	22.2	0.2	111	15.716
TYP2	0.0	5.6	7.0	na	14.82	0.2	74.081	7.0
1	74.208	K = K @ ARM1	18.88	na	22.86			
2	74.167	K = K @ ARM1	19.39	na	23.17			
3	74.208	K = K @ ARM1	19.52	na	23.25			
4	74.208	K = K @ ARM1	17.8	na	22.2			
5	74.167	K = K @ ARM2	18.01	na	22.32			
6	74.167	K = K @ ARM1	19.03	na	22.95			
7	74.208	K = K @ ARM1	20.18	na	23.64			
A	74.167		20.41	na				
B	74.167		21.1	na				
C	74.167		22.46	na				
D	74.125		23.57	na				
E	74.125		24.21	na				
G	74.125		24.73	na				
H	74.125		29.07	na				
N	74.0		31.04	na				
RT	72.208		31.81	na				
RB	67.792		33.81	na				
X1	54.5		39.7	na	250.0			
TEST	54.5		39.73	na				

The maximum velocity is 14.08 and it occurs in the pipe between nodes B and C

Final Calculations - Hazen-Williams

Sprinkler Systems, Inc.
 LOCKARDS COLLISION

Page 5
 Date 07-08-2009

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	***** Notes *****
TYP1 to ARM1	22.20 22.2	1.049 100 0.2212	2E 2.855 1T 3.568	3.000 6.423 9.423	15.716 0.0 2.084		K Factor = 5.60 Vel = 8.24
	0.0 22.20					17.800	K Factor = 5.26
TYP2 to ARM2	14.82 14.82	1.049 100 0.1047	2E 2.855 1T 3.568	2.500 6.423 8.923	7.000 0.0 0.934		K Factor = 5.60 Vel = 5.50
	0.0 14.82					7.934	K Factor = 5.26
1 to 2	22.86 22.86	1.442 100 0.0496		0.0 0.0 10.000	18.875 0.018 0.496		K Factor @ node ARM1 Vel = 4.49
2 to A	23.17 46.03	1.442 100 0.1809	1T 5.304	0.333 5.304 5.637	19.389 0.0 1.020		K Factor @ node ARM1 Vel = 9.04
	0.0 46.03					20.409	K Factor = 10.19
3 to A	23.25 23.25	1.442 100 0.0511	1T 5.304	11.667 5.304 16.971	19.523 0.018 0.868		K Factor @ node ARM1 Vel = 4.57
	0.0 23.25					20.409	K Factor = 5.15
4 to 5	22.20 22.2	1.442 100 0.0470		0.0 0.0 4.000	17.800 0.018 0.188		K Factor @ node ARM1 Vel = 4.36
5 to 6	22.32 44.52	1.442 100 0.1700		0.0 0.0 6.000	18.006 0.0 1.020		K Factor @ node ARM2 Vel = 8.75
6 to B	22.95 67.47	1.442 100 0.3672	1T 5.304	0.333 5.304 5.637	19.026 0.0 2.070		K Factor @ node ARM1 Vel = 13.25
	0.0 67.47					21.096	K Factor = 14.69
7 to B	23.64 23.64	1.442 100 0.0527	1T 5.304	11.667 5.304 16.971	20.183 0.018 0.895		K Factor @ node ARM1 Vel = 4.64
	0.0 23.64					21.096	K Factor = 5.15
A to B	69.28 69.28	2.157 100 0.0542		0.0 0.0 12.667	20.409 0.0 0.687		Vel = 6.08

Final Calculations - Standard

Sprinkler Systems, Inc.
 LOCKARDS COLLISION

Page 6
 Date 07-08-2009


Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
B	91.11	2.157	0.0	5.333	21.096				
to		100	0.0	0.0	0.0				
C	160.39	0.2565	0.0	5.333	1.368		Vel = 14.08		
C	0.0	2.157	0.0	4.250	22.464				
to		100	0.0	0.0	0.018				
D	160.39	0.2562	0.0	4.250	1.089		Vel = 14.08		
D	0.0	2.157	0.0	2.500	23.571				
to		100	0.0	0.0	0.0				
E	160.39	0.2564	0.0	2.500	0.641		Vel = 14.08		
E	0.0	2.157	0.0	2.000	24.212				
to		100	0.0	0.0	0.0				
G	160.39	0.2565	0.0	2.000	0.513		Vel = 14.08		
G	0.0	2.157	1T 8.783	8.167	24.725				
to		100	0.0	8.783	0.0				
H	160.39	0.2564	0.0	16.950	4.346		Vel = 14.08		
H	0.0	3.26	1E 6.714	34.583	29.071				
to		100	1T 14.388	21.101	0.054				
N	160.39	0.0343	0.0	55.684	1.910		Vel = 6.16		
N	0.0	6.357	0.0	1.792	31.035				
to		100	0.0	0.0	0.776				
RT	160.39	0.0017	0.0	1.792	0.003		Vel = 1.62		
RT	0.0	6.065	1D 47.0	4.417	31.814				
to		120	1W 13.1	63.100	1.913				
RB	160.39	0.0012	1G 3.0	67.517	0.080		Vel = 1.78		
RB	0.0	8.27	1E 28.468	600.292	33.807				
to		140	1G 6.326	90.148	5.757				
X1	160.39	0.0002	1T 55.354	690.440	0.136		Vel = 0.96		
X1	250.00	12.34	0.0	200.000	39.700		Qa = 250		
to		140	0.0	0.0	0.0				
TEST	410.39	0.0002	0.0	200.000	0.032		Vel = 1.10		
	0.0								
	410.39				39.732		K Factor = 65.11		


Water Supply Curve (C)

Sprinkler Systems, Inc.
 LOCKARDS COLLISION

City Water Supply:
 C1 - Static Pressure : 82
 C2 - Residual Pressure: 78
 C2 - Residual Flow : 1393

Demand:
 D1 - Elevation : 8.536
 D2 - System Flow : 160.394
 D2 - System Pressure : 39.732
 Hose (Adj City) : 250
 Hose (Demand) : 410.394
 D3 - System Demand : 41.851
 Safety Margin





... Fire Protection by Computer Design

Sprinkler Systems, Inc.
2-4 Avon Street
P.O. Box 1285
Lewiston, Maine 04240
207-782-0104

Job Name : LOCKARDS COLLISION
Building : OFFICE ADDITION
Location : 238-254 RIVERSIDE STREET, PORTLAND, ME 04102
System : 1 OF 1
Contract : 09002
Data File : LOCKARDSAUTO2.WXF

Hydraulic Design Information Sheet

Name - LOCKARDS COLLISION Date - 7-8-2009
 Location - 238-254 RIVERSIDE STREET, PORTLAND, ME 04102
 Building - OFFICE ADDITION System No. - 1 OF 1
 Contractor - PM CONSTRUCTION Contract No. - 09002
 Calculated By - KRISTOPHER J. FISH Drawing No. - 1 OF 1
 Construction: () Combustible (X) Non-Combustible Ceiling Height - 8-0
 Occupancy - LIGHT HAZARD - 225 SF

S (X) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. () 1 () 2 () 3 () Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve

S Other

T Specific Ruling Made By Date

E
 M Area of Sprinkler Operation - ENTIRE System Type Sprinkler/Nozzle
 Density - .1 () Wet Make RELIABLE
 D Area Per Sprinkler - 205.375 (X) Dry Model F1FR
 E Elevation at Highest Outlet - 74.208 () Deluge Size 1/2X1/2
 S Hose Allowance - Inside () Preaction K-Factor 5.6
 I Rack Sprinkler Allowance - () Other Temp.Rat.155 DEG
 G Hose Allowance - Outside - 100 GPM AT X1
 N

Note DESIGN AREA #2 - OFFICES

Calculation Flow Required - 594.301 Press Required - 50.576 AT TEST
 Summary C-Factor Used: 100 Overhead 140 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:
 A Date of Test - 9-8-2004 Cap. -
 T Time of Test - Rated Cap.- Elev.-
 E Static Press - 82 @ Press -
 R Residual Press - 78 Elev. - Well
 Flow - 1393 Proof Flow
 S Elevation - 54.5

U
 P Location - WATER FLOWED FROM HYD #1263 ON RIVERSIDE CT FROM A 12" DEAD END
 P CITY MAIN. TEST GUAGES READ FROM HYD #1264 ON RIVERSIDE ST
 L Source of Information - PORTLAND WATER DISTRICT
 Y

C Commodity Class Location
 O Storage Ht. Area Aisle W.
 M Storage Method: Solid Piled % Palletized % Rack
 M
 () Single Row () Conven. Pallet () Auto. Storage () Encap.
 S R () Double Row () Slave Pallet () Solid Shelf () Non
 T A () Mult. Row () Open Shelf

O C
 R K Flue Spacing Clearance:Storage to Ceiling
 A Longitudinal Transverse

G
 E Horizontal Barriers Provided:

Pressure / Flow Summary - STANDARD

Sprinkler Systems, Inc.
 LOCKARDS COLLISION

Page 10
 Date 07-08-2009

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
TYP1	0.0	5.6	7.0	na	14.82	0.1	148.162	7.0
TYP2	0.0	5.6	7.0	na	14.82	0.1	148.162	7.0
TYP3	0.0	5.6	10.86	na	18.45	0.1	184.505	10.855
TYP4	0.0	5.6	13.45	na	20.54	0.1	205.375	13.45
TYP5	0.0	5.6	7.0	na	14.82	0.1	148.162	7.0
TYP6	0.0	5.6	7.0	na	14.82	0.1	148.162	7.0
TYP7	0.0	5.6	12.22	na	19.58	0.1	195.75	12.219
8	74.208	K = K @ ARM1	17.41	na	22.02			
4	74.208		17.57	na				
5	74.167		17.77	na				
6	74.167		18.05	na				
9	74.167	K = K @ ARM1	17.98	na	22.38			
10	74.167	K = K @ ARM1	16.35	na	21.34			
11	74.167	K = K @ ARM2	16.67	na	21.48			
12	74.25	K = K @ ARM3	14.64	na	19.91			
13	74.167	K = K @ ARM4	15.25	na	20.54			
14	74.125	K = K @ ARM5	16.59	na	21.35			
15	74.167	K = K @ ARM1	14.31	na	19.96			
16	74.167	K = K @ ARM1	14.63	na	20.19			
F	74.167		14.65	na				
17	74.125	K = K @ ARM5	15.77	na	20.82			
18	74.167	K = K @ ARM2	19.46	na	23.21			
19	74.125	K = K @ ARM2	20.2	na	23.64			
20	74.125	K = K @ ARM6	20.68	na	23.57			
J1	74.125		23.99	na				
21	74.167	K = K @ ARM7	14.61	na	20.15			
22	74.125	K = K @ ARM2	14.99	na	20.36			
23	74.167	K = K @ ARM1	15.18	na	20.56			
24	74.125	K = K @ ARM1	15.49	na	20.77			
K	74.125		16.47	na				
25	74.167	K = K @ ARM2	19.9	na	23.47			
26	74.125	K = K @ ARM2	20.44	na	23.78			
M	74.125		21.55	na				
L	74.125		21.61	na				
27	74.083	K = K @ ARM1	23.09	na	25.36			
J	74.083		25.43	na				
B	74.167		18.31	na				
C	74.167		18.44	na				
D	74.125		18.56	na				
E	74.125		18.77	na				
G	74.125		19.21	na				
H	74.125		26.37	na				
28	74.083	K = K @ ARM2	28.29	na	27.98			
29	74.0	K = K @ ARM1	35.52	na	31.45			
N	74.0		40.31	na				
RT	72.208		41.1	na				
RB	67.792		43.66	na				
X1	54.5		50.51	na	100.0			
TEST	54.5		50.58	na				

The maximum velocity is 19.74 and it occurs in the pipe between nodes J and H

Final Calculations - Hazen-Williams

Sprinkler Systems, Inc.
 LOCKARDS COLLISION

Page 11
 Date 07-08-2009

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
TYP1 to ARM1	14.82 14.82	1.049 100 0.1047	2E 1T	2.855 3.568 0.0	2.000 6.423 8.423	7.000 0.0 0.882		K Factor = 5.60 Vel = 5.50	
	0.0 14.82					7.882		K Factor = 5.28	
TYP2 to ARM2	14.82 14.82	1.049 100 0.1047	2E 1T	2.855 3.568 0.0	2.500 6.423 8.923	7.000 0.0 0.934		K Factor = 5.60 Vel = 5.50	
	0.0 14.82					7.934		K Factor = 5.26	
TYP3 to ARM3	18.45 18.45	1.049 100 0.1571	2E 1T	2.855 3.568 0.0	4.500 6.423 10.923	10.855 0.0 1.716		K Factor = 5.60 Vel = 6.85	
	0.0 18.45					12.571		K Factor = 5.20	
TYP4 to ARM4	20.54 20.54	1.049 100 0.1914	2E 1T	2.855 3.568 0.0	3.000 6.423 9.423	13.450 0.0 1.804		K Factor = 5.60 Vel = 7.62	
	0.0 20.54					15.254		K Factor = 5.26	
TYP5 to ARM5	14.82 14.82	1.049 100 0.1046	2E 1T	2.855 3.568 0.0	3.000 6.423 9.423	7.000 0.0 0.986		K Factor = 5.60 Vel = 5.50	
	0.0 14.82					7.986		K Factor = 5.24	
TYP6 to ARM6	14.82 14.82	1.049 100 0.1046	2E 1T	2.855 3.568 0.0	4.750 6.423 11.173	7.000 0.0 1.169		K Factor = 5.60 Vel = 5.50	
	0.0 14.82					8.169		K Factor = 5.19	
TYP7 to ARM7	19.58 19.58	1.049 100 0.1753	2E 1T	2.855 3.568 0.0	2.500 6.423 8.923	12.219 0.0 1.564		K Factor = 5.60 Vel = 7.27	
	0.0 19.58					13.783		K Factor = 5.27	
8 to 4	22.02 22.02	1.442 100 0.0463		0.0 0.0 0.0	3.500 0.0 3.500	17.410 0.0 0.162		K Factor @ node ARM1 Vel = 4.33	
4 to 5	0.0 22.02	1.442 100 0.0460		0.0 0.0 0.0	4.000 0.0 4.000	17.572 0.018 0.184		Vel = 4.33	

Final Calculations - Standard

Sprinkler Systems, Inc.
 LOCKARDS COLLISION

Page 12
 Date 07-08-2009

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
5	0.0	1.442		6.000	17.774				
to		100		0.0	0.0				
6	22.02	0.0463		6.000	0.278		Vel = 4.33		
6	0.0	1.442	1T	5.304	0.333	18.052			
to		100		0.0	5.304	0.0			
B	22.02	0.0463		0.0	5.637	0.261	Vel = 4.33		
	0.0								
	22.02				18.313		K Factor = 5.15		
9	22.38	1.442	1T	5.304	1.667	17.980		K Factor @ node ARM1	
to		100		0.0	5.304	0.0			
B	22.38	0.0478		0.0	6.971	0.333	Vel = 4.40		
	0.0								
	22.38				18.313		K Factor = 5.23		
10	21.34	1.442		7.500	16.345			K Factor @ node ARM1	
to		100		0.0	0.0	0.0			
11	21.34	0.0437		7.500	0.328		Vel = 4.19		
11	21.47	1.442	1T	5.304	6.500	16.673		K Factor @ node ARM2	
to		100		0.0	5.304	0.018			
D	42.81	0.1583		0.0	11.804	1.868	Vel = 8.41		
	0.0								
	42.81				18.559		K Factor = 9.94		
12	19.91	1.442		15.000	14.642			K Factor @ node ARM3	
to		100		0.0	0.036				
13	19.91	0.0384		15.000	0.576		Vel = 3.91		
13	20.54	1.442		9.250	15.254			K Factor @ node ARM4	
to		100		0.0	0.018				
14	40.45	0.1426		9.250	1.319		Vel = 7.95		
14	21.36	1.442	1T	5.304	1.667	16.591		K Factor @ node ARM5	
to		100		0.0	5.304	0.0			
E	61.81	0.3122		0.0	6.971	2.176	Vel = 12.14		
	0.0								
	61.81				18.767		K Factor = 14.27		
15	19.96	1.442	1T	5.304	3.667	14.308		K Factor @ node ARM1	
to		100		0.0	5.304	0.0			
F	19.96	0.0386		0.0	8.971	0.346	Vel = 3.92		
	0.0								
	19.96				14.654		K Factor = 5.21		
16	20.19	1.442		0.500	14.634			K Factor @ node ARM1	
to		100		0.0	0.0				
F	20.19	0.0400		0.500	0.020		Vel = 3.97		
F	19.96	1.442		7.833	14.654				
to		100		0.0	0.0	0.018			
17	40.15	0.1406		7.833	1.101		Vel = 7.89		

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
17 to G	20.82 60.97 0.0 60.97	1.442 100 0.3044	1T 5.304 0.0 0.0	6.000 5.304 11.304	15.773 0.0 3.441			K Factor @ node ARM5 Vel = 11.98	
						19.214		K Factor = 13.91	
18 to 19	23.21 23.21	1.442 100 0.0510	0.0 0.0 0.0	14.000 0.0 14.000	19.464 0.018 0.714			K Factor @ node ARM2 Vel = 4.56	
19 to 20	23.63 46.84	1.442 100 0.1866	0.0 0.0 0.0	2.583 0.0 2.583	20.196 0.0 0.482			K Factor @ node ARM2 Vel = 9.20	
20 to J1	23.58 70.42	1.442 100 0.3975	0.0 0.0 0.0	8.333 0.0 8.333	20.678 0.0 3.312			K Factor @ node ARM6 Vel = 13.83	
J1 to J	0.0 70.42 0.0 70.42	1.682 100 0.1877	1T 7.065 0.0 0.0	0.500 7.066 7.566	23.990 0.018 1.420			Vel = 10.17	
						25.428		K Factor = 13.96	
21 to 22	20.15 20.15	1.442 100 0.0392	0.0 0.0 0.0	9.250 0.0 9.250	14.608 0.018 0.363			K Factor @ node ARM7 Vel = 3.96	
22 to K	20.37 40.52 0.0 40.52	1.442 100 0.1429	0.0 0.0 0.0	10.333 0.0 10.333	14.989 0.0 1.477			K Factor @ node ARM2 Vel = 7.96	
						16.466		K Factor = 9.99	
23 to 24	20.56 20.56	1.442 100 0.0408	0.0 0.0 0.0	7.250 0.0 7.250	15.180 0.018 0.296			K Factor @ node ARM1 Vel = 4.04	
24 to K	20.78 41.34	1.442 100 0.1483	1T 5.304 0.0 0.0	1.250 5.304 6.554	15.494 0.0 0.972			K Factor @ node ARM1 Vel = 8.12	
K to L	40.51 81.85 0.0 81.85	1.442 100 0.5249	1T 5.304 0.0 0.0	4.500 5.304 9.804	16.466 0.0 5.146			Vel = 16.08	
						21.612		K Factor = 17.61	
25 to 26	23.47 23.47	1.442 100 0.0521	0.0 0.0 0.0	10.000 0.0 10.000	19.904 0.018 0.521			K Factor @ node ARM2 Vel = 4.61	

Final Calculations - Standard

Sprinkler Systems, Inc.
 LOCKARDS COLLISION

Page 14
 Date 07-08-2009

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	***** Notes *****
26 to M	23.78 47.25	1.442 100 0.1899	1T 5.304 0.0	0.500 5.304 5.804	20.443 0.0 1.102		K Factor @ node ARM2 Vel = 9.28
M to L	0.0 47.25	2.157 100 0.0268	0.0 0.0 0.0	2.500 0.0 2.500	21.545 0.0 0.067		Vel = 4.15
L to 27	81.85 129.1	2.157 100 0.1716	0.0 0.0 0.0	8.500 0.0 8.500	21.612 0.018 1.459		Vel = 11.33
27 to J	25.36 154.46	2.157 100 0.2391	1T 8.783 0.0	1.000 8.783 9.783	23.089 0.0 2.339		K Factor @ node ARM1 Vel = 13.56
J to H	70.42 224.88	2.157 100 0.4790	0.0 0.0 0.0	2.000 0.0 2.000	25.428 -0.018 0.958		Vel = 19.74
	0.0 224.88				26.368		K Factor = 43.79
B to C	44.40 44.4	2.157 100 0.0238	0.0 0.0 0.0	5.333 0.0 5.333	18.313 0.0 0.127		Vel = 3.90
C to D	0.0 44.4	2.157 100 0.0238	0.0 0.0 0.0	4.250 0.0 4.250	18.440 0.018 0.101		Vel = 3.90
D to E	42.81 87.21	2.157 100 0.0832	0.0 0.0 0.0	2.500 0.0 2.500	18.559 0.0 0.208		Vel = 7.66
E to G	61.81 149.02	2.157 100 0.2235	0.0 0.0 0.0	2.000 0.0 2.000	18.767 0.0 0.447		Vel = 13.08
G to H	60.97 209.99	2.157 100 0.4221	1T 8.783 0.0	8.167 8.783 16.950	19.214 0.0 7.154		Vel = 18.44
H to 28	224.88 434.87	3.26 100 0.2171	0.0 0.0 0.0	8.750 0.0 8.750	26.368 0.018 1.900		Vel = 16.72
28 to 29	27.98 462.85	3.26 100 0.2437	1E 6.714 0.0	22.833 6.714 29.547	28.286 0.036 7.200		K Factor @ node ARM2 Vel = 17.79
29 to N	31.45 494.3	3.26 100 0.2752	1T 14.388 0.0	3.000 14.387 17.387	35.522 0.0 4.785		K Factor @ node ARM1 Vel = 19.00

Final Calculations - Standard

Sprinkler Systems, Inc.
 LOCKARDS COLLISION

Page 15
 Date 07-08-2009

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
N	0.0	6.357	0.0	1.792	40.307				
to		100	0.0	0.0	0.776				
RT	494.3	0.0106	0.0	1.792	0.019		Vel = 5.00		
RT	0.0	6.065	1D 47.0	4.417	41.102				
to		120	1W 13.1	63.100	1.913				
RB	494.3	0.0096	1G 3.0	67.517	0.645		Vel = 5.49		
RB	0.0	8.27	1E 28.468	600.292	43.660				
to		140	1G 6.326	90.148	5.757				
X1	494.3	0.0016	1T 55.354	690.440	1.095		Vel = 2.95		
X1	100.00	12.34	0.0	200.000	50.512		Qa = 100		
to		140	0.0	0.0	0.0				
TEST	594.3	0.0003	0.0	200.000	0.064		Vel = 1.59		
	0.0								
	594.30				50.576		K Factor = 83.57		

Water Supply Curve (C)

Sprinkler Systems, Inc.
 LOCKARDS COLLISION

City Water Supply:
 C1 - Static Pressure : 82
 C2 - Residual Pressure: 78
 C2 - Residual Flow : 1393

Demand:
 D1 - Elevation : 8.518
 D2 - System Flow : 494.301
 D2 - System Pressure : 50.576
 Hose (Adj City)
 Hose (Demand) : 100
 D3 - System Demand : 594.301
 Safety Margin : 30.597

