

ELECTRICAL PERMIT

City of Portland, Me.



11:30
1/9/97

To the Chief Electrical Inspector, Portland Maine:
The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the City of Portland Electrical Ordinance, National Electrical code and the following specification:

Date 05 December 1996

Permit # 16872

LOCATION: 270 Riverside St

OWNER Tidy-Up Carwash

ADDRESS Global Gas Mart

316-3-008

							TOTAL EACH FEE				
OUTLETS		Receptacles		Switches		Smoke Detector			.20		
FIXTURES		(number of)									
		incandescent		fluorescent				20	.20	4.00	
		fluorescent strip							.20		
SERVICES											
		Overhead				TTL AMPSTO	800		15.00		
		Underground					800		15.00		
TEMPORARY SERV.											
		Overhead				AMPS OVER	800		25.00		
		Underground					800		25.00		
METERS		(number of)							1.00		
MOTORS		(number of)						5	2.00	10.00	
RESID/COM		Electric units							1.00		
HEATING		oil/gas units							5.00		
APPLIANCES		Ranges		Cook Tops		Wall Ovens			2.00		
		Water heaters		Fans		Dryers			2.00		
Disposals		Dishwasher		Compactors		Others (denote)			2.00		
MISC. (number of)		Air Cond/win							3.00		
		Air Cond/cent							10.00		
		Signs							5.00		
		Pools							10.00		
		Alarms/res							5.00		
		Alarms/com							15.00		
		Heavy Duty							2.00		
		Outlets									
		Circus/Carnv							25.00		
		Alterations							5.00		
		Fire Repairs							15.00		
		E Lights							1.00		
		E Generators							20.00		
		Panels							4.00		
TRANSFORMER		0-25 Kva							5.00		
		25-200 Kva							8.00		
		Over 200 Kva							10.00		
							TOTAL AMOUNT DUE				
							MINIMUM FEE/COMMERCIAL	35.00			
							MINIMUM FEE	25.00			25.00

INSPECTION: Will be ready _____ or will call _____

CONTRACTORS NAME Portland Pump
ADDRESS P.O. Box 1180 Scarborough, ME
TELEPHONE 883-4317
MASTER LICENSE No. 16872
LIMITED LICENSE No. _____

SIGNATURE OF CONTRACTOR

ELECTRICAL INSTALLATIONS

Permit Number _____

Location _____

Owner _____

Date of Permit _____

Final Inspection 2/24/97

By Inspector [Signature]

INSPECTION: Service _____ by _____

Service called in _____

Closing-in _____ by _____

PROGRESS INSPECTIONS:

1/9/97 (CONDUITS)
1/15/97 Fuel pumps
1/24/97 SERVICE EQUIP
2/20/97 (PUMP)

DATE:	REMARKS:
2/20/97	Not ready (Panel) 11 eqpt wiring (some stacked down) (2 - 2 1/2" PVC conduits not fine stopped) Downward flow

1800
 100
 50.00
 4%
 300
 4.00
 3%

TOTAL AMOUNT TO
 PAYMENT FOR