

**City of Portland, Maine - Building or Use Permit Application**

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 05-0145	<b>PERMIT ISSUED</b>	EBL: 117 B005001
-----------------------	----------------------	---------------------

<b>Location of Construction:</b> 375 Riverside St	<b>Dwner Name:</b> Reynolds Marianne M	<b>Owner Address:</b> Po Box 99	<b>Phone:</b>
<b>Business Name:</b>	<b>Contractor Name:</b> Air Temp	<b>Contractor Address:</b> 11 Wallace Ave South Portland	<b>Phone:</b> 2077742800
<b>Lessee/Buyer's Name</b>	<b>Phone:</b>	<b>Permit Type:</b> HVAC	<b>Zone:</b> B4

<b>Past Use:</b> Commercial	<b>Proposed Use:</b> Commercial/ Install a Bryant Direct vent natural gas heater	<b>Permit Fee:</b> \$129.00	<b>Cost of Work:</b> \$12,000.00	<b>CEO District:</b> 5
<b>Proposed Project Description:</b> Install a Bryant Direct vent natural gas heater		<b>FIRE DEPT:</b> <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied	<b>INSPECTION:</b> Use Group <b>B</b> Type: <b>HVAC</b>	
		Signature: <i>[Signature]</i>	Signature: <i>[Signature]</i> 2/17/05	
Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied				
Signature: _____ Date: _____				

<b>Permit Taken By:</b> Idobson	<b>Date Applied For:</b> 02/08/2005	<b>Zoning Approval</b>		
------------------------------------	--	------------------------	--	--

<p><b>Special Zone or Reviews</b></p> <p><input type="checkbox"/> Shoreland</p> <p><input type="checkbox"/> Wetland</p> <p><input type="checkbox"/> Flood Zone</p> <p><input type="checkbox"/> Subdivision</p> <p><input type="checkbox"/> Site Plan <i>JK</i></p> <p>Maj <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/></p> <p>Date: <i>[Signature]</i> 2/16/05</p>	<p><b>Zoning Appeal</b></p> <p><input type="checkbox"/> Variance</p> <p><input type="checkbox"/> Miscellaneous</p> <p><input type="checkbox"/> Conditional Use</p> <p><input type="checkbox"/> Interpretation</p> <p><input type="checkbox"/> Approved</p> <p><input type="checkbox"/> Denied</p> <p>Date: _____</p>	<p><b>Historic Preservation</b></p> <p><input checked="" type="checkbox"/> Not in District or Landmark</p> <p><input type="checkbox"/> Does Not Require Review</p> <p><input type="checkbox"/> Requires Review</p> <p><input type="checkbox"/> Approved</p> <p><input type="checkbox"/> Approved w/Conditions</p> <p><input type="checkbox"/> Denied</p> <p>Date: <i>[Signature]</i></p>
---	--	--

**CERTIFICATION**

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT

ADDRESS

DATE

PHONE

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE

DATE

PHONE

**City of Portland, Maine - Building or Use Permit**

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

<b>Permit No:</b> 05-0145	<b>Date Applied For:</b> 0210812005	<b>CBL:</b> 317 B005001
------------------------------	--	----------------------------

<b>Location of Construction:</b> 375 Riverside St	<b>Owner Name:</b> Reynolds Marianne M	<b>Owner Address:</b> Po Box 99	<b>Phone:</b>
--	---	------------------------------------	---------------

<b>Business Name:</b>	<b>Contractor Name:</b> Air Temp	<b>Contractor Address:</b> 11 Wallace Ave South Portland	<b>Phone</b> (207) 774-2300
-----------------------	-------------------------------------	---	--------------------------------

<b>Lessee/Buyer's Name</b>	<b>Phone:</b>	<b>Permit Type:</b> HVAC
----------------------------	---------------	-----------------------------

<b>Proposed Use:</b> Commercial/ Install a Bryant Direct vent natural gas heater	<b>Proposed Project Description:</b> Install a Bryant Direct vent natural gas heater
---	---

**Dept:** Zoning      **Status:** Approved      **Reviewer:** Jeanine Bourke      **Approval Date:** 02/16/2005  
**Note:**      **Ok to Issue:**

**Dept:** Building      **Status:** Approved      **Reviewer:** Jeanine Bourke      **Approval Date:** 02/17/2005  
**Note:** 2/16/05 spoke w/Ron M. @ Patco for engineer statement for load on roof structurals. He will fax.      **Ok to Issue:**   
2/17 received fax, **ok** to issue


1) The installation must comply with the State of Maine Gas Regulations.

**Dept:** Fire      **Status:** Approved      **Reviewer:** Lt. MacDougal      **Approval Date:** 0211612005  
**Note:**      **Ok to Issue:**



FILL IN AND SIGN WITH INK

# APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT



317 B S

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL 375 Riverside Use of Building Retail Date 2/2/05  
 Name and address of owner of appliance Big Moose Heating 375 Riverside  
Portland, ME 04103  
 Installer's name and address AIRTEMP 11 Wallace Ave.  
S. Portland, ME 04106 Telephone 907-774-2300

### Location of appliance:

- Basement  Floor  
 Attic  Roof

### Type of Fuel:

- Gas  Oil  Solid

Appliance Name: Bryant

U.L. Approved  Yes  No

Will appliance be installed in accordance with the manufacture's installation instructions?  Yes  No

IF NO Explain: \_\_\_\_\_

### The Type of License of Installer:

- Master Plumber # \_\_\_\_\_  
 Solid Fuel # \_\_\_\_\_  
 Oil # \_\_\_\_\_  
 Gas # Pvt-1977  
 Other \_\_\_\_\_

### Type of Chimney:

- Masonry Lined  
 Factory built \_\_\_\_\_  
 Metal  
 Factory Built U.L. Listing # \_\_\_\_\_  
 Direct Vent  
 Type PVC UL# \_\_\_\_\_

### Type of Fuel Tank

- Oil NONE Natural Gas  
 Gas

Size of Tank N/A

Number of Tanks N/A

Distance from Tank to Center of Flame N/A feet.

Cost of Work: \$ 12,000

Permit Fee: \$ 200

### Approved

Fire: [Signature]

Ele.: \_\_\_\_\_


Bldg.: [Signature]

### Approved with Conditions

- See attached letter or requirement

Inspector's Signature \_\_\_\_\_

Date Approved \_\_\_\_\_



Signature of Installer [Signature]



*Fax Transmittal*


To: Portland Cole Restaurant Attn: Jeanie Bonke  
 Date: 2/17/05 Fax: 874-8716  
 From: Ron Marcini No. of pages: 2  
 (including cover sheet)

**Message:**

*Jeanie,*

*Here is doc. For Big Moose*

*Thanks  
Ron*



**Varco Pruden Buildings, Inc.**  
**WISCONSIN SERVICE CENTER**  
ENGINEERING GROUP

**Date: 02/16/2005**

**To: Jason Gartner w/ Patco Contracting**

**copy:**

**Fax:** number of pages 1

**Copy fax:**

**From: Carl W. Walker, PE**  
**WI Service Center**

**ph: 608-882-5001 ext. 415**

**fax: 608-882-2370**

**e-mail: cwalker@vp.com**

**SUBJECT: WI0401125**  
**Hanging unit heaters**

**Please be advised the hanging of unit heaters on the above subject job will not affect the structural integrity of the purlins if the heater is attached in a manner to meet VP detail EN1 OA1.**

**If you have any further questions, please let us know.**

