

PERMIT ISSUED

City of Portland, Maine - Building or Use Permit Application
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 04-1551 Issue Date: NOV 17 2004 CBL: 318 A007001

Location of Construction: 789 Warren Ave	Owner Name: House Warmers Coal Company	Owner Address: 7 Penwood Cir	City of Portland	Phone:
Business Name:	Contractor Name: Dead River Company	Contractor Address: PO Box 467 Scarborough		Phone: 2078839515
Lessee/Buyer's Name:	Phone:	Permit Type: HVAC		Zone: B-4

Past Use: Commercial	Proposed Use: commercial install 120 gal. above ground tank	Permit Fee: \$30.00	Cost of Work: \$300.00	CEO District: 5
Proposed Project Description: install a 120 gal. above ground tank		FIRE DEPT: <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied	INSPECTION: Use Group: <i>NA</i> Type: <i>410 APC</i>	

Signature: <i>[Signature]</i>	Signature: <i>[Signature]</i>
PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)	
Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied	Date: <i>[Date]</i>

Permit Taken By: dmartin	Date Applied For: 10/14/2004	Zoning Approval	
-----------------------------	---------------------------------	------------------------	--

- This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules.
- Building permits do not include plumbing, septic or electrical work.
- Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work.

Special Zone or Reviews	Zoning Appeal	Historic Preservation
<input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan <input type="checkbox"/> Major <input type="checkbox"/> Minor <input type="checkbox"/> MPA	<input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied	<input checked="" type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied
Date: <i>[Date]</i>	Date: <i>[Date]</i>	Date: <i>[Date]</i>

CERTIFICATION


I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE
RESPONSIBLE PERSON IN CHARGE OF WORK TITLE		DATE	PHONE



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT



To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL 318 - A - 007 . 001 SYSTEM Use of Building SHOP Date 10-13-04

Name and address of owner of appliance MR & MRS WARMERS COAL COMPANY
789 WARDEN AVE - PORTLAND

Installer's name and address DEAD RIVER COMPANY
78 ROSSWIT HILL RD SABBODUCK ME 04074 Telephone 883-9515

Location of appliance:

- Basement
- Floor
- Attic
- Roof

SUSPENDED VAN HEATER

Type of Fuel:

- Gas
- Oil
- Solid

Appliance Name: NODINE HEATER

U.L. Approved Yes No

Will appliance be installed in accordance with the manufacturer's installation instructions? Yes No

IF NO Explain: _____

The Type of License of Installer:

- Master Plumber # _____
- Solid Fuel # _____
- Oil # _____
- Gas # PWT 1449
- Other _____

Type of Chimney:

- Masonry Lined
- Factory built _____
- Metal
- Factory Built U.L. Listing # _____

Direct Vent
Type B-VENT UL# 441

Type of Fuel Tank

- Oil
- Gas

Size of Tank 120 GALLON ABOVE GROUND

Number of Tanks ONE

Distance from Tank to Center of Flame 100 feet

Cost of Work: \$ 300.00

Permit Fee: \$ 30.00

Approved

See attached letter or requirement

Approved with Conditions

Fire: _____
Ele.: _____
Bldg.: _____

Inspector's Signature

Date Approved

Signature of Installer DEAD RIVER COMPANY

White - Inspection

Yellow - File

Pink - Applicant's


Gold - Assessor's Copy

141



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT



To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL 318-A-CDD-001 34512 Use of Building SHOP Date 10-13-04

Name and address of owner of appliance HOUSE WARMERS COAL COMPANY
789 WARREN AVE - PORTLAND

Installer's name and address DEAD RIVER COMPANY
73 DEANS HILL ROAD SEABOARD, ME CDD7 Telephone 883-9515

Location of appliance:

- Basement
- Floor
- Attic
- Roof

Type of Fuel: SYNTHETIC GAS VENT HEATER

- Gas
- Oil
- Solid

Appliance Name: NOBIVE HEATER

U.L. Approved Yes No

Will appliance be installed in accordance with the manufacturer's installation instructions? Yes No

IF NO Explain: _____

The Type of License of Installer:

- Master Plumber # _____
- Solid Fuel # _____
- Oil # _____
- Gas # PNT 1449
- Other _____

Type of Chimney:

- Masonry Lined
- Factory built _____

Metal
Factory Built U.L. Listing # _____

Direct Vent
Type VENT U.L.# 441

Type of Fuel Tank

- Oil
- Gas

Size of Tank 120 GALLON ABOVEGROUND

Number of Tanks ONE

Distance from Tank to Center of Flame 420 feet

Cost of Work: \$ 300.00

Permit Fee: \$ 30.00

Approved  MAINE

See attached letter or requirement

Approved with Conditions

Fire: 4414
Ele.: 70731100
Bldg.: DMB

Inspector's Signature _____ Date Approved _____


Signature of Installer DEAD RIVER COMPANY by [Signature]

White - Inspection Yellow - File Pink - Applicant's Gold - Assessor's Copy

[Signature]

HOUSE WAREMERS COAL COMPANY
719 WARREN AVE
ROSELAND, NJ

NOT TO SCALE





allied engineering, inc.

Structural

Mechanical

Electrical

Technology

MEMO

PROJECT NUMBER:

Date: November 1, 2004

Project Name: Artour Care

To: Eric Hoyr

Company: Artour Care

From: William P. Faucher, P.E.

RE: Heater Support Load

Sent Via: Fax # - HARD COPY TO FOLLOW? Yes No

of Pages: 1

cc:

MARKING: NEW/VAL/IMP/ORD

COMMENTS:

We have been asked to review the installed addition roof framing for its capability of supporting a 770 space heater. The Heating unit can be supported by this roof framing without concern.

318 A 7

One Westbrook Common, Westbrook, ME 04092
207-854-8125 Voice 207-854-0603 Fax

Web: www.allied-eng.com
E-Mail: info@allied-eng.com

789 WHELEN AVE.

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No:	04-1551	Date Applied For:	10/14/2004	CBL:	318 A007001
------------	---------	-------------------	------------	------	-------------

Location of Construction: 789 Warren Ave	Owner Name: House Warmers Coal Company	Owner Address: 7 Penwood Cir	Phone:
Business Name:	Contractor Name: Dead River Company	Contractor Address: PO Box 467 Scarborough	Phone (207) 883-9515
Lessee/Buyer's Name	Phone:	Permit Type: HVAC	

Proposed Use: commercial install 120 gal. above ground gas tank and Suspended Heater	Proposed Project Description: install a 120 gal. above ground gas tank and heating unit
-----------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------

Dept: Zoning Note:	Status: Approved	Reviewer: Marge Schmeckal	Approval Date: 10/14/2004	Ok to Issue: <input checked="" type="checkbox"/>
Dept: Building Note:	Status: Approved with Conditions	Reviewer: Mike Nugent	Approval Date: 11/16/2004	Ok to Issue: <input checked="" type="checkbox"/>
Dept: Fire Note:	Status: Approved with Conditions	Reviewer: Lt. MacDougal	Approval Date: 10/19/2004	Ok to Issue: <input checked="" type="checkbox"/>
1) the propane tank shall be installed in accordance with NFPA 54 standards				

Comments:
10/21/2004-mjr: Need info regarding loading if suspended, called applicant