DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

ALEXANDER-RUSSELL COMPANY LLC

Located at

470 RIVERSIDE ST - UNIT #3

PERMIT ID: 2014-02166 ISS

ISSUE DATE: 10/22/2014

CBL: 321 A004003

has permission to

No Construction. Use will be office space, warehousing, and production of all natural bio-pesticide production in Unit #3.

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Laurie Leader

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

Building Inspections

Fire Department

manufacturing, offices and warehousing

Use Group: F-1/S-1/B Type: 3B

Factory (Moderate hazard) Non-toxic

pesticide

Storage (Moderate hazard)

Business - Offices

Building is sprinkled NFPA 13

ENTIRE

MUBEC/IBC 2009

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

REQUIRED INSPECTIONS:

Certificate of Occupancy/Final

Final - Electric

Fire - Change of Use Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 2014-02166

Date Applied For: 09/17/2014

CBL:

321 A004003

Proposed Use:

Office Space, Warehousing, Production - All natural bio-pesticide production.

Proposed Project Description:

No Construction. Use will be office space, warehousing, and production of all natural bio-pesticide production in Unit #3.

Dept: Zoning

Status: Approved w/Conditions

Reviewer: Marge Schmuckal

Approval Date:

09/19/2014

Ok to Issue:

Ok to Issue:

Note: Conditions:

1) Separate permits shall be required for any new signage.

Dept: Building

Status: Approved w/Conditions

Reviewer: Laurie Leader

Approval Date:

10/22/2014

Note:

Conditions:

- 1) This is a Change of Use ONLY permit. It does NOT authorize any construction activities.
- 2) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.
- 3) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.

Dept: Fire

Status: Approved w/Conditions

Reviewer: Craig Messinger

Approval Date:

10/09/2014

Note:

Ok to Issue:

Conditions:

- 1) The entire sprinkler system shall be maintained in accordance with NFPA 25, Standard for Inspection, Testing and Maintenance of Water-Based Fire Protection Systems, 2008 edition.
- 2) Emergency lights and exit signs are required. Emergency lights and exit signs are required to be labeled in relation to the panel and circuit and on the same circuit as the lighting for the area they serve.
- 3) Fire extinguishers are required per NFPA 1 Table 13.6.2.
- 4) Hazarous Materials must be stored in approved lockers.
- 5) Shall meet requirements of NFPA 101, Chapter 40, Industrial Occupancies
- 6) Shall meet the requirements of 2009 NFPA 1 Fire Code.