

Joe Falcone
Lic. #MS10016408
37 Daggett Street
Portland, ME 04103
207-318-5144

I have inspected the electrical service at 470
Riverside Street Unit 1B.


There is currently 800 amps located at this
building.

We will be using approx. 500 amps. We are
putting in a 600 amp service. This leaves 200
amps for Moonlight Productions.

This will be more than adequate for each tenant.

Any further questions, please call.

Thank you.


7/18/14