Location of Construction:	Owner: A Robert Young	Phone:		Per 9 6:1158
Owner Address:	Leasee/Buyer's Name:	Phone: Busines	ssName:	PERMIT ISSUED
Contractor Name: 04103	Address:	Phone:		Permit Issued:
Past Use:	Proposed Use:	COST OF WORK:	PERMIT FEE:	NOV 2 1 1996
warehouse \$444%	wholesale trailers. ONLY	FIRE DEPT. ☐ Approved ☐ Denied Signature:	INSPECTION: Use Group: Type: BOCSHAFILE Signature: Holds	Zone: CBL: 321-B-9
Proposed Project Description:		PEDESTRIAN ACTIVITI	ES DISTRICT (PAUL).)	Zoning Approval: 19/Nov/
(for legal current use) change of use - fro wholese	m warehouse to ile trailers, only	Action: Approved Approved Denied Signature:	with Conditions:	Special Zone or Reviews Shoreland Condition Wetland Whole Sa Flood Zone On Ly Subdivision No retain
Permit Taken By:	Date Applied For:	15/95		☐ Site Plan maj ☐ minor ☐ mn
 Building permits do not include plumbing Building permits are void if work is not station may invalidate a building permit and 	arted within six (6) months of the date of issu	ance. False informa-	PERMIT SE	☐ Conditional Use ☐ Interpretation ☐ Approved ☐ Denied Historic Preservation ☐ Not in District or Landma ☐ Does Not Require Review ☐ Requires Review
				Action:
I hereby certify that I am the owner of record of authorized by the owner to make this application if a permit for work described in the application areas covered by such permit at any reasonable	on as his authorized agent and I agree to cor on issued, I certify that the code official's au	nform to all applicable laws of to athorized representative shall hat (s) applicable to such permit	his jurisdiction. In addition,	☐ Denied
SIGNATURE OF APPLICANT	ADDRESS:	DATE:	PHONE:	- 11.7
RESPONSIBLE PERSON IN CHARGE OF W			PHONE:	_

The physical Changes co	MMENTS/ Charle of ase to	- Confron
to a chief use -		
	Inspection Record	
	Type	Date
	Foundation:	
	Framing:	
	Plumbing:	
	Final:Other:	

BUILDING PERMIT REPORT

REASON FOR PERMIT: Change of USP - to Whole sale Trailers (only) BUILDING OWNER: Robert Young CONTRACTOR: 11 PERMIT APPLICANT: APPROVAL: */[*/[*/]] *22 DENIED:	DATE: 19 NOV 96 ADDRESS: U	l'Evergreen DR:
BUILDING OWNER: Robert Young CONTRACTOR: 11	REASON FOR PERMIT: Change of USP -	To whole sale Trailers (only)
	BUILDING OWNER: Robert Young	
PERMIT APPLICANT: APPROVAL: */5*/5*/7*/2 ** 22	CONTRACTOR: '1 1 (
	PERMIT APPLICANT:	APPROVAL: */5*/5/17 *22

CONDITION OF APPROVAL OR DENIAL

Before concrete for foundation is placed, approvals from the Development Review coordinator and Inspection Services must 1. be obtained. (A 24 hour notice is required prior to inspection)

Precaution must be taken to protect concrete from freezing. 2,

It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. This is 3.

done to verify that the proper setbacks are maintained.

- Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from 4. adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting rating. Private garages attached sis-by-side to rooms in the above occupancies shall be completely separated from the interior spaces and the attic area by means of 1/2 inch gypsum board or the equivalent applied to the garage means of 1/2 inch gypsum board or the equivalent applied to the garage side. (Chapter 4 Section 407.0 of the BOCA/1996)
- Guardrail & Handrails A guardrail system is a system of building components located near the open sides of elevated 5. walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level. Minimum height all Use Groups 42", except Use Group R which is 36". In occupancies in Use Group A, B, H-4, I-1, I-2 M and R and public garages and open parking structures, open guards shall have balusters or be of solid material such that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that would provide a ladder effect.

Headroom in habitable space is a minimum of 7'6". 6.

Stair construction in Use Group R-3 & r-4 is a minimum of 10" tread and 7 3/4" maximum rise. All other Use group 7. minimum 11" tread. 7" maximum rise. 8.

The minimum headroom in all parts of a stairway shall not be less than 80 inches.

Every sleeping room below the fourth story in buildings of use Groups \$ and I-1 shall have at least one operable window or 9. exterior door approved for emergency egress or rescue. The units must be operable from the inside without the use of special knowledge or separate tools. Where windows are provided as means of egress or rescue they shall have a sill height not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm), and a minimum net clear opening of 5.7 sq. ft.

10. Each apartment shall have access to two (20 separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units.

All vertical openings shall be enclosed with construction having a fire rating of at lest one (1)hour, including fire doors with 11. self closer's.

The boiler shall be protected by enclosing with (1) hour fire-rated construction including fire doors and ceiling, or by 12, providing automatic extinguishment.

- All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the 13. provisions of the City's building code Chapter 9, Section 19, 919.3.2 (BOCA National Building Code/1996), and NFPA 101 Chapter 18 & 19. (Smoke detectors shall be installed and maintained at the following locations):
 - In the immediate vicinity of bedrooms
 - In all bedrooms

In each story within a dwelling unit, including basements

In addition to the required AC primary power source, required smoke detectors in occupancies in Use Groups R-2, R-3 and I-1 shall receive power from a battery when the AC primary power source is interrupted. (Interconnection is required)

A portable fire extinguisher shall be located as per NFPA #10. They shall bear the label of an approved agency and be of an 14. approved type.

₹15.	The Fire Alarm System shall be maintained to NFPA #72 Standard.
<u> </u>	The Sprinkler System shall maintained to NFPA #13 Standard.
X17 .	All exit signs, lights, and means of egress lighting shall be done in accordance with Chapter 10 Section & Subsections 1023. & 1024. Of the City's building code. (The BOCA National Building Code/1996)
18.	All construction and demolition debris must be disposed at the City's authorized reclamation site. The fee rate is attached. Proof of such disposal must be furnished to the office of Inspection Services before final Certificate of Occupancy is issued
19.	or demolition permit is granted. Section 25-135 of the Municipal Code for the City of Portland states, "No person or utility shall be granted a permit to excavate or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year".
20.	The builder of a facility to which Section 4594-C of the Maine State Human Rights Act Title 5 MRSA refers, shall obtain a certification from a design professional that the plans commencing construction of the facility, the builder shall submit the certification to the Division of Inspection Services.
21.	This permit does not excuse the applicant from obtaining any license which may be needed from the City Clerk's office.
22,	This permit is for whole sale Trailers Only,
23.	
24,	
25.	
10	Latter .
P. San	nuel Holfses, Chief of Code Enforcement
10.51	
cc: Lt.	McDougall, PFD

41 Evergicen Drive - 97' Schens ive ONLY ENERGINEN WHSE / SHOP ARCH Wholesale Distribution Change or Use OFFICE AMA 1201 41 EULRSTEIN DR