



	ALARM BLOCK #1	ALARM BLOCK #2
INTRUSION DOOR ALARM	1	1
	2	2
COMMERCIAL POWER FAIL	3	3
	4	4
SURGE ARRESTOR ALARM	5	5
	6	6
EQUIP. ROOM SMOKE ALARM	7	7
	8	8
HYDROGEN GAS ALARM	9	9
	10	10
HIGH HUMIDITY ALARM	11	11
	12	12
HIGH TEMPERATURE ALARM	13	13
	14	14
LOW TEMPERATURE ALARM	15	15
	16	16
HVAC FAIL #1 ALARM	17	17
	18	18
HVAC FAIL #2 ALARM	19	19
	20	20
GEN. RUN ALARM	21	21
	22	22
GEN. LOW FUEL ALARM	23	23
	24	24
GEN. SHUTDOWN ALARM	25	25
	26	26
GEN. MAJOR ALARM	27	27
	28	28
	29	29
	30	30
	31	31
	32	32
GEN. FAIL ALARM	33	33
	34	34
FUEL BASIN RUPTURE ALARM	35	35
	36	36
TRANSFER SWITCH FAIL	37	37
	38	38
PORTABLE GEN. FAIL ALARM	39	39
	40	40
PORTABLE GEN. LOW FUEL	41	41
	42	42
PORTABLE GEN. MAJOR	43	43
	44	44
PORTABLE GEN. RUNNING	45	45
	46	46
PORTABLE GEN. THEFT ALARM	47	47
	48	48
	49	49
	50	50

NOTES:
1. SEE ALARM WIRING SHEET #1 FOR NOTES

						THESE PLANS ARE THE CONFIDENTIAL PROPERTY AND TRADE SECRETS OF FIBREBOND CORPORATION. ANY USE OF THESE DRAWINGS OR THE INFORMATION CONTAINED HEREIN FOR ANY REASON OTHER THAN AS EXPRESSLY AUTHORIZED BY FIBREBOND CORPORATION IS STRICTLY PROHIBITED. THESE DRAWINGS HAVE BEEN DISTRIBUTED WITH THE UNDERSTANDING THAT ANYONE RECEIVING OR OTHERWISE OBTAINING POSSESSION OF THEM WILL BE EXPRESSLY NOTIFIED OF THEIR CONFIDENTIAL NATURE.				1300 DAVENPORT DRIVE MINDEN, LA. 71055 ph. (800) 824-2614 www.fibrebond.com					
						AT&T MOBILITY 11'-5" X 24'-0" PATIO SHELTER ALARM WIRING SHEET #2				SCALE: NONE SHEET NO.: 4-2					
REV.	BY	DATE	REVISION	APP.	DATE	BOM	DATE	DRN. BY: CSP	DATE: 6/5/13	APP. BY: CSP	DATE: -	B DWG NO.: D-9312			
								CHK. BY:	DATE:	APP. BY: MG	DATE: -				