<u>ITEM LIST</u>

ITEM NO.	FIBREBOND PART NO.	MANUFACTURER PART NO.	MANUFACTURER	DESCRIPTION
1	823-00023	AA1220061-3S	INTERSECT	PANEL, ASCO ILC. SERIES, AA1220061-3S
	833-00026	MC4000	BARD	LEAD/LAG THERMOSTAT
-=	837-00151	W48A1-A05EPXXXJ	BARD	HVAC, 4TON, 5KW, 1 PH WITH ECONOMIZER R410A UNIT
<u>- 4</u>	837-00151	W48A1-A05EPXXXJ	BARD	HVAC, 4TON, 5KW, 1 PH WITH ECONOMIZER R410A UNIT
	833-10877	1UHH2	DAYTON	HIGH TEMP ALARM
- = -			BATTON	1101 12.01 70.01.01
- -	831-00072	20784	TCP	FIXTURE, TCP_LED_EXIT/FLOOD_COMBO
8.	822-21981/822-13401			GENERATOR CONTROL BOX, 4" W.P.J.B. W/ 3/4" PLG W/ COVER
9.	831-00094/831-00093	207 A 232	TEXAS FLOURESCENTS	FIXTURE, INTERIOR LIGHT, 32W, W/A 2 BULB T8 4' WITH LENS
10.	827-00086	CSB120I	HUBBELL	SWITCH 20AMP 120V SINGLE POLE AC TOGGLE
11.	827-00071/822-10583/822	-10150	COOPER	20AMP DUPLEX RECEPTACLE / 4" x 4" J.B.
12.				
13.	848-00027/822-10150	OSD223-48	CPS	SMOKE DETECTOR, -48VDC WITH ALARM W/ 4X4 JB
14.				
15.	818-00032		HARGER	WAVEGUIDE, 4" 24 PORT WITH PVC CAPS
16.	822-10150	4SDEK	APPLETON	4" x 4" J.B. (1/2" & 3/4" KNOCKOUT)
17.				
18.				DOOR, 3070 18 GA. GALVANIZED, WITH 161 PREP POLYSTYRENE INSULATION, 1.5 HOUR FIRE RATED FL3078.3
19.	847-10789	83T7K-STK-626	BEST	DEADBOLT
20.	847-11053	1130	SARGENT	DOOR CLOSURE
21.	847-11073	TA2314NRP26D	McKINNEY	DOOR HINGES
22.	847-12450	16AD-42	NATIONAL GUARD	DRIP STRIP, 42"
23.	847-12569	198NA-36	NATIONAL GUARD	DOOR SWEEP, 36"
24.	192797			COVER PLATE, 25 1/2" X 25 1/2" PAINTED MESA TAN FOR 818-00033 WG
25.	847-12634	B-1	AUSTIN HARDWARE	DOOR STOP (BLACK RUBBER)
26.	847-00053	345D-US32D	HAGER	LOCK GUARD, 1 5/8" X 10", STAINLESS STEEL
27.	847-12348	_	HAGER	THRESHOLD, 36" ALUMINUM
28.	847-22371	_	_	HOLDER, 304Ss, MODEL 5601
29.	196474	FB#196474	FIBREBOND	1/4" X 6" X 30" CELL GROUND BAR COPPER
30.	194343	FB#194343	FIBREBOND	1/4" X 4" X 10" GROUND BAR
31.	848-11351	7939-2GY	ADEMCO	MAGNETIC DOOR ALARM
32 33	835-11317	S66B450MH49	SEIMONS	ALARM BLOCK
33.	841-13867	63202	DEFLECTO	LETTER TRAY
34.	839-10767	4" PVC	_	4" SCHEDULE 40 PVC
35	827-00071/822-10583/822	-10150	COOPER	20AMP DUPLEX RECEPTACLE / 4" x 4" J.B.
36.	813-00067/814-00024			BOARD, TELCO 3/4" X 48" X 96" NUPOLY MDF W/CAP TRIM
36. 37.	822-10268	ASE6X6X4NK	HOFFMAN	6" x 6" x 4" J.B.
38.	831-00094/831-00093	207 A 232	TEXAS FLOURESCENTS	FIXTURE, INTERIOR LIGHT, 32W, W/A 2 BULB T8 4' WITH LENS
39.	831-23605/822-10887	2LBN5	LUMAPRO	FIXTURE, 150W EXTERIOR W/MOTION DETECTOR, BOX, 4" ROUND W/P SURFACE
40.	827-00071/822-10583/822	-10150	COOPER	20AMP DUPLEX RECEPTACLE / 4" x 4" J.B.
41.	827-00085/822-13765/822		HUBBELL	RECEPTACLE, 20AMP GFCI/RECEPTACLE, COVER/2" x 4" W.P.J.B.
42.	839-10782	1/2" PVC	BARTEET	1/2" SCHEDULE 40 PVC CAST @ 45"
43				
44.				
45	831-40076/831-00082	-		FIXTURE, 4" PORCELAIN W/CHAIN; BULB, 50W, 48V DC LIGHT
46.	827-00188/822-10159/822	-00102		SWITCH 10AMP DC TOGGLE W/ SINGLE SWITCH COVER IN 2X4 JUNCTION BOX
47.	197340			BAR TINNED COPPER, 1/4"X4"X24", STAMPED STOLEN DO NOT RECYCLE
48.	827-23676	5000GP-C	ALERT	REEL, HARDWIRED 10A 16/3 30'-0"
49.	827-00086/822-10580/822	-10150	HUBBELL	SWITCH 20AMP 120V TOGGLE W/ 2 SWITCH COVER IN 4X4 JUNCTION BOX
50.				

<u>ITEM LIST</u>

ITEM NO.	FIBREBOND PART NO.	MANUFACTURER PART NO.	MANUFACTURER	DESCRIPTION
51.	833-11718/822-10159	-		HUMIDISTAT 20-80 RH W/ 2x4 JUNCTION BOX
52.	822-12610	 E989R	CARLON	ENCLOSURE, 12"x12"x6" PVC
<u>52.</u> 53.	846-11206			CANOPY, DOOR - 30" X 56"
54.	847-12747		BEST	DOOR PEEP 210 DEGREE
55.				
56. 57.				
57.	822-12740	MALB-6	KILLARK	2" LB, NEC, MOGUL W/ COVER
58.				HIDDEN 16 1/2" X 16 1/2" BLOCKOUT FOR OPTIONAL 24VDC EXHAUST FAN
<u>58.</u> 59.	822-10150			4" X 4" J.B., 20A DUPLEX RECEPT. — INSTALL RECEPT. ONLY UNDER INSTALLED WAVEGUIDE
60.	821-10527			WIREWAY, 4" X 4"
61.	824-22196	D224NRB	SQUARE D	DISCONNECT, FUSIBLE - 200 AMP w/200 AMP FUSES W.P./ HEAVY DUTY
62.				
63.	833-10877	1UHH2	DAYTON	LOW TEMP ALARM
64.				
65.	827-00224/827-11704/822	2–10268		HVAC SHUTDOWN RELAY 48V DC 11 BLADE MOUNTED IN 6x6x4 J.B.
66.				
67.				
68.				
69.				
70.				
71.				
72. 73.				
73.	848-00034/822-23634	099141	ARRGH MANUFACTURING	DETECTOR, HYDROGEN 12-48VDC/BOX, 2 GANG SWITCH - 1" 5/8" D
74.	841-23025			DESK, WALLMOUNT FOLD-UP
75. 76.				
_76	822-21981/822-13401/820	0-11838		BOX, 4" W.P.J.B. W/ 3/4" PLG W/ 3/4" X 1/2" REDUCING BUSHINGS W/ COVER
77. 78. 79.	822-21981/822-13401			BOX, 4" W.P.J.B. W/ 3/4" PLG W/ COVER
<u> 78. </u>	826-00003	MTC6001EC-2-1	MICRIN	GENERATOR INTERFACE PANEL, 200 AMP 120/240 CAM LOC Ø1
_79 <u>.</u>	836-00044	MC2082	MICRIN/COMMTECH	CABLE 40' GENERATOR INTERFACE PANEL MONITOR
80.				
81.	-			CUSTOMER SUPPLIED GENERATOR
82.	848-24655	CI-355	WATT_STOPPER/LEGRAND	SENSOR, PASSIVE INFRARED LINE VOLTAGE CEILING
83.				
_84				
85.				
86.				
87.				
_88.				
89.				
90.				
91.				
92.				
93.				
94. 95.				
96.				
_ <u>96.</u> _97.				
- <u>97.</u> 98.				
99.				
100.				
100.				

	PACKING LIST							
ITEM NO.	QTY.	FIBREBOND PART NO.	MFG'S. PART NO.	MANUFACTURER	DESCRIPTION			
-		841-50030	474	-	BRUSH, 1" PAINT			
-	.25 gal	851-00263	_	-	PAINT, THOROLASTIC FINE MESA TAN (USA - 100%)			
-	*	850-00003	K-73650P-4.0	SILAPRENE	CAULK, TAN			
-	8	197788	FB#197786	FIBREBOND	PLATE, TIEDOWN - 3/8" X 9" X 12"			
-	16	854-00008	20655	_	ANCHOR, SLEEVE - 3/4" X 2 1/2"			
	4	196286	FB#196286	FIBREBOND	PLATE, TIEDOWN - 1/2" X 10" X 16"			
		853-11490	_	_	BOLT, 5/8" X 2" GRADE 8			
		855-11510	-	-	LOCKWASHER, 5/8" PLATED			
	8	855-15863	-	-	WASHER, 5/8" SAE PLATED			

^{*}VARIES WITH SIZE OF BLDG., SEE SEQUENCE 120

								THESE PLANS ARE THE CONFIDENTIAL PROPERTY AND TRADE SECRETS OF FIBREBOND	
								CORPORATION. ANY USE OF THESE DRAWINGS OR THE INFORMATION CONTAINED HEREIN FOR ANY REASON OTHER THAN	AT&T MODILIT
								AS EXPRESSLY AUTHORIZED BY FIBREBOND CORPORATION IS STRICTLY PROHIBITED. THESE	11'-5" X 24'-0" PATIO SHELTER FIBREBOND
								DRAWINGS HAVE BEEN DISTRIBUTED WITH THE UNDERSTANDING THAT ANYONE RECEIVING OR OTHERWISE	SCALE: SHEET NO.:
								OBTAINING POSSESSION OF THEM	BY: CSP DATE: 6/3/13 BY: CSP DATE: -
REV.	BY	DATE	REVISION	APP.	DATE	ВОМ	DATE	WILL BE EXPRESSLY NOTIFIED OF THEIR CONFIDENTIAL NATURE.	CHK. DATE: APP. MG DATE: — B DWG NO.: D-9312

NOTE:

1. ITEMS ARE SUBJECT TO CHANGE DUE TO AVAILABILITY AND EQUAL SUBSTITUTES WILL BE USED. ELECTRICAL OR MECHANICAL REQUIREMENTS MAY CHANGE DUE TO MANUFACTURES SPECIFICATIONS.