<u>ITEM LIST</u>

TEM NO.	FIBREBOND PART NO.	MANUFACTURER PART NO.	MANUFACTURER	DESCRIPTION
1.	823-00226	AA1240061-3S	INTERSECT	400A AUTOMATIC TRANSFER SWITCH W/ DISTRIBUTION & SURGE PROTECTION/QOB BOLT-ON BREAKERS
2.	833-00026	MC4000	BARD	LEAD/LAG THERMOSTAT
3.	837-00151	W48A1-A05EPXXXJ	BARD	HVAC, 4TON, 5KW, 1 PH WITH ECONOMIZER R410A UNIT
4.	837-00151	W48A1-A05EPXXXJ	BARD	HVAC, 4TON, 5KW, 1 PH WITH ECONOMIZER R410A UNIT
5.	833-10877	1UHH2	DAYTON	HIGH TEMP ALARM
6.				
7.	831-00072	20784	TCP	FIXTURE, TCP LED EXIT/FLOOD COMBO
8.	822-21981/822-13401			GENERATOR CONTROL BOX, 4" W.P.J.B. W/ 3/4" PLG W/ COVER
9.	831-00094/831-00093	207 A 232	TEXAS FLOURESCENTS	FIXTURE, INTERIOR LIGHT, 32W, W/A 2 BULB T8 4' WITH LENS
10.	827-00086	CSB120I	HUBBELL	SWITCH 20AMP 120V SINGLE POLE AC TOGGLE
11.	827-00071/822-10583/822	_10150	COOPER	20AMP DUPLEX RECEPTACLE / 4" x 4" J.B.
12.				
13.	848-00027/822-10150	OSD223-48	CPS	SMOKE DETECTOR, -48VDC WITH ALARM W/ 4X4 JB
14.				
15.	818-00032	_	HARGER	WAVEGUIDE, 4" 24 PORT WITH PVC CAPS
16.	822-10150	4SDEK	APPLETON	4" x 4" J.B. (1/2" & 3/4" KNOCKOUT)
17.				
18.	_	_	_	DOOR, 3070 18 GA. GALVANIZED, WITH 161 PREP POLYSTYRENE INSULATION, 1.5 HOUR FIRE RATED FL3078
19.	847-10789	83T7K-STK-626	BEST	DEADBOLT
20.	847-11053	1130	SARGENT	DOOR CLOSURE
21.	847-11073	TA2314NRP26D	McKINNEY	DOOR HINGES
22.	847-12450	16AD-42	NATIONAL GUARD	DRIP STRIP, 42"
23.	847-12569	198NA-36	NATIONAL GUARD	DOOR SWEEP, 36"
24.	192797			COVER PLATE, 25 1/2" X 25 1/2" PAINTED MESA TAN FOR 818-00033 WG
25.	847-12634	B-1	AUSTIN HARDWARE	DOOR STOP (BLACK RUBBER)
26.	847-00053	345D-US32D	HAGER	LOCK GUARD, 1 5/8" X 10", STAINLESS STEEL
27.	847-12348	_	HAGER	THRESHOLD, 36" ALUMINUM
28.	847-22371			HOLDER, 304Ss, MODEL 5601
29.	196474	FB#196474	FIBREBOND	1/4" X 6" X 30" CELL GROUND BAR COPPER
30.	194343	FB#194343	FIBREBOND	1/4" X 4" X 10" GROUND BAR
31.	848-11351	7939-2GY	ADEMCO	MAGNETIC DOOR ALARM
32 33	835-11317	S66B450MH49	SEIMONS	ALARM BLOCK
33.	841-13867	63202	DEFLECTO	LETTER TRAY
34.	839-10767	4" PVC		4" SCHEDULE 40 PVC
35.	827-00071/822-10583/822	-10150	COOPER	20AMP DUPLEX RECEPTACLE / 4" x 4" J.B.
36 37	813-00067/814-00024	_	_	BOARD, TELCO 3/4" X 48" X 96" NUPOLY MDF W/CAP TRIM
37.	822-10268	ASE6X6X4NK	HOFFMAN	6" x 6" x 4" J.B.
38.	831-00094/831-00093	207 A 232	TEXAS FLOURESCENTS	FIXTURE, INTERIOR LIGHT, 32W, W/A 2 BULB T8 4' WITH LENS
39	831-23605/822-10887	2LBN5	LUMAPRO	FIXTURE, 150W EXTERIOR W/MOTION DETECTOR, BOX, 4" ROUND W/P SURFACE
40.	827-00071/822-10583/822	_10150	COOPER	20AMP DUPLEX RECEPTACLE / 4" x 4" J.B.
41.	827-00085/822-13765/822	-10365	HUBBELL	RECEPTACLE, 20AMP GFCI/RECEPTACLE, COVER/2" x 4" W.P.J.B.
42.	839-10782	1/2" PVC	BARTEET	1/2" SCHEDULE 40 PVC CAST @ 45'
43.				
44.				
45.	831-40076/831-00082			FIXTURE, 4" PORCELAIN W/CHAIN; BULB, 50W, 48V DC LIGHT
46.	827-00188/822-10159/822			SWITCH 10AMP DC TOGGLE W/ SINGLE SWITCH COVER IN 2X4 JUNCTION BOX
47.	197340	_		BAR TINNED COPPER, 1/4"X4"X24", STAMPED STOLEN DO NOT RECYCLE
48.	827-23676	5000GP-C	ALERT	REEL, HARDWIRED 10A 16/3 30'-0"
49.	827-00086/822-10580/822		HUBBELL	SWITCH 20AMP 120V TOGGLE W/ 2 SWITCH COVER IN 4X4 JUNCTION BOX
50.				

<u>ITEM LIST</u>

ITEM NO.	FIBREBOND PART NO.	MANUFACTURER PART NO.	MANUFACTURER	DESCRIPTION			
51.	833-11718/822-10159	=		HUMIDISTAT 20-80 RH W/ 2x4 JUNCTION BOX			
52.	822-12610 846-11206	E989R	CARLON	ENCLOSURE, 12"x12"x6" PVC			
53.	846-11206			CANOPY, DOOR - 30" X 56"			
54.	847-12747		BEST	DOOR PEEP 210 DEGREE			
55.							
56.							
57.	822-00175	BLB400-A	APPLETON	CONDULET LB 4" NEC 6X HIDDEN 16 1/2" X 16 1/2" BLOCKOUT FOR OPTIONAL 24VDC EXHAUST FAN			
<u>58.</u> 59.				HIDDEN 16 1/2 X 16 1/2 BLOCKOUT FOR OPTIONAL 24VDC EXHAUST FAN			
_59	822-10150			4" X 4" J.B., 20A DUPLEX RECEPT INSTALL RECEPT. ONLY UNDER INSTALLED WAVEGUIDE WIREWAY, 4" X 4"			
60. 61.	821-10527 824-21742		SQUARE D	DISCONNECT, SQ. D 400A 600V FUS			
-61.	024-21/42	-	U	DISCONNECT, SQ. D 400A 600V FOS			
62. 63.	833-10877	1UHH2	DAYTON	LOW TEMP ALARM			
64				COTT ICMI ALAKM			
<u>64.</u> 65.	827-00224/827-11704/822			HVAC SHUTDOWN RELAY 48V DC 11 BLADE MOUNTED IN 6x6x4 J.B.			
66.							
66. 67.							
68.							
69.							
70.							
_71 <u>.</u>							
72. 73.							
_ <u>73.</u>	848-00034/822-23634	099141	ARRGH MANUFACTURING	DETECTOR, HYDROGEN 12-48VDC/BOX, 2 GANG SWITCH - 1" 5/8" D			
74.	841-23025			DESK, WALLMOUNT FOLD-UP			
75. 76.	822-21981/822-13401/820			BOX, 4" W.P.J.B. W/ 3/4" PLG W/ 3/4" X 1/2" REDUCING BUSHINGS W/ COVER			
_ <u>/6.</u> _77.	622-21961/622-13401/620 822-21981/822-13401	-11030		BOX, 4 W.P.J.B. W/ 3/4 PLG W/ 3/4 X 1/2 REDUCING BUSHINGS W/ COVER			
- <u>//.</u> _78.	826-00021	MTC6001ESH	MICRIN/COMMTECH	BOX, 4" W.P.J.B. W/ 3/4" PLG W/ COVER CENERATOR INTERFACE PANEL 400 AMP			
_ <u>70.</u> _79.	836-00044	MC2082	MICRIN/COMMTECH	CABLE 40' GENERATOR INTERFACE PANEL MONITOR			
80.				OUDER TO GENERATOR INTERNATION MICHAEL MICHIGAN			
81.				CUSTOMER SUPPLIED GENERATOR			
81. 82.	848-24655	CI-355	WATT STOPPER/LEGRAND	SENSOR, PASSIVE INFRARED LINE VOLTAGE CEILING			
83.							
84.							
85.							
86.							
87.							
88.							
<u>89.</u> 90.							
91 <u>.</u> 92.							
93.							
94.							
95.							
96.							
97.							
98.							
99.							
100.							

TEM NO.	QTY.	FIBREBOND PART NO.	MFG'S. PART NO.	MANUFACTURER	DESCRIPTION
-	1	841-50030	474	-	BRUSH, 1" PAINT
-	.25 gal	851-00263	-	-	PAINT, THOROLASTIC FINE MESA TAN (USA - 100%)
-	*	850-00003	K-73650P-4.0	SILAPRENE	CAULK, TAN
-	8	197788	FB#197786	FIBREBOND	PLATE, TIEDOWN - 3/8" X 9" X 12"
-	16	854-00008	20655	_	ANCHOR, SLEEVE - 3/4" X 2 1/2"
	4	196286	FB#196286	FIBREBOND	PLATE, TIEDOWN - 1/2" X 10" X 16"
	8	853-11490	_	_	BOLT, 5/8" X 2" GRADE 8
	8	855-11510	_	_	LOCKWASHER, 5/8" PLATED
	8	855-15863	_	_	WASHER, 5/8" SAE PLATED

^{*}VARIES WITH SIZE OF BLDG., SEE SEQUENCE 120

								THESE PLANS ARE THE CONFIDENTIAL PROPERTY AND TRADE SECRETS OF FIBREBOND	ph (800) 824 2614, wasay fibrohond com
								CORPORATION. ANY USE OF THESE DRAWINGS OR THE INFORMATION CONTAINED HEREIN	ATAT MODILITY
								FOR ANY REASON OTHER THAN AS EXPRESSLY AUTHORIZED BY FIBREBOND CORPORATION IS	
								STRICTLY PROHIBITED. THESE DRAWINGS HAVE BEEN DISTRIBUTED WITH THE UNDERSTANDING THAT	SCALE: SHEET NO.:
								ANYONE RECEIVING OR OTHERWISE OBTAINING POSSESSION OF THEM WILL BE EXPRESSLY NOTIFIED OF	BY: CSP DAIE: 6/5/13 BY: CSP DAIE: -
REV	. BY	DATE	REVISION	APP.	DATE	ВОМ	DATE	WILL BE EXPRESSLY NOTIFIED OF THEIR CONFIDENTIAL NATURE.	CHK. DATE: APP. MG DATE: — B DWG D—9312

NOTE:

1. ITEMS ARE SUBJECT TO CHANGE DUE TO AVAILABILITY AND EQUAL SUBSTITUTES WILL BE USED. ELECTRICAL OR MECHANICAL REQUIREMENTS MAY CHANGE DUE TO MANUFACTURES SPECIFICATIONS.