



TOP OF ROOF 120'-0"

T/LOW ROOF ELEV.=114'-6"

TOP OF ROOF FRAMING ELEV.=114'-0"

T/SLAB ELEV.=100'-0"

TOP OF ROOF

120'-0"

T/LOW ROOF ELEV.=114'-6"

TOP OF ROOF FRAMING ELEV.=114'-0"

T/SLAB ELEV.=100'-0"

PITCH 6" OVERALL TO DRAIN

SIMPSON H2.5A HURRICANE CLIPS AT

(2)2x6 @ 24"O.C. EXTERIOR

W/STUDS (TYP).—

27'-0"

BEARING WALL ALIGN TRUSSES

-5" REINF. CONCRETE SLAB

PITCH 6" OVERALL TO DRAIN

SIMPSON H2.5A HURRICANE CLIPS AT

(2)2x6 @ 24"O.C. EXTERIOR

W/STUDS (TYP).—

27'-0"

BEARING WALL ALIGN TRUSSES

BOTH ENDS OF ALL ROOF TRUSSES (TYP)

√5" REINF. CONCRETE SLAB

BOTH ENDS OF ALL ROOF TRUSSES (TYP)

PSTEEL ELEV.=112-4"

1/STEEL ELEV.=112-4"

(2)2x10 CONT. PLATE

W/1/2" Ø THRU BOLTS @

3'-0"O.C. AT 5½" BEAM

GA. IN %6"Ø HOLES (TYP)—

W24x76 STEEL BEAM

-EDPM ROOFING BY OTHERS

 $-\frac{1}{2}$ " RELEASE BOARD BY OTHERS

4" RIGID INSULATION BY OTHERS

EDGES AND INTERMEDIATE (TYP.)

CHORD OPEN WEB TRUSSES

-20" DEEP PARALLEL

@ 24"O.C. (TYP)

←6x8 P.T. SILL

2x6 @ 24"O.C. EXTERIOR BEARING WALL UPPER LEVEL

2x6 @ 12"O.C. EXTERIOR

BEARING WALL AT LOWER

LEVEL ALIGN W/TRUSSES,

FLOOR JOISTS W/STUDS (TYP).

1/2" THICK APA RATED EXTERIOR WALL SHEATHING. FASTEN W/8d

NAILS @ 4" O.C. AT PANEL EDGES

AND 6" O.C. INTERMEDIATE. (TYP.)-

SIMPSON H2.5A HURRICANE CLIPS AT BOTH ENDS OF ALL ROOF TRUSSES (TYP)-

EDPM ROOFING BY OTHERS -

2x6 @ 12"O.C. EXTERIOR

BEARING WALL AT LOWER

JOISTS W/STUDS (TYP). —

LEVEL ALIGN W/ROOF FLOOR

½" THICK APA RATED EXTERIOR WALL SHEATHING. FASTEN W/8d

NAILS @ 4" O.C. AT PANEL EDGES

AND 6" O.C. INTERMEDIATE. (TYP.)

 $1\!\!\!/2$ " RELEASE BOARD BY OTHERS -

%" THICK APA RATED ROOF SHEATHING.

EDGES AND INTERMEDIATE (TYP.) -

FASTEN W/10d NAILS @ 6" O.C. AT PANEL

ALIGN TRUSSES W/STUDS (TYP). —

2x6 CONT. PLATE (TYP)-

3/4" APA RATED SHEATHING.

ADHESIVE AND 10D RING SHANK

EDGES AND INTERMEDIATE (TYP)

2x12 @ 12"O.C. JOISTS (TYP)

12'-8<u>3</u>"

½" THICK APA RATED EXTERIOR WALL SHEATHING. FASTEN W/10d

NAILS @ 3" O.C. AT PANEL EDGES

AND 6" O.C. INTERMEDIATE. (TYP.)

-2x12 @ 12"0.C. JOIST

TAPERED TO 2x10 (TYP)

OUTRIGGERS @ 24"O.C. (TYP)

 $-2x4 \times 3'-0"$ LONG MIN.

12'-83"

FASTEN W/CONSTRUCTION

NAILS @ 6"O.C. AT PANEL

<u>OFFICE</u>

RIPPED TO 111/8" (TYP)

MEZZANINE

5¼"x11%" LVL BEAM

%" THICK APA RATED ROOF SHEATHING. FASTEN W/10d NAILS @ 6" O.C. AT PANEL

-2x6 KING STUD

W/(2)2x6 JACK

-2x12 PERIMETER

26'-91"

-EDPM ROOFING BY OTHERS

-½" RELEASE BOARD BY OTHERS

EDGES AND INTERMEDIATE (TYP.)

%" THICK APA RATED ROOF SHEATHING. FASTEN W/10d NAILS @ 6" O.C. AT PANEL

(2)2x10 CONT. PLATE

W/1/2"ø THRU BOLTS @

3'-0"O.C. AT 5½" BEAM

GA. IN ¾6"Ø HOLES (TYP)—

W24x76 STEEL BEAM

— 4" RIGID INSULATION BY OTHERS

CHORD OPEN WEB TRUSSES

-20" DEEP PARALLEL

@ 24"O.C. (TYP)

 $26' - 9\frac{1}{4}"$

- 2x6 @ 24"0.C. EXTERIOR

---2x12 PERIMETER

-6x8 P.T. SILL

BEARING WALL UPPER LEVEL

ALIGN TRUSSES W/STUDS (TYP).

FLOOR JOISTS W/STUDS (TYP).

-2x6 @ 12"O.C. INTERIOR BEARING WALL AT

LOWER LEVEL ALIGN W/ROOF TRUSSES AND

STUD EACH SIDE

L & L STRUCTURA ENGINEERING SERVICES, I SIX Q STREET SOUTH PORTLAND, MAINE 04106