



PORTLAND MAINE

Strengthening a Remarkable City. Building a Community for Life. www.portlandmaine.org

Planning & Urban Development Department
Penny St. Louis Littell, Director

Planning Division
Alexander Jaegerman, Director

JULY 2, 2010

Rick Romano
P.O. Box 1079
Portland, ME 04104

Joseph Delaney
19 Commercial Street
Portland, ME 04101

RE: Review Comments for Final Plan – Administrative Review

Project Name: Riverside Wood/Millwork Shop
Project ID: 10-79900010
Project Address: 828 Riverside St CBL: 325-B-008-001
Planner: Erick Giles, AICP, LEED AP

Mr. Delany:

Thank you for submitting an application for the Riverside Wood/Millwork Shop at 828 Riverside St. This proposal is being reviewed as a final plan for Planning Authority review subject to the following applicable Land Use Code provisions:

- Site Plan Ordinance, Article V

Final Plan Staff Review Comments

a. Deputy City Engineer David Margolis-Pineo

The Department of Public Services has the following comments.

- i. Applicant needs to apply for a sidewalk waiver if they do not intend to install a sidewalk.
- ii. Applicant current shows an approximate 10' x 10' shed within the View Street R-O-W. Applicant shall indicate that this shed will be moved onto the applicant's property within the required 10' setback line.
- iii. Applicant indicates the existing 25' wide driveway will be removed and replaced with a 20' wide driveway. Does the applicant intend to alter the curb cut to the street?
- iv. The applicant is requested to show how drainage from the site will be handled.