BELOW AS APPLICABLE.

2. ALL RECEPTACLES SHALL BE INSTALLED 18" AFF TO CENTERLINE OF BOX UNLESS NOTED OTHERWISE.

COORDINATE WORK ACCORDINGLY. COMPLY WITH SPECIFICATIONS AND NOTES

3. ALL WIRING SHALL BE COPPER UNLESS DESIGNATED AS "AL". UNLESS OTHERWISE NOTED ALL WIRING SHALL BE 2*12 AWG AND 1*12 EQUIPMENT GROUNDING CONDUCTOR. HOMERUNS FED FROM A 20A-1P, 120V CIRCUIT IN EXCESS OF 70'SHALL BE *10 AWG.

4. CONNECT BATTERY BACKED EMERGENCY AND EXIT LIGHTING TO NEARES LIGHTING CIRCUIT AHEAD OF ANY SWITCHING. CONNECT REMOTE HEADS WITH *10 AWG COPPER CONDUCTORS. AC EXIT FIXTURES SHALL BE CONNECTED TO NEAREST EMERGENCY CIRCUIT OR AS INDICATED.

5. TEST ALL EMERGENCY LIGHTING UNITS FOR PROPER OPERATION OF LAMPS AND BATTERIES.

6. SEE MECHANICAL PLAN FOR HVAC UNITS, PUMPS AND FANS CONTROLLED BY THERMOSTATS (PROVIDED BY ATC CONTRACTOR).

7. FUSES AND OVERLOAD UNITS FOR MOTORS SHALL BE SIZED BASED ON ACTUAL MOTOR NAMEPLATE DATA AND IN ACCORDANCE WITH NEC. CIRCUIT BREAKERS FOR MOTORS ARE SUPPLIED AT MAX VALUE PER NEC (2.5 x FLA). SIZE IN THE FIELD IN ACCORDANCE WITH MFGR RECOMMENDATION.

8. ALL WORK SHALL COMPLY WITH NFPA70, NFPA72, NFPA101 & ALL FEDERAL, STATE & LOCAL REGULATIONS.

9. ALL PENETRATIONS THROUGH FLOORS, RATED WALLS AND PARTITIONS SHALL BE SEALED WITH UL APPROVED FIRE SEALANT MATERIAL TO MAINTAIN FIRE RATING FOR THE SEPARATION.

10. ALL ENCLOSURES, CONDUIT BODIES AND THEIR COVERS CONTAINING FIRE ALARM SYSTEM CONDUCTORS SHALL BE PAINTED RED.

11. AN EQUIPMENT GROUNDING CONDUCTOR SHALL BE INSTALLED WITH ALL FEEDERS AND BRANCH CIRCUITS. SIZE IN ACCORDANCE WITH NFPA 70

12. COORDINATE INSTALLATION OF VOICE/DATA OUTLETS WITH OWNER, MIS OR COMMUNICATIONS CONTRACTOR.

13. LOCATE DISCONNECTS AT EQUIPMENT AS REQUIRED BY MANUFACTURER. LOCATIONS ON DRAWINGS ARE APPROXIMATE

14. THE CONTRACTOR SHALL SET ALL ELECTRONIC BREAKERS TO SPECIFIED TRIP SETTINGS BEFORE ENERGIZING EQUIPMENT

15. ALL CONDUCTOR INSULATION FOR BUILDING WIRE SHALL BE THWN/THHN UNLESS NOTED OTHERWISE.

16. OUTLETS INSTALLED IN FIRE RATED WALLS BACK TO BACK SHALL BE SEPARATED BY 24" MINIMUM OR BE PROTECTED WITH "PUTTY PADS" PER 2009 INTERNATIONAL BUILDING CODE SECTION 713.3.2

17. PROVIDE AIR VAPOR BARRIER BOXES FOR WIRING DEVICES IN EXTERIOR WALLS AND INTERIOR SOUND CONTROL WALLS BETWEEN RESIDENT ROOMS INSTALL PER MANUFACTURER'S INSTRUCTIONS. PROVIDE LESSCO MODEL

18. MINIMUM WIRE SIZE ON ALL BRANCH CIRCUITS SHALL BE *12.

ABBREVIATIONS LP LIGHTING PANELBOARD ALTERNATING CURRENT, ABOVE COUNTER LTG LIGHTING AMERICANS WITH DISABILITIES ACT LSIG LONG TIME, SHORT TIME, INSTANTANEOUS, GROUND FAULT AMP FRAME CIRCUIT BREAKER TRIP FUNCTIONS AS INDICATED ARC FAULT CIRCUIT INTERRUPTER MCC MOTOR CONTROL CENTER ABOVE FINISHED FLOOR MCCB MOLDED CASE CIRCUIT BREAKER ABOVE FINISHED GRADE MAIN CIRCUIT BREAKER AMPERES INTERRUPTING CAPACITY MAIN DISTRUBITION PANEL AL ALUMINUM MH MANHOLE AMP TRIP MAIN LUGS ONLY AUTOMATIC TEMPERATURE CONTROL MTS MANUAL TRANSFER SWITCH AUTOMATIC TRANSFER SWITCH NC NORMALLY CLOSED OF NURSE CALL AWG AMERICAN WIRE GAUGE NATIONAL ELECTRICAL CODE BLDG NFPA NATIONAL FIRE PROTECTION ASSOCIATION CONDUIT NIGHT LIGHT CB CIRCUIT BREAKER NORMALLY OPEN NO CI CAST IRON NO. NUMBER CIRCUIT OVERLOAD CENTERLINE POLE CENTRAL MAINE POWER (ELECTRIC UTILITY) PUBLIC ADDRES CONCRETE MASONRY UNIT PUSH BUTTON CURRENT TRANSFORMER POWER FACTOR CONC CONCRETE PH CARBON STEEL PNL COPPER TP1-2 TELE-POWER POLE - POLE AND CIRCUIT NUMBER AS INDICATED CABINET UNIT HEATER PSNH PUBLIC SERVICE OF NEW HAMPSHIRE (ELECTRIC UTILITY) DAMP LOCATION PΤ POTENTIAL TRANSFORMER ELECTRICAL CONTRACTOR PVC POLYVINYL CHLORIDE EXHAUST FAN EXISTING REMAINS IN PLACE EXISTING RELOCATE RSC

ELECTRICAL EQUIPMENT TO BE RELOCATED ELECTRICAL EQUIPMENT TO REMAIN RIGID STEEL CONDUIT RTU ROOF TOP UNIT ELECTRICAL EQUIPMENT TO REMOVE RVNR REDUCED VOLTAGE, NON-REVESING

SMART BOARD SB SUPPLY FAN SINGLE LINE DIAGRAM

3W THREE WIRE

MANUAL MOTOR STARTER SWITCH WITH THERMAL OVERLOAD DEVICE, MOUNTED AT UNIT SOLID STATE

DIRECT CURRENT SWBD-1 SWITCHBOARD NUMBER AS DESIGNATED GROUND FAULT INTERRUPTER TC TIME CLOCK GROUND TRANSFER SWITCH HIGH INTENSITY DISCHARGE

T&B TOP AND BOTTOM HAND-OFF-AUTOMATIC HORSEPOWER TYP TYPICAL UG UNDERGROUND HIGH PRESSURE SODIUM HERTZ VOLT VOLT-AMPERE

٧A ICB INSULATED CASE CIRCUIT BREAKER VFD VARIABLE FREQUENCY DRIVE JUNCTION BOX THOUSAND AMP INTERRUPTING CAPACITY WATT WITH THOUSAND CIRCULAR MIL

WEATHERPROOF THOUSAND VOLTS XFMR TRANSFORMER THOUSAND VOLT-AMPS EXPLOSION PROOF THOUSAND WATTS (KILOWATT) LIGHTING CONTACTORS THREE PHASE 4W FOUR WIRE LATERAL CONTROL PIT

SYMBOL LEGEND

SURFACE MOUNTED POWER PANEL, SEE PANEL SCHEDULES FOR RATING RECESSED MOUNTED POWER PANEL, SEE PANEL SCHEDULES FOR RATING

(1/4) ELECTRIC MOTOR DRIVEN EQUIPMENT, HP SHOWN

H, DS, DW @ JUNCTION BOX, "H" DENOTES RANGE HOOD, "DS" DENOTES DISPOSAL, "DW" DENOTES DISHWASHER SM MANUAL MOTOR STARTER SWITCH WITH THERMAL OVERLOAD DEVICE

MOUNTED AT UNIT DISCONNECT SWITCH, SIZE AND NUMBER OF POLES AS INDICATED ON DRAWING. PROVIDED BY EC UNLESS NOTED OTHERWISE. PROVIDE FUSES WHERE RECOMMENDED BY MANUFACTURER.

COMBINATION MOTOR STARTER/ DISCONNECT SWITCH WITH AUXILARY CONTACTS AND HAND-OFF-AUTO SWITCH AND RED RUN LIGHT. PROVIDED AND INSTALLED BY EC UNLESS NOTED OTHERWISE.

VARIABLE FREQUENCY DRIVE, PROVIDED BY MC, INSTALLED AND WIRED BY EC

DUPLEX RECEPTACLE, 20A, 125V SPEC GRADE GROUNDING TYPE, TAMPER PROOF AND MATCHING PLATE. MOUNT 18" AFF UNLESS NOTED OTHERWISE.

QUAD RECEPTACLE, 20A, 125V SPEC GRADE GROUNDING TYPE, TAMPER PROOF AND MATCHING PLATE. MOUNT 18" AFF UNLESS NOTED OTHERWISE.

DUPLEX RECEPTACLE, 20A, 125V SPEC GRADE GROUNDING TYPE, TAMPER PROOF AND MATCHING PLATE. MOUNT 18" AFF, BOTTOM RECEPTACLE SWITCHED.

GROUND FAULT DUPLEX RECEPTACLE 20A, 125V, TAMPER PROOF WITH MATCHING

PLATE FURNISHED W/ OUTLET. FLUSH MOUNTED 45" AFF UNLESS OTHERWISE NOTED.

REFRIGERATOR DUPLEX RECEPTACLE, 20A, 125V SPEC GRADE GROUNDING TYPE, TAMPER PROOF AND MATCHING PLATE MOUNT RECEPTACLE AT 48" AFF.

CL FLUSH FLOOR MOUNTED DUPLEX RECEPTACLE- 20A, 125V SPEC GRADE GROUNDING TYPE. "CL" DENOTES CEILING MONTED

- RANGE OUTLET 50 AMP, 250 VOLT, GROUNDING TYPE FLUSH MOUNTED 18" AFF → DRYER OUTLET 30 AMP, 250 VOLT, GROUNDING TYPE FLUSH MOUNTED 18" AFF

CONTRACTOR SUPPLIED EQUIPMENT PLUG. CONTRACTOR SHALL COORDINATE PLUG STYLE WITH EQUIPMENT OR EQUIPMENT SUPPLIER PRIOR TO ROUGH-IN.

----- RACEWAY & WIRING OR MC CABLE RUN CONCEALED IN WALLS/CEILINGS BRANCH CIRCUIT WIRING SHALL CONSIST OF ---- RACEWAY & WIRING RUN EXPOSED (1)1/2"C-2*12AWG+1*12GND UNLESS OTHER WISE NOTED. (*)ASTERISK DENOTED *10AWG FOR ALL RACEWAY & WIRING RUN CIRCUITS CONTAINED IN HOME RUN. (**)DOUBLE CONCEALED UNDER FLOOR OR ASTERISK DENOTES (1)3/4"C-2*8AWG+1*10GND. BURIED 30" BELOW FINISH GRADE

PROVIDE EQUIPMENT GROUNDS IN ACCORDANCE

WITH NFPA 70, ARTICLE 250.

CABLE TV JUNCTION BOX "CTV", SIZE AS REQUIRED BY CABLE UTILITY

TEMPERATURE CONTROL PANEL, PROVIDED BY MC WIRED BY EC

PUSHBUTTON FOR ELECTRICALLY OPERATED DOOR, FURN W/ DOOR OPERATOR,

WIRED BY EC

DOOR PUSHBUTTON-DOORBEL

HOME RUN TO PANEL, WITH

PANEL AND CIRCUIT NUMBER

DOOR ELECTRIC STRIKE

LIGHTING FIXTURES, CAPITAL LETTERS DENOTE TYPE PER

LIGHTING FIXTURE SCHEDULE. LOWER CASE LETTERS INDICATE SWITCH CONTROL. "ab" INDICATES INBOARD LAMPS CONTROLLED BY OUTBOARD SWITCHED "a" AND "b". DIAGONAL INDICATED

NIGHT LIGHT (UNSWITCHED)

SELF CONTAINED EMERGENCY LIGHT W/2 HEADS DUAL-LITE (LED) MODEL LZ25NI-03L, 25 WATTS FOR 90 MINUTES, COLOR BY ARCHITECT

INTERIOR REMOTE HEAD DUAL-LITE (LED) MODEL No CPRD 1203L, COLOR BY ARCHITECT

EXTERIOR REMOTE HEAD DUAL-LITE (LED) MODEL No OCRD 1203L COLOR BY ARCHITECT

EXIT LIGHT FIXTURE, UNSWITCHED, DUAL-LITE LX-U-R-W-E OR APPROVED EQUAL

EXIT/ EMERGENCY LIGHT COMBO, DUAL-LITE No EVCU-R-D4-IOR APPROVED EQUAL COLOR BY ARCHITECT

SECURITY CAMERA LOCATION, COORDINATE AND PROVIDE DUPLEX RECEPTACLE, DATA AND CONDUIT PER MANUFACTURERS RECOMMENDATIONS

CEILING MOUNTED MOTION SENSOR (WATTSTOPPER OR EQUAL) CORRIDORS: WT-2255 SENSOR & B120E-P POWER PACK. OTHER COMMON SPACES: WT-605 SENSOR & B120E-P POWER PACK. SENSORS AND RELAYS TO CONTROL CIRCUITS IN SPACES INDICATED. DEVICES SHALL PROVIDE FULL COVERAGE IN AREAS INSTALLED.

DT INDICATES DUAL TECHNOLOGY PIR INDICATED PASSIVE INFRARED TECHNOLOGY

 S_{MS} WALL MOUNTED SWITCH MOTION SENSOR. MOUNT AT 48" AFF UNLESS OTHER WISE NOTED S SINGLE POLE SWITCH, 120V, 20A, SPEC GRADE, GROUNDING TYPE, MOUNT 48" AFF, 3=3-WAY,

 $\mathbb{S}_4\,\mathbb{S}_3$ 4=4-WAY,LOWER CASE LETTER INDICATES FIXTURE OR CONTROLLED LOAD. SWITCH WITH PILOT LIGHT, SWITCH SHALL BE PROVIDED W/ ENGRAVED NAMEPLATE

IDENTIFYING USE SRF REMOTE RANGE HOOD FAN SWITCH, CONNECT TO HOOD FAN THRU HOOD JUNCTION BOX.

SRL REMOTE RANGE HOOD LIGHT SWITCH, CONNECT TO HOOD LIGHT THRU JUNCTION BOX.

SB BURNER SAFETY SWITCH, PROVIDE WITH RED PLATE, MOUNTED 72" AFF

 \square_{\circ} \square Single pole dimmer switch, 120V, 20A, SPEC grade, grounding type, mount 48" Aff, \square_{4} \square_{3} 3=3-way, 4=4-way, lower case letter indicates fixture or controlled load.

PC PHOTOCELL

LC LIGHTING CONTACTOR

TC TIMECLOCK

▼ TELEPHONE/DATA DUAL JACK, MOUNT 18"AFF, RUN TWO CAT 5E CABLES BACK TO TBB (3)

□ DATA JACK, RUN TWO CAT 5E CABLES BACK TO TBB. NUMBER INDICATES QUANTITY

OF RECEPTS, COORDINATE LOCATION WITH OWNER PRIOR TO ROUGH-IN CL FLUSH FLOOR MOUNTED TELEPHONE/DATA DUAL JACK, RUN TWO CAT 5E CABLES

BACK TO TBB. "CL" DENOTES CEILING MOUNTED ▼ TELEPHONE JACK, MOUNT 18"AFF UNLESS NOTED OTHERWISE, RUN ONE CAT 5E CABLE

TELEPHONE BACK BOARD

™(((●)) WiFiROUTER, OCE CAT 5E CABLE BACK TO TBB OR IT ROOM. MOUNT ABOVE CEILING,

' "W" DENOTES WALL MOUNTED AT 72" AFF

IP INTERCOM PANEL IN UNIT

INTERCOM PANEL AT RECEPTION

CARD READER LOCATION: PROVIDE BOX AND 3/4" CONDUIT TO NEAREST LOCATION ABOVE SUSPENDED CEILING. PROVIDE 120V DOOR STRIKE POWER FROM NEAREST RECEPTACLE CIRCUIT.

FACE FIRE ALARM CONTROL PANEL WITH DEDICATED TELEPHONE JACK

ANN FIRE ALARM ANNUNCIATOR PANEL

FEM FIRE EXTINGUISHER ELECTRONIC MONITOR-SHALL BE ACCOMPLISHED THROUGH USE OF AN ADDRESSABLE INTERFACE DEVICE AND SHALL PROVIDE INPUT TO THE FACP

FIRE ALARM AUDIO/VISUAL, MOUNT 6'-8"AFF, NUMBER DENOTES CANDELA RATING. "MH" DENOTES MINIHORN, "CL" DENOTES CEILING MOUNTED. NO DESIGNATION EQUALS 15cd

F FIRE ALARM PULL STATION, MOUNT 48"AFF

15 SDI FIRE ALARM VISUAL STROBE ONLY, FLUSH MOUNT 6'-8" AFF, NUMBER DENOTES

CANDELA RATINGS. "CL" DENOTES CEILING MOUNTED SYSTEM CONNECTED SMOKE / CARBON MONOXIDE DETECTOR, PHOTOELECTRIC TYPE

135° SYSTEM CONNECTED FIXED TEMPERATURE HEAT DETECTOR

(SD) SMOKE DETECTOR, PHOTOELECTRIC TYPE, SYSTEM CONNECTED.

SMOKE DETECTOR, PHOTOELECTRIC TYPE, SYSTEM CONNECTED.

"ER" DENOTES ELEV RECALL SB SYSTEM CONNECTED SMOKE DETECTOR, PHOTOELECTRIC TYPE, WITH SOUNDER BASE

(c) CARBON MONOXIDE DETECTOR

SD DUCT SMOKE DETECTOR & TEST STATION

FIRE/SMOKE DAMPER, SUPPLIED AND INSTALLED BY MECHANICAL CONTRACTOR. ELECTRICAL CONTRACTOR TO PROVIDE ALL WIRING CONNECTIONS AND FIRE ALARM DUCT SMOKE DETECTORS, ADDRESSABLE MODULES AND PROGRAMMING.

F SPRINKLER SYSTEM FLOW SWITCH | SUPPLIED BY SPRINKLER CONTRACTOR

WIRED BY EC, VERIFY LOCATIONS WITH SPRINKLER SYSTEM TAMPER SWITCH SPRINKLER CONTRACTOR.

	Main Kit / Item	Design	Energy	Required	Dedicate	Energy	Receptacle	Other
Legend #		Count	Source	Voltage	Circuit	BTUs	Height AFF	Notes
	Walk-in, keg & bottle beer (7*12)/no floor	1	Electric	208	Υ	1 ph/ 14 amps		Add light circuit/evap coil drain nec/interior compr
	Liquor lock up (back bar cabinet)	1	N/A	N/A	N		·	
	Beer blast unit (NO2)	1	Electric	110	Υ	11 amps	36"	tank must be chained to wall
	Other	1	N/A	N/A	N			
4	Dish rack, dirty (4' * 2')	1	N/A	N/A	N			
	Pepsi BIB pump rack/supplied by Pepsi	1	N/A	N/A	N			CO2 line required/soda trunk line starts here
6	Dish rack, run in, dirty w/ over shelf for glass	1	N/A	N/A	N			
7	Dish machine, pre-wash	1	H20	N/A	N			H2O required/floor drain (to grease trap)
8	Dish machine, high temp rinse, ventless	1	Electric	208	Υ	3 ph/ 30 amps	Disconnect required? 6'	H2O required/floordrain (NOT to grease trap)
9	Dish rack, run out, clean	1	N/A	N/A	N			
10	Floor sink/drain	5	N/A	N/A	N			these are NOT routed through the grease interceptor
11	Potsink, 24" * 90", 3 bay w/ dbl drain boards	1	H20	N/A	N			Regr H2o/floordrain (to grease trap)
12	Dish rack, clean (4' by 2')	1	N/A	N/A	N			
14	Keg racks, for empties	1	N/A	N/A	N			
15	BIB storage	1	N/A	N/A	N			
16	H2O heater, gas	1	Gas & elec	N/A	N	190,000	Hard wired top of unit	H2O required & drain / power exhaust, sep circuit
17	Bottle racks, for empties	1	N/A	N/A	N			4' by 18" "Costco" rack on casters
18	Dry storage racks	1	N/A	N/A	N			4' by 18" "Costco" rack on casters
19	Walk-in, cooler (11' * 16')/exterior w/ floor	1	Electric	208	Y	1 ph/ 14 amps	Disconnect required? 6'	Add light circuit/evap coil drain nec/exterior compr
20	Freezer, 2 door	2	Electric	208	Υ	12 amps		
21	1,000 external grease interceptor	1	N/A	N/A	N			Fed from pre-wash sink and 3 bay pot sink ONLY
22	Carbinator (from Pepsi)	1	electic	110	Υ	9 amps		Reqr H2O & drain
22.5	Uniform/shirt rack/from linen company	1	N/A	N/A	N			Uniforms on hangers
23	Linen bin - soiled/from linen company	2	N/A	N/A	N			Soiled uniforms
24	Chemical storage/dedicated rack	1	N/A	N/A	N			
25	Salamander	1	Gas	N/A	N	36,000		Wall mount
26	Ice machine, 600 lb head & bin	1	Electric	208	Υ	12 amps	60"	H2O & floor drain required
27	Mop sink	1	N/A	N/A	N			H2O & drain reuired
28/28.5	Pizza ovens, TSB18", stacked	2	Electric	220	Υ	3 ph/ 50 amps		Italforni TSB24" (19.5 KW)
29	Rational ovens, 61G w/ stand	1	Elec & Gas	110	Υ	82,000 / 5 amps	36"	oven on stand, floor sink below, H2O required
30	Cook top/hot plate, 2 burner/802HA	1	Gas	N/A	Υ	60,000		12" L-R counter top unit
30.5	Flat top grill (15")/Star 615BF	1	Gas	N/A	Υ	30,000		15" L-R counter top unit
31	Char-broiler (15")/Star 6115RCBF	1	Gas	N/A	Υ	50,000		15" L-R counter top unit
	Chef base, refrigeration unit - 4'	1	Electric	110	Υ	8 amps	18"	4' L-R / 4 draw unit
	S/S table, 5'	1	N/A	N/A	N			5' with splash
33	Fryers	3	Gas	N/A	N	122,000		122,000 btu PER fryer
	Hood, cooking line, 18' by 4' ID	1	Electric	208	Υ	15 amps		Additional lighting circuit
	Pizza prep unit	1	Electric	110	Υ	9 amps	from over shelf	6' unti (6 draws) on casters
	Under counter flat top unit	1	Electric	110	Υ	5 amps	from over shelf	5' unti (4 draws) on casters

ERM

DC

GND

HΖ

EXISTING REMOVE

ELECTRIC UNIT HEATER

EWC ELECTRICAL WATER COOLER

FACP FIRE ALARM CONTROL PANEL

FAPS FIRE ALARM PULL STATION


FURNISHED WITH UNIT

LIGHT EMITTING DIODE

FIBER REINFORCED PLASTIC

FULL VOLTAGE, NON-REVERSING

37	Sandwich unit	1	Electric	110	Υ	8 amps	from over shelf	5' unit on casters
38	Food warmer	1	Electric	110	Y	12 amps	side of overshelf	3 dille oil oddeeld
39	Other	1	Electric	110	Υ	15 amps	side of overshelf	
40	Overshelf, dbl stack (w/ heat lamps)	1	N/A	N/A	N	13 amp3	Side of oversilen	16'
40.5	Heat lamps, 4'	3	Electric	110	Y	1100 watts ea	from over shelf	each lamp requires a circuit
41	Freezer, 1 door	1	Electric	110	Y	8 amps	36"	edon famp regames a circuit
42	S/S table, 2' by 2'	2	N/A	N/A	N	o dirips	30	
43	Coffee maker	1	Electric	208	Y	14 amps	4" above splash	1 circuit / H2O required
44	Sink, 2' by 2' for French fries	1	H20	N/A	N		,	H2O & drain required
44.5	Frycutter/wall mount	1	N/A	N/A	N			WALL BLOCKING for cutter board
45	S/S table w/ splash - 4' by 2'	1	N/A	N/A	N			48" by 24"
46	Sink, 2' by 4', for vegtables	1	H20	N/A	N			H2O & drain required
47	Other	1	Electric	110	Y	8 amps		
48	Freezer/cooler split, server only	1	Electric	110	Y	8 amps	36"	
49	Glasswasher (under counter)	1	Electric	208	Y	30 amps	24"	H2O & drain required / 2 pull 50 amp breaker
50	Wet/dry glass drain	1	H20	N/A	N			H2O & drain required
51	Other	1	N/A	N/A	N			700000000000000000000000000000000000000
52	Pick up server rack	1	N/A	N/A	N			
53	Other	1	Electric	120	Υ	12 amps	4" above splash	
54	Hose reel, kitchen clean up	1	N/A	N/A	N		60"	H2O required / WALL BLOCKING
55	Proofer/warmer	1	Electric	110	Υ	14 amps		,
56	NCO2 bulk tank	1	N/A	N/A	N	•		NCO2 to relocate
57	Toaster, 4 slice	1	Electric	110	V	13 amps	from over shelf	
58	Other	1	N/A	N/A	N			24" by 30"
59	Floor sink/drain to GREASE interceptor	2	N/A	N/A	N			From pre-wash sink and 3 bay sink ONLY
60	Micros terminal	1	Electric	110	Y	3 amps	30" (within cabinet base)	dedicated grnd for this circuit
61	Micros printer(s)	2	Electric	110	use above	3 amps		use recptl for Micros screen
62	Floor drains	6	N/A	N/A	N			
63	Tortilla press	1	Electric	110	Y	15 amps		
64	Coffee marker, vender, controller	1	H20/electric	110	Y	13 amps	within cab base	1 circuit for all 3 pieces / 1/4" H2O line required
65	Microwave	1	Electric	110	Υ	14 amps	60"	
66	Server beepers/call charging station	1	Electric	110	Υ	3 amps	48"	Wall mount at 48" AFF
67	Other	1	N/A	N/A	N			
68	Pepsi fountain unit	1	Electric	110	Υ	6 amps		H2O & drain req. (floor bell works well)
69	Hand sink, cut into s/s table	1	N/A	N/A	N			H2O & drain req.
70	Hand sink, towel & soap built, on legs	1	N/A	N/A	N			H2O & drain req.
71	Hand sink, drop in	1	N/A	N/A	N			H2O & drain req.
72	Icee unit	1	H20/electric	220	Υ	14 amps	36"	2 pull, 20 amp breaker / 1/4" H20 line/CO2 line
73	Pizza warmer	1	Electric	110	Υ	8 amps	4" above splash	
74	Pretzel warmer	1	Electric	110	Υ	8 amps	4" above splash	



ATION

RENOV

ANE

ANK

M

MZ

Date Drawn -Drawn By -

Revised -03/24/16 - PERMIT

| Project •

Scale - AS NOTEL

Sheet Number