Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 07/21/15

SECOND FLOOR LAYOUT
SCALE 1/4"=1'-0"

HEAD LEGEND

- (8) (155) VIKING MODEL VK302 WHITE PENDENT
  STANDARD SURFACE MOUNT WHITE ESCUTCHEON
  QUICK RESPONSE, STANDARD COVERAGE
  K=5.6, 1/2" NPT, SIN VK302
- (29) (155) VIKING MODEL VK302 WHITE PENDENT
  STANDARD SURFACE MOUNT WHITE ESCUTCHEON
  W/ MODEL D-1 HEAD GUARD
  QUICK RESPONSE, STANDARD COVERAGE
  K=5.6, 1/2" NPT, SIN VK302
- (10) (155) RELIABLE MODEL F1FR56 UPRIGHT
  BRASS ON SPRIG
  QUICK RESPONSE, STANDARD COVERAGE
  K=5.6, 1/2" NPT, SIN RA1425

DEAN & ALLYN, INC.
FIRE PROTECTION · SPECIAL HAZARD
116 LEWISTON ROAD, GRAY, MAINE 04039
(207)657-5646 FAX:(207)657-5647

SCALE 3/32"=1'-0" | SCALE 1/8"=1'-0" | SCALE 3/16"=1'-0" | SCALE 1/4"=1'-0"

DANA A. STEWART
NICET IV – #064544

				APPROVED BY	DATE	SURVEYED BY	SEC	5/13/15
					/ /	DRAWN BY	SEC	5/17/15
					/ /	CHECKED BY	DAS	5/19/15
					/ /	AT DEAN & ALLYN, INC		
		0	SUBMIT FOR APPROVAL	5/20/15	/ /	SCALE AS NOTED		
			REVISIONS	DATE	/ /	SHEET NO. 2 OF 2		

DRAWING TITLE: SPRINKLER SYSTEM LAYOUT

SUBMITTAL

JOB: SPURWINK SERVICES
899 RIVERSIDE STREET
PORTLAND, ME
SOUTH PORTLAND, ME 04106

NO. OF SPRINKLERS SHOWN ON THIS SHEET: 47

NO. OF SPRINKLERS ON JOB: 97

CONTRACT WITH: PC CONSTRUCTION

CONTRACT NO. C151271