Building Inspections - Spurwink Services Kaufman House

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 07/21/15

From: Scott Cote <SCote@deanandallyn.com>
To: Building Inspections <buildinginspections@portlandmaine.gov>
Date: 6/16/2015 9:44 AM
Subject: Spurwink Services Kaufman House
Attachments: 1ST FLOOR.pdf; 2ND FLOOR.pdf; Portland Permit.pdf

Please find attached Sprinkler Layout drawings for Levels I & II Spurwink Services (Kaufman House). The building is an existing building with an existing schedule sprinkler system. Renovations will maintain existing schedule system. All system components will remain with the exception of adding monitoring devices for heads in elevators and elevator machine room. All other work is limited to these two levels.

Any questions or concerns please feel free to contact me. Thank you.

Scott Cote
System Specialist
Dean and Allyn Inc
P (207) 657-5646
C (207) 272-0122
Email: scote@deanandallyn.com