

Vista 250

| Quantity | Part # | Description | Standby | Alarm | Total standby | Total alarm |
|--------------|--------|-------------------------|---------|-------|---------------|-------------|
| 1 | V250 | Fire Panel (maximum) | 0.305 | 0.485 | 0.305 | 0.485 |
| 1 | 6160CR | Annunicator | 0.150 | 0.150 | 0.150 | 0.150 |
| | 4208SN | Expander | 0.001 | 0.033 | 0.000 | 0.000 |
| 1 | | Sprinkler | 0.001 | 0.001 | 0.001 | 0.001 |
| 11 | | Pull Station | 0.001 | 0.001 | 0.011 | 0.011 |
| | 2W | Smoke | 0.000 | 0.130 | 0.000 | 0.000 |
| | 4W | Smoke | 0.020 | 0.023 | 0.000 | 0.000 |
| | | heat | 0.000 | 0.000 | 0.000 | 0.000 |
| 10 | | Addressable smoke | 0.001 | 0.001 | 0.010 | 0.010 |
| | | Motion | 0.015 | 0.022 | 0.000 | 0.000 |
| | | Duct Detector | 0.001 | 0.001 | 0.000 | 0.000 |
| | | Duct smoke | 0.001 | 0.001 | 0.000 | 0.000 |
| | | Duct relay | 0.001 | 0.001 | 0.000 | 0.000 |
| | | Duct Remote | 0.001 | 0.001 | 0.000 | 0.000 |
| | | Remote light | 0.001 | 0.001 | 0.000 | 0.000 |
| | | | 0.000 | 0.000 | 0.000 | 0.000 |
| 1 | | NAC Trigger only | 0.000 | 0.001 | 0.001 | 0.001 |
| | | NAC power maximum (24V) | 0.000 | 3.400 | 0.000 | 0.000 |
| | | NAC power maximum (12V) | | 2.300 | 0.000 | 0.000 |
| | | | | | 0.000 | 0.000 |
| | | | | | 0.000 | 0.000 |
| | | Miscellaneous | | | 0.000 | 0.000 |
| TOTAL | | | 0.499 | 6.552 | 0.478 | 0.658 |

| | Hours | Standby current | | Total |
|---------|------------|------------------|--|---------------|
| | 24 | 0.4780 | | 11.472 |
| Minutes | | Alarm current | | |
| 5 | 0.08333333 | 0.6580 | | 0.055 |
| | | Battery Capacity | | |
| | 10% | 11.5268 | | 12.680 |