## **Sequence of Operations**

	Audio/visual activation	Activate audible/visual signal at FACP & Annunciator	Device Description at FACP & Annunciator	Shutdown of HVAC equipment	Log event in system history	Activate Elevator Fire Hat	Activate Elevator primary or secondary control	Activate Elevator shunt trip	Silence of audible devices Including FACP & annunciator	Release door holders	Release locked doors	Event acknowledgement	Reset of all system functions and all visual devices	Remote transmission to Central Station A=alarm; T=trouble; S=Supervisory; L = log only	Remote indicator
Manual Pull Stations		X	X	<u>, , , , , , , , , , , , , , , , , , , </u>	X	Ì			<u> </u>	X	X			Α .	
Smoke detectors common area	Х	Х	Х		Х					Х	Χ			Α	
Smoke detectors elevator lobbies	Х	Х	Х		Х		Х			Х	Χ			Α	
Smoke Detectors elevator shaft/machine room	Х	Х	Х		Х	Χ	Х			Х	Χ			Α	
Duct mounted Smoke Detectors		Х	Χ	Χ	Х									S	Χ
Heat Detectors common area/inside apartments	Х	Х	Х		Х					Х	Χ			Α	
Heat Detectors Elevator shaft/machine room	Х	Х	Х		Х	Χ		Χ		Х	Χ			Α	
Sprinkler flow or pressure switches	Χ	X	Χ		Χ					Х	Χ			Α	
Sprinkler Tamper, low temp, or low air		X	Χ		Χ									S	
Secondary fire panel such as kitchen hood	Χ	Х	Χ		Х					Х	Χ			A	
FACP/annunciator silence button		Х	Х		Х				Х					L	
FACP/annunciator acknowledge button		Х	Χ		Χ							Χ			
FACP/annunciator reset button		Х	Χ		Х								X	L	
Removal of any device		Χ	Х		Χ									Т	
Ground fault		Χ	Х		Χ									Т	
System wiring "open"		Χ	Х		Χ									Т	
AC Power loss		Χ	Х		Χ									Т	
Secondary power loss		Χ	Х		Χ									Т	
Telephone line loss		Х	Χ		Х									T	