


City of Portland, Maine - Building or Use Permit Application

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 05-1324	Issue Date: OCT 11 2005	CEB: 320 B007001
-----------------------	-----------------------------------	---------------------



Location of Construction: I4 Industrial Way	Owner Name: Northeastern Graphic Supply	Owner Address: Po Box 1418
Business Name:	Contractor Name: HVAC Services, Inc.	Contractor Address: 73 Bradley Drive Westbrook
Lessee/Buyer's Name	Phone:	Permit Type: HVAC
Past Use: Commercial	Proposed Use: Commercial install a trane rtu's & furnace in attic/roof	Permit Fee: \$246.00
		Cost of Work: \$25,000.00
		CEO District: 5
Proposed Project Description: Install a Trane rtu's & furnace in attichoof.	FIRE DEPT: <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied to NCPA 90A	INSPECTOR: Use Group: N/A HVAC 10/5/05 [Signature]
	Signature:	Signature:
	PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)	
	Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied	
	Signature:	Date:

Permit Taken By: dmartin	Date Applied For: 09/13/2005	Zoning Approval		
1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules. 2. Building permits do not include plumbing, septic or electrical work. 3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..	Special Zone or Reviews <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan Maj <input type="checkbox"/> Minor <input type="checkbox"/> MIM <input type="checkbox"/> Date: 1/3/05	Zoning Appeal <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied Date:	Historic Preservation <input checked="" type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied Date:	

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.


SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE		DATE	PHONE



FILL IN AND SIGN WITH INK

326 B.007

APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT



To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL 14 Industrial Way Portland ME Use of Building _____ Date 9/9/05
 Name and address of owner of appliance Andy Graham
14 Industrial Way Portland ME
 Installer's name and address HVAC SERVICES INC
73 Bradley Dr. Westbrook ME 04092 Telephone 854 8422

Location of appliance:

- Basement Floor
 Attic Roof

Type of Fuel:

- Gas Oil Solid

Appliance Name: Trane Rtu's & Furnace

U.L. Approved Yes No

Will appliance be installed in accordance with the manufacture's installation instructions? Yes No

IF NO Explain: _____

The Type of License of Installer:

- Master Plumber # _____
 Solid Fuel # _____
 Oil # _____
 Gas # PNT 896
 Other _____

Type of Chimney:

- Masonry Lined
 Factory built _____
 Metal
 Factory Built U.L. Listing # _____

direct Vent
Type _____ UL# _____

Type of Fuel Tank

- Oil
 Gas


Size of Tank _____

Number of Tanks _____

Distance from Tank to Center of Flame _____ feet.

Cost of Work: \$ 25,000

Permit Fee: \$ 246.00



Approved

Fire: _____
 Ele.: _____
 Bldg.: _____

Approved with Conditions

- See attached letter or requirement

Inspector's Signature _____

Date Approved _____

Signature of Installer _____

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 05-1324	Date Applied For: 09/12/2005	CBL: 326 B007001
------------------------------	--	----------------------------

Location of Construction: 14 Industrial Way	Owner Name: Northeastern Graphic Supply	Owner Address: Po Box 1418	Phone:
Business Name:	Contractor Name: HVAC Services, Inc.	Contractor Address: 73 Bradley Drive Westbrook	Phone (207) 854-4822
Lessee/Buyer's Name	Phone:	Permit Type: HVAC	

Proposed Use: Commercial install a trane rtu's & furnace in attic/roof	Proposed Project Description: Install a Trane rtu's & furnace in attichoof.
--	---


Dept: Zoning **Status:** Approved **Reviewer:** Marge Schmuckal **Approval Date:** 09/13/2005
Note: **Ok to Issue:**

Dept: Building **Status:** Approved with Conditions **Reviewer:** Mike Nugent **Approval Date:** 10/05/2005
Note: **Ok to Issue:**

1) Equipment must be installed in compliance with the manufacturer's specifications

Dept: Fire **Status:** Approved with Conditions **Reviewer:** Cptn Greg Cass **Approval Date:** 09/13/2005
Note: **Ok to Issue:**

1) Entire system to be checked for compliance with NFPA 90A



CIVIL & STRUCTURAL ENGINEERING
 www.cascobayengineering.com
 424 Fore St., Portland, ME 04101 Phons 207.842.2800 Fax 207.842.2828

September 7, 2005

Mr. Michael Nugent
 Inspection Services Manager
 City of Portland
 389 Congress Street
 Portland, ME 04101

Re: Color Works Renovation, Riverside Street


Project Number: 5059


Dear Mr. Nugent:


This letter is to confirm that **we have** analyzed the existing roof supports for the proposed HVAC **units**: 1 unit (ceiling hung) **weight** -140 lbs; 2 units (roof mounted, 5 ton units) weight =615 lbs; 1 unit (roof mounted, 15 ton unit) weight=2,005 lbs. The new units are in the same locations as the existing HVAC units were **located**, The existing units will be removed prior to the placement of the new units noted above.

Please contact us **if** you have any additional questions or concerns,

Sincerely,


 Eric Dube
 President
 Casco Bay Engineering


 Carolyn C. Bird, P.E.
 Vice President
 Casco Bay Engineering



ERIC DUBE TO SEND NEW LETTER