

NOTCH TO RECEIVE METAL WALL PANEL, TYP AT EXTERIOR FOUNDATION WALLS

1/2" CHAMFER

1/2"

2 1/2"

10"

4 1/2"

1" TROWELED CHAMFER (OMIT AT TWALL = +0'-0")

T/WALL (+2'-0")

#4'S AT 12" O.C. VERT

1" RIGID INSULATION WITH 45° TAPER AND SEALANT SLAB

EXT. GRADE

F.F. (+0'-0")

#4'S AT 12" O.C. HORIZ.

#4 DOWELS TO WALL AT 16" O.C.

18"

8"

NOTES

1. SEE C2/S3 FOR ADD'L INFO
2. USE REINFORCING SHOWN FOR ALL 10" THICK WALLS
3. SEE ARCH FOR ADDITIONAL WALL AND SLAB INSULATION.

(2) #5'S IN FOOTING

VARIES SEE PLAN

VARIES

4'-6" MIN.

1'-0"

2'-0"

ASSOCIATED DESIGN PARTNERS INC.

80 Leighton Road Office: (207) 878-1751
 Falmouth, Maine 04105 Fax: (207) 878-1788
 E-Mail: adp@adpengineering.com

THIS DRAWING, DESIGN AND ELECTRONIC FILE ARE THE PROPERTY OF ASSOCIATED DESIGN PARTNERS, INC. THE REPRODUCTION, COPYING OR ANY OTHER USE OF THIS DOCUMENT WITHOUT WRITTEN CONSENT IS PROHIBITED.

PROJECT: **ALLAGASH BREWERY BREWHOUSE ADDITION**
 FOR:

SHEET TITLE:
THERMAL BREAK AT FND WALL AND SLAB

REVISIONS

No.	BY	DESCRIPTION	DATE
▲			
▲			
▲			
▲			

DATE : 10-23-12
 SCALE : 3/4"=1'-0"

DESIGN BY: ASW
 DRAWN BY: RSC

FILE #:
 PROJECT NUMBER:
12160

SHEET NO:
SKC-2