

FIRE ALARM AND EMERGENCY COMMUNICATION SYSTEM RECORD OF COMPLETION

*To be completed by the system installation contractor at the time of system acceptance and approval.
It shall be permitted to modify this form as needed to provide a more complete and/or clear record.
Insert X's in all unused lines.*

Attach additional sheets, data, or calculations as necessary to provide a complete record.

1. PROPERTY INFORMATION

Name of property: Allagash Brewing
Address: 50 Industrial Way, Portland ME
Description of property: Allagash Brewery and retail store
Occupancy type: Commercial
Name of property representative:
Address:
Phone: Fax: E-mail:
Authority having jurisdiction over this property: Portland Fire Dept
Phone: 207-874-8570 Fax: E-mail:

2. INSTALLATION, SERVICE, AND TESTING CONTRACTOR INFORMATION

Installation contractor for this equipment: TRT Electric
Address: 65 Washington St Augusta ME
License or certification number:
Phone: 207-512-8301 Fax: E-mail:
Service organization for this equipment: BK Systems Inc.
Address: 4 Cote Ave Gulfstream ME
License or certification number:
Phone: 603-647-8775 Fax: E-mail:
A contract for test and inspection in accordance with NFPA standards is in effect as of:
Contracted testing company: Norris Inc.
Address: 2237 Broadway South Portland ME
Phone: 1-800-270-3473 Fax: E-mail:
Contract expires: Contract number: Frequency of routine inspections:

3. DESCRIPTION OF SYSTEM OR SERVICE

- Fire alarm system (nonvoice)
 Fire alarm with in-building fire emergency voice alarm communication system (EVACS)
 Mass notification system (MNS)
 Combination system, with the following components:
 Fire alarm EVACS MNS Two-way, in-building, emergency communication system
 Other (specify):

3. DESCRIPTION OF SYSTEM OR SERVICE (continued)

NFPA 72 edition: 2010

Additional description of system(s):

3.1 Control Unit

Manufacturer: Notifier

Model number: NFW2-100

3.2 Mass Notification System

This system does not incorporate an MNS

3.2.1 System Type:

- In-building MNS combination
- In-building MNS stand-alone Wide-area MNS Distributed recipient MNS
- Other (specify):

3.2.2 System Features:

- Combination fire alarm MNS MNS autonomous control unit Wide-area MNS to regional national alerting interface
- Local operating console (LOC) Direct recipient MNS (DRMNS) Wide-area MNS to DRMNS interface
- Wide-area MNS to high-power speaker array (HPSA) interface In-building MNS to wide-area MNS interface
- Other (specify):

3.3 System Documentation

An owner's manual, a copy of the manufacturer's instructions, a written sequence of operation, and a copy of the numbered record drawings are stored on site. Location: Fire Alarm Panel

3.4 System Software

This system does not have alterable site-specific software.

Operating system (executive) software revision level:

Site-specific software revision date:

Revision completed by:

A copy of the site-specific software is stored on site. Location:

3.5 Off-Premises Signal Transmission

This system does not have off-premises transmission.

Name of organization receiving alarm signals with phone numbers:

Alarm: Cunningham Security

Phone: 1-800-210-0257

Supervisory: Cunningham Security

Phone: 1-800-210-0257

Trouble: Cunningham Security

Phone: 1-800-210-0257

Entity to which alarms are retransmitted:

Phone:

Method of retransmission:

If Chapter 26, specify the means of transmission from the protected premises to the supervising station:

If Chapter 27, specify the type of auxiliary alarm system: Local energy Shunt Wired Wireless

4. CIRCUITS AND PATHWAYS

4.1 Signaling Line Pathways

4.1.1 Pathways Class Designations and Survivability

Pathways class: 0 Survivability level: N/A Quantity:
(See NFPA 72, Sections 12.3 and 12.4)

4.1.2 Pathways Utilizing Two or More Media

Quantity: 0 Description: N/A

4.1.3 Device Power Pathways

- No separate power pathways from the signaling line pathway
- Power pathways are separate but of the same pathway classification as the signaling line pathway
- Power pathways are separate and different classification from the signaling line pathway

4.1.4 Isolation Modules

Quantity:

4.2 Alarm Initiating Device Pathways

4.2.1 Pathways Class Designations and Survivability

Pathways class: A Survivability level: 0 Quantity: 1
(See NFPA 72, Sections 12.3 and 12.4)

4.2.2 Pathways Utilizing Two or More Media

Quantity: 0 Description: N/A

4.2.3 Device Power Pathways

- No separate power pathways from the initiating device pathway
- Power pathways are separate but of the same pathway classification as the initiating device pathway
- Power pathways are separate and different classification from the initiating device pathway

4.3 Non-Voice Audible System Pathways

4.3.1 Pathways Class Designations and Survivability

Pathways class: A Survivability level: 0 Quantity: 3
(See NFPA 72, Sections 12.3 and 12.4)

4.3.2 Pathways Utilizing Two or More Media

Quantity: 0 Description: N/A

4.3.3 Appliance Power Pathways

- No separate power pathways from the notification appliance pathway
- Power pathways are separate but of the same pathway classification as the notification appliance pathway
- Power pathways are separate and different classification from the notification appliance pathway

5. ALARM INITIATING DEVICES

5.1 Manual Initiating Devices

5.1.1 Manual Fire Alarm Boxes

This system does not have manual fire alarm boxes.

Type and number of devices: Addressable: _____ Conventional: _____ Coded: _____ Transmitter: _____
Other (specify): _____

5.1.2 Other Alarm Boxes

This system does not have other alarm boxes.

Description:

Type and number of devices: Addressable: _____ Conventional: _____ Coded: _____ Transmitter: _____
Other (specify): _____

5.2 Automatic Initiating Devices

5.2.1 Smoke Detectors

This system does not have smoke detectors.

Type and number of devices: Addressable: _____ Conventional: _____

Other (specify): _____

Type of coverage: Complete area Partial area Nonrequired partial area

Other (specify): _____

Type of smoke detector sensing technology: Ionization Photoelectric Multicriteria Aspirating Beam

Other (specify): _____

5.2.2 Duct Smoke Detectors

This system does not have alarm-causing duct smoke detectors.

Type and number of devices: Addressable: _____ Conventional: _____

Other (specify): _____

Type of coverage:

Type of smoke detector sensing technology: Ionization Photoelectric Aspirating Beam

5.2.3 Radiant Energy (Flame) Detectors

This system does not have radiant energy detectors.

Type and number of devices: Addressable: _____ Conventional: _____

Other (specify): _____

Type of coverage:

5.2.4 Gas Detectors

This system does not have gas detectors.

Type of detector(s): _____

Number of devices: Addressable: _____ Conventional: _____

Type of coverage:

5.2.5 Heat Detectors

This system does not have heat detectors.

Type and number of devices: Addressable: _____ Conventional: _____

Type of coverage: Complete area Partial area Nonrequired partial area Linear Spot

Type of heat detector sensing technology: Fixed temperature Rate-of-rise Rate compensated

5. ALARM INITIATING DEVICES (continued)

5.2.6 Addressable Monitoring Modules

This system does not have monitoring modules.

Number of devices:

5.2.7 Waterflow Alarm Devices

This system does not have waterflow alarm devices.

Type and number of devices: Addressable: Conventional: Coded: Transmitter:

5.2.8 Alarm Verification

This system does not incorporate alarm verification.

Number of devices subject to alarm verification: Alarm verification set for seconds

5.2.9 Presignal

This system does not incorporate pre-signal.

Number of devices subject to presignal:

Describe presignal functions:

5.2.10 Positive Alarm Sequence (PAS)

This system does not incorporate PAS.

Describe PAS:

5.2.11 Other Initiating Devices

This system does not have other initiating devices.

Describe:

6. SUPERVISORY SIGNAL-INITIATING DEVICES

6.1 Sprinkler System Supervisory Devices

This system does not have sprinkler supervisory devices.

Type and number of devices: Addressable: Conventional: Coded: Transmitter:

Other (specify):

6.2 Fire Pump Description and Supervisory Devices

This system does not have a fire pump.

Type fire pump: Electric pump Engine

Type and number of devices: Addressable: Conventional: Coded: Transmitter:

Other (specify):

6.2.1 Fire Pump Functions Supervised

Power Running Phase reversal Selector switch not in auto Engine or control panel trouble Low fuel

Other (specify):

6.3 Duct Smoke Detectors (DSDs)

This system does not have DSDs causing supervisory signals.

Type and number of devices: Addressable: Conventional:

Other (specify):

Type of coverage:

Type of smoke detector sensing technology: Ionization Photoelectric Aspirating Beam

6.4 Other Supervisory Devices

This system does not have other supervisory devices.

Describe: Booster trouble supervisory

7. MONITORED SYSTEMS

7.1 Engine-Driven Generator

This system does not have a generator.

7.1.1 Generator Functions Supervised

- Engine or control panel trouble
- Generator running
- Selector switch not in auto
- Low fuel
- Other (specify):

7.2 Special Hazard Suppression Systems

This system does not monitor special hazard systems.

Description of special hazard system(s):

7.3 Other Monitoring Systems

This system does not monitor other systems.

Description of special hazard system(s):

8. ANNUNCIATORS

This system does not have annunciators.

8.1 Location and Description of Annunciators

Location 1: Retail left entrance EDU-80

Location 2:

Location 3:

9. ALARM NOTIFICATION APPLIANCES

9.1 In-Building Fire Emergency Voice Alarm Communication System

This system does not have an FVACS.

Number of single voice alarm channels:

Number of multiple voice alarm channels:

Number of speakers:

Number of speaker circuits:

Location of amplification and sound-processing equipment:

Location of paging microphone stations:

Location 1:

Location 2:

Location 3:

9.2 Nonvoice Notification Appliances

This system does not have nonvoice notification appliances.

Horns: 10

With visible: 10

Bells:

With visible:

Chimes:

With visible:

Visible only: 9

Other (describe):

9.3 Notification Appliance Power Extender Panels

This system does not have power extender panels.

Quantity: 1

Locations: Production electric room

10. MASS NOTIFICATION CONTROLS, APPLIANCES, AND CIRCUITS This system does not have an MNS

10.1 MNS Local Operating Consoles

Location 1:

Location 2:

Location 3:

10.2 High-Power Speaker Arrays

Number of HP/SA speaker initiation zones:

Location 1:

Location 2:

Location 3:

10.3 Mass Notification Devices

Combination fire alarm/MNS visible appliances:

MNS-only visible appliances:

Textual signs:

Other (describe):

Supervision (list):

10.3.1 Special Hazard Notification

This system does not have special suppression/predischARGE notification.

MNS systems DO NOT override notification appliances required to provide special suppression/predischARGE notification.

11. TWO-WAY EMERGENCY COMMUNICATION SYSTEMS

11.1 Telephone System

This system does not have a two-way telephone system.

Number of telephone jacks installed:

Number of warden stations installed:

Number of telephone handsets stored on site:

Type of telephone system installed: Electrically powered Sound powered

11.2 Two-Way Radio Communications Enhancement System

This system does not have a two-way radio communications enhancement system.

Percentage of area covered by two-way radio service: Critical areas: _____ % General building areas: _____ %

Amplification component locations:

Inbound signal strength: _____ dBm Outbound signal strength: _____ dBm

Donor antenna isolation is: _____ dB above the signal booster gain

Radio frequencies covered:

Radio system monitor panel location:

11. TWO-WAY EMERGENCY COMMUNICATION SYSTEMS *(continued)*

11.3 Area of Refuge (Area of Rescue Assistance) Emergency Communications Systems

This system does not have an area of refuge (area of rescue assistance) emergency communications system.

Number of stations: _____ Location of central control point: _____

Days and hours when central control point is attended: _____

Location of alternate control point: _____

Days and hours when alternate control point is attended: _____

11.4 Elevator Emergency Communications Systems

This system does not have an elevator emergency communications system.

Number of elevators with stations: _____ Location of central control point: _____

Days and hours when central control point is attended: _____

Location of alternate control point: _____

Days and hours when alternate control point is attended: _____

11.5 Other Two-Way Communication Systems

Describe: _____

12. CONTROL FUNCTIONS

This system activates the following control functions:

Hold-open door releasing devices Smoke management HVAC shutdown F/S dampers

Door unlocking Elevator recall Fuel source shutdown Extinguishing agent release

Elevator shunt trip Mass notification system override of fire alarm notification appliances

Other (specify): _____

12.1 Addressable Control Modules

This system does not have control modules.

Number of devices: 3

Other (specify): RTU shutdowns

13. SYSTEM POWER

13.1 Control Unit

13.1.1 Primary Power

Input voltage of control panel: 120vac Control panel amps: 2

Overcurrent protection: Type: Circuit breaker Amps: 20

Location (of primary supply panel board): in FACP

Disconnecting means location: electric rm panel 4 ckt #14

13.1.2 Engine-Driven Generator

This system does not have a generator.

Location of generator: _____

Location of fuel storage: _____ Type of fuel: _____

© 2015 National Fire Protection Association

13. SYSTEM POWER (continued)

13.1.3 Uninterruptible Power System

This system does not have a UPS.

Equipment powered by a UPS system:

Location of UPS system:

Calculated capacity of UPS batteries to drive the system components connected to it:

In standby mode (hours):

In alarm mode (minutes):

13.1.4 Batteries

Location: in RACP

Type: SEALED
AGM
DEEP-
CYCLE

Nominal voltage: 24vdc

Amp-hour rating: 12AH

Calculated capacity of batteries to drive the system:

In standby mode (hours): 24

In alarm mode (minutes): 10

Batteries are marked with date of manufacture Battery calculations are attached

13.2 In-Building Fire Emergency Voice Alarm Communication System or Mass Notification System

This system does not have an EVACS or MNS system.

13.2.1 Primary Power

Input voltage of EVACS or MNS panel:

EVACS or MNS panel amps:

Overcurrent protection: Type:

Amps:

Location (of primary supply panel board):

Disconnecting means location:

13.2.2 Engine-Driven Generator

This system does not have a generator.

Location of generator:

Location of fuel storage:

Type of fuel:

13.2.3 Uninterruptible Power System

This system does not have a UPS.

Equipment powered by a UPS system:

Location of UPS system:

Calculated capacity of UPS batteries to drive the system components connected to it:

In standby mode (hours):

In alarm mode (minutes):

13.2.4 Batteries

Location:

Type:

Nominal voltage:

Amp-hour rating:

Calculated capacity of batteries to drive the system:

In standby mode (hours):

In alarm mode (minutes):

Batteries are marked with date of manufacture Battery calculations are attached

13. SYSTEM POWER (continued)

13.3 Notification Appliance Power Extender Panels This system does not have power extender panels.

13.3.1 Primary Power

Input voltage of power extender panel(s): 120V AC Power extender panel amps: 3.2 AMPS/MAX

Overcurrent protection: Type: CIRCUIT BREAKER Amps: 20AMPS

Location of primary supply panel board: Production electric rm in panel MB1 sec 2 ckt#45

Disconnecting means location:

13.3.2 Engine-Driven Generator This system does not have a generator.

Location of generator:

Location of fuel storage: Type of fuel:

13.3.3 Uninterruptible Power System This system does not have a UPS.

Equipment powered by a UPS system:

Location of UPS system:

Calculated capacity of UPS batteries to drive the system components connected to it:

In standby mode (hours): In alarm mode (minutes):

13.3.4 Batteries

Location: IN BOOSTER Type: SEALED AGM DEEP-CYCLE Nominal voltage: 24V DC Amp-hour rating: 7.5AH

Calculated capacity of batteries to drive the system:

In standby mode (hours): 24 In alarm mode (minutes): 10

Batteries are marked with date of manufacture Battery calculations are attached

14. RECORD OF SYSTEM INSTALLATION

Fill out after all installation is complete and wiring has been checked for opens, shorts, ground faults, and improper branching, but before conducting operational acceptance tests.

This is a: New system Modification to an existing system Permit number:

The system has been installed in accordance with the following requirements: (Note any or all that apply.)

- NFPA 72, Edition:
- NFPA 70, National Electrical Code, Article 760, Edition:
- Manufacturer's published instructions

Other (specify):

System deviations from referenced NFPA standards:

Signed: [Signature] Printed name: JASON COOK Date: 4/9/2015
Organization: BK SYSTEMS INC Title: TECHNICAL REPRESENTATIVE Phone: 603-647-8775

15. RECORD OF SYSTEM OPERATIONAL ACCEPTANCE TEST

New system

All operational features and functions of this system were tested by, or in the presence of, the signer shown below, on the date shown below, and were found to be operating properly in accordance with the requirements for the following:

Modifications to an existing system

All newly modified operational features and functions of the system were tested by, or in the presence of, the signer shown below, on the date shown below, and were found to be operating properly in accordance with the requirements of the following:


NFPA 72, Edition:

NFPA 70, National Electrical Code, Article 760, Edition:

Manufacturer's published instructions

Other (specify):

Individual device testing documentation [Inspection and Testing Form (Figure 14.6.2.4) is attached]

Signed:  Printed name: JASON COOK Date: 4/9/2015
Organization: BK SYSTEMS INC Title: TECHNICAL REPRESENTATIVE Phone: 603-647-8775

16. CERTIFICATIONS AND APPROVALS

16.1 System Installation Contractor:

This system, as specified herein, has been installed and tested according to all NFPA standards cited herein.

Signed: _____ Printed name: Jason Aube Date: 4/9/2015
Organization: TRT Electric Title: Electrician Phone: 207-400-0630

16.2 System Service Contractor:

The undersigned has a service contract for this system in effect as of the date shown below.

Signed: _____ Printed name: _____ Date: _____
Organization: _____ Title: _____ Phone: _____

16.3 Supervising Station:

This system, as specified herein, will be monitored according to all NFPA standards cited herein.

Signed: _____ Printed name: _____ Date: _____
Organization: Cunningham Security Title: _____ Phone: 1-800-210-0257

16. CERTIFICATIONS AND APPROVALS (continued)

16.4 Property or Owner Representative:

I accept this system as having been installed and tested to its specifications and all NFPA standards cited herein.

Signed: _____ Printed name: _____ Date: _____
Organization: _____ Title: _____ Phone: _____

16.5 Authority Having Jurisdiction:

I have witnessed a satisfactory acceptance test of this system and find it to be installed and operating properly in accordance with its approved plans and specifications, with its approved sequence of operations, and with all NFPA standards cited herein.

Signed: _____ Printed name: _____ Date: _____
Organization: Portland Fire Dept. Title: _____ Phone: _____

FIRE ALARM AND EMERGENCY COMMUNICATION SYSTEM INSPECTION AND TESTING FORM

*To be completed by the system inspector or tester at the time of the inspection or test.
It shall be permitted to modify this form as needed to provide a more complete and/or clear record.
Insert N/A in all unused lines.
Attach additional sheets, data, or calculations as necessary to provide a complete record.*

Date of this inspection or test: 4/9/2015

Time of inspection or test: 11am

1. PROPERTY INFORMATION

Name of property: Allagash Brewing

Address: 50 Industrial Way Portland ME

Description of property: Allagash Brewery and retail store

Occupancy type: Commercial

Name of property representative:

Address:

Phone:

Fax:

E-mail:

Authority having jurisdiction over this property: Portland Fire Dept.

Phone: 207-874-8576

Fax:

E-mail:

2. INSTALLATION, SERVICE, AND TESTING CONTRACTOR INFORMATION

Service and/or testing organization for this equipment: BK Systems Inc

Address: 4 Cote Ave Goffstown NH

Phone: 603-647-8775

Fax:

E-mail:

Service technician or tester: JASON COOK

Qualifications of technician or tester: FACTORY TRAINED NOTIFIER TECHNICIAN, NICET II #128113

A contract for test and inspection in accordance with NFPA standards is in effect as of:

The contract expires:

Contract number:

Frequency of tests and inspections:

Monitoring organization for this equipment: Cunningham Security

Address:

Phone: 1-800-210-0257

Fax:

E-mail:

Entity to which alarms are retransmitted:

Phone:

3. TYPE OF SYSTEM OR SERVICE

Fire alarm system (nonvoice)

Fire alarm with in-building fire emergency voice alarm communication system (EVACS)

Mass notification system (MNS)

Combination system, with the following components:

Fire alarm

EVACS

MNS

Two-way, in-building, emergency communication system

Other (specify):

NFPA 72-2009, Section 7.5.2.2 (p. 1 of 12)

3. TYPE OF SYSTEM OR SERVICE (continued)

NFPA 72 edition: 2010

Additional description of system(s):

3.1 Control Unit

Manufacturer: Notifier

Model number: NFW2-100

3.2 Mass Notification System

This system does not incorporate an MNS.

3.2.1 System Type:

In-building MNS combination

In-building MNS stand-alone Wide-area MNS Distributed recipient MNS

Other (specify):

3.2.2 System Features:

Combination fire alarm MNS MNS ACU only Wide-area MNS to regional national alerting interface

Local operating console (LOC) Direct recipient MNS (DRMNS) Wide-area MNS to DRMNS interface

Wide-area MNS to high-power speaker array (HPSA) interface In-building MNS to wide-area MNS interface

Other (specify):

3.3 System Documentation

An owner's manual, a copy of the manufacturer's instructions, a written sequence of operation, and a copy of the record record drawings are stored on site. Location: at FACP

3.4 System Software

This system does not have alterable site-specific software.

Software revision number:

Software last updated on:

A copy of the site-specific software is stored on site. Location:

4. SYSTEM POWER

4.1 Control Unit

4.1.1 Primary Power

Input voltage of control panel: 120VAC

Control panel amps: 2

4.1.2 Engine-Driven Generator

This system does not have a generator.

Location of generator:

Location of fuel storage:

Type of fuel:

4.1.3 Uninterruptible Power System

This system does not have a UPS.

Equipment powered by a UPS system:

Location of UPS system:

Calculated capacity of UPS batteries to drive the system components connected to it:

In standby mode (hours):

In alarm mode (minutes):

4. SYSTEM POWER (continued)

4.1.4 Batteries

Location: In FACP Type: SEALED
AGM DEEP-
CYCLE Nominal voltage: 24vdc Amp-hour rating: 12AH

Calculated capacity of batteries to drive the system:

In standby mode (hours): 24 In alarm mode (minutes): 10

Batteries are marked with date of manufacture.

4.2 In-Building Fire Emergency Voice Alarm Communication System or Mass Notification System

This system does not have an EVACS or MNS.

4.2.1 Primary Power

Input voltage of EVACS or MNS panel: EVACS or MNS panel amps:

4.2.2 Engine-Driven Generator

This system does not have a generator.

Location of generator:

Location of fuel storage:

Type of fuel:

4.2.3 Uninterruptible Power System

This system does not have a UPS.

Equipment powered by a UPS system:

Location of UPS system:

Calculated capacity of UPS batteries to drive the system components connected to it:

In standby mode (hours): In alarm mode (minutes):

4.2.4 Batteries

Location: Type: Nominal voltage: Amp-hour rating:

Calculated capacity of batteries to drive the system:

In standby mode (hours): In alarm mode (minutes):

Batteries are marked with date of manufacture.

4.3 Notification Appliance Power Extender Panels

This system does not have power extender panels.

4.3.1 Primary Power

Input voltage of power extender panel(s): 120V AC Power extender panel amps: 3.2 AMPS/MAX

4.3.2 Engine-Driven Generator

This system does not have a generator.

Location of generator:

Location of fuel storage:

Type of fuel:

4.3.3 Uninterruptible Power System

This system does not have a UPS.

Equipment powered by a UPS system:

Location of UPS system:

Calculated capacity of UPS batteries to drive the system components connected to it:

In standby mode (hours):

In alarm mode (minutes):

4. SYSTEM POWER (continued)

4.3.4 Batteries

Location: in Booster Type: SEALED AGM DEEP-CYCLE Nominal voltage: 24V DC Amp-hour rating: 7.5AH

Calculated capacity of batteries to drive the system:

In standby mode (hours): 24

In alarm mode (minutes): 10

[X] Batteries are marked with date of manufacture.

5. ANNUNCIATORS

[] This system does not have annunciators.

5.1 Location and Description of Annunciators

Annunciator 1: Retail left entrance FDU-80

Annunciator 2:

Annunciator 3:

6. NOTIFICATIONS MADE PRIOR TO TESTING

Monitoring organization Contact: Cunningham Security Time:
Building management Contact: Time:
Building occupants Contact: Time:
Authority having jurisdiction Contact: Portland Fire Dept. Time:
Other, if required Contact: Time:

7. TESTING RESULTS

7.1 Control Unit and Related Equipment

Table with 4 columns: Description, Visual Inspection, Functional Test, Comments. Rows include Control unit, Lamps/LEDs/LCDs, Fuses, Trouble signals, Disconnect switches, Ground-fault monitoring, Supervision, Local annunciator, Remote annunciators.

Power extend panels	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Isolation modules	<input type="checkbox"/>	<input type="checkbox"/>
Other (specify)	<input type="checkbox"/>	<input type="checkbox"/>

7. TESTING RESULTS (continued)

7.2 Control Unit Power Supplies

Description	Visual Inspection	Functional Test	Comments
120-volt power	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Generator or UPS	<input type="checkbox"/>	<input type="checkbox"/>	
Battery condition	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Load voltage	<input type="checkbox"/>	<input type="checkbox"/>	
Discharge test	<input type="checkbox"/>	<input type="checkbox"/>	
Charger test	<input type="checkbox"/>	<input type="checkbox"/>	
Other (specify)	<input type="checkbox"/>	<input type="checkbox"/>	

7.3 In-Building Fire Emergency Voice Alarm Communications Equipment

Description	Visual Inspection	Functional Test	Comments
Control unit	<input type="checkbox"/>	<input type="checkbox"/>	
Lamps LEDs LCDs	<input type="checkbox"/>	<input type="checkbox"/>	
Fuses	<input type="checkbox"/>	<input type="checkbox"/>	
Primary power supply	<input type="checkbox"/>	<input type="checkbox"/>	
Secondary power supply	<input type="checkbox"/>	<input type="checkbox"/>	
Trouble signals	<input type="checkbox"/>	<input type="checkbox"/>	
Disconnect switches	<input type="checkbox"/>	<input type="checkbox"/>	
Ground-fault monitoring	<input type="checkbox"/>	<input type="checkbox"/>	
Panel supervision	<input type="checkbox"/>	<input type="checkbox"/>	
System performance	<input type="checkbox"/>	<input type="checkbox"/>	
Sound pressure levels	<input type="checkbox"/>	<input type="checkbox"/>	
Occupied <input type="checkbox"/> Yes <input type="checkbox"/> No			
Ambient dBA			
Alarm dBA			
(attach report with locations, values, and weather conditions)			
System intelligibility	<input type="checkbox"/>	<input type="checkbox"/>	
<input type="checkbox"/> CSI <input type="checkbox"/> STI			
(attach report with locations, values, and weather conditions)			
Other (specify)	<input type="checkbox"/>	<input type="checkbox"/>	

7. TESTING RESULTS (continued)

7.4 Notification Appliance Power Extender Panels

Description	Visual Inspection	Functional Test	Comments
Lamps LEDs LCDs	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Fuses	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Primary power supply	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Secondary power supply	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Trouble signals	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Ground-fault monitoring	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Panel supervision	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Other (specify)	<input type="checkbox"/>	<input type="checkbox"/>	

7.5 Mass Notification Equipment

Description	Visual Inspection	Functional Test	Comments
Functional test	<input type="checkbox"/>	<input type="checkbox"/>	
Reset power down test	<input type="checkbox"/>	<input type="checkbox"/>	
Fuses	<input type="checkbox"/>	<input type="checkbox"/>	
Primary power supply	<input type="checkbox"/>	<input type="checkbox"/>	
UPS power test	<input type="checkbox"/>	<input type="checkbox"/>	
Trouble signals	<input type="checkbox"/>	<input type="checkbox"/>	
Disconnect switches	<input type="checkbox"/>	<input type="checkbox"/>	
Ground-fault monitoring	<input type="checkbox"/>	<input type="checkbox"/>	
CCU security mechanism	<input type="checkbox"/>	<input type="checkbox"/>	
Prerecorded message content	<input type="checkbox"/>	<input type="checkbox"/>	
Prerecorded message activation	<input type="checkbox"/>	<input type="checkbox"/>	
Software backup performed	<input type="checkbox"/>	<input type="checkbox"/>	
Test backup software	<input type="checkbox"/>	<input type="checkbox"/>	
Fire alarm to MNS interface	<input type="checkbox"/>	<input type="checkbox"/>	
MNS to fire alarm interface	<input type="checkbox"/>	<input type="checkbox"/>	
In-building MNS to wide-area MNS	<input type="checkbox"/>	<input type="checkbox"/>	

7. TESTING RESULTS (continued)

7.5 Mass Notification Equipment (continued)

Description	Visual Inspection	Functional Test	Comments
MNS to direct recipient MNS	<input type="checkbox"/>	<input type="checkbox"/>	
Sound pressure levels Occupied <input type="checkbox"/> Yes <input type="checkbox"/> No Ambient dBA Alarm dBA (attach report with locations, values, and weather conditions)	<input type="checkbox"/>	<input type="checkbox"/>	
System intelligibility <input type="checkbox"/> CSI <input type="checkbox"/> SII (attach report with locations, values, and weather conditions)	<input type="checkbox"/>	<input type="checkbox"/>	
Other (specify)	<input type="checkbox"/>	<input type="checkbox"/>	

7.6 Two-Way Communications Equipment

Description	Visual Inspection	Functional Test	Comments
Phone handsets	<input type="checkbox"/>	<input type="checkbox"/>	
Phone jacks	<input type="checkbox"/>	<input type="checkbox"/>	
Off-hook indicator	<input type="checkbox"/>	<input type="checkbox"/>	
Call-in signal	<input type="checkbox"/>	<input type="checkbox"/>	
System performance	<input type="checkbox"/>	<input type="checkbox"/>	
System audibility	<input type="checkbox"/>	<input type="checkbox"/>	
System intelligibility	<input type="checkbox"/>	<input type="checkbox"/>	
Radio communications enhancement system	<input type="checkbox"/>	<input type="checkbox"/>	
Area of refuge communication system	<input type="checkbox"/>	<input type="checkbox"/>	
Elevator emergency communications system	<input type="checkbox"/>	<input type="checkbox"/>	
Other (specify)	<input type="checkbox"/>	<input type="checkbox"/>	

7. TESTING RESULTS (continued)

7.7 Combination Systems

Description	Visual Inspection	Functional Test	Comments
Fire extinguishing monitoring devices system	<input type="checkbox"/>	<input type="checkbox"/>	
Carbon monoxide detector system	<input type="checkbox"/>	<input type="checkbox"/>	
Combination fire security system	<input type="checkbox"/>	<input type="checkbox"/>	
Other (specify)	<input type="checkbox"/>	<input type="checkbox"/>	

7.8 Special Hazard Systems

Description (specify)	Visual Inspection	Functional Test	Comments
	<input type="checkbox"/>	<input type="checkbox"/>	
	<input type="checkbox"/>	<input type="checkbox"/>	
	<input type="checkbox"/>	<input type="checkbox"/>	

7.9 Emergency Communications System

- Visual
- Functional
- Simulated operation
- Ensure pre-discharge notification appliances of special hazard systems are not overridden by the MNS
See MPT 7.24.4.1-1.

7.10 Monitored Systems

Description (specify)	Visual Inspection	Functional Test	Comments
Engine-driven generator	<input type="checkbox"/>	<input type="checkbox"/>	
Fire pump	<input type="checkbox"/>	<input type="checkbox"/>	
Special suppression systems	<input type="checkbox"/>	<input type="checkbox"/>	
Other (specify)	<input type="checkbox"/>	<input type="checkbox"/>	

7. TESTING RESULTS (continued)

7.11 Auxiliary Functions

Description	Visual Inspection	Functional Test	Comments
Door-releasing devices	<input type="checkbox"/>	<input type="checkbox"/>	
Fan shutdown	<input type="checkbox"/>	<input type="checkbox"/>	
Smoke management/smoke control	<input type="checkbox"/>	<input type="checkbox"/>	
Smoke damper operation	<input type="checkbox"/>	<input type="checkbox"/>	
Smoke shutter release	<input type="checkbox"/>	<input type="checkbox"/>	
Door unlocking	<input type="checkbox"/>	<input type="checkbox"/>	
Elevator recall	<input type="checkbox"/>	<input type="checkbox"/>	
Elevator shunt trip	<input type="checkbox"/>	<input type="checkbox"/>	
MNS override of FA signals	<input type="checkbox"/>	<input type="checkbox"/>	
Other (specify)	<input type="checkbox"/>	<input type="checkbox"/>	

7.12 Alarm Initiating Device

Device test results sheet attached listing all devices tested and the results of the testing

7.13 Supervisory Alarm Initiating Device

Device test results sheet attached listing all devices tested and the results of the testing

7.14 Alarm Notification Appliances

Appliance test results sheet attached listing all appliances tested and the results of the testing

7.15 Supervisory Station Monitoring

Description	Yes	No	Time	Comments
Alarm signal	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	12pm	
Alarm restoration	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	12pm	
Trouble signal	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	12pm	
Trouble restoration	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	12pm	
Supervisory signal	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	12pm	
Supervisory restoration	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	12pm	

8. NOTIFICATIONS THAT TESTING IS COMPLETE

Monitoring organization	Contact: Cunningham Security	Time: 12pm
Building management	Contact:	Time:
Building occupants	Contact:	Time:
Authority having jurisdiction	Contact: Portland Fire Dept.	Time: 12pm
Other, if required	Contact:	Time:


9. SYSTEM RESTORED TO NORMAL OPERATION

Date: 4-9-2015 Time: 12pm

10. CERTIFICATION

10.1 Inspector Certification:

This system, as specified herein, has been inspected and tested according to all NFPA standards cited herein.

Signed:  Printed name: JASON COOK Date: 4/9/2015
Organization: BK SYSTEMS INC Title: TECHNICAL REPRESENTATIVE Phone: 603-647-8775

10.2 Acceptance by Owner or Owner's Representative:

The undersigned has a service contract for this system in effect as of the date shown below.

Signed: Printed name: Date:
Organization: Title: Phone:

