



VERTICAL GRANITE CURB
NOT TO SCALE

- NOTES:**
1. EXCAVATION INCIDENTAL TO COST OF CURB TO BE COMPACTED TO A FIRM EVEN SURFACE PRIOR TO SETTING OF CURB
 2. SUBBASE SHALL BE COMPACTED TO A FIRM EVEN SURFACE PRIOR TO SETTING OF CURB




TYP. PAVED PARKING LOT SECTION
NOT TO SCALE

- NOTES:**
1. COMPACT GRAVEL SUBBASE, BASE COURSE TO 92% OF MAXIMUM DENSITY USING HEAVY ROLLER COMPACTION.
 2. CONTRACTOR SHALL SET GRADE STAKES MARKING SUBBASE AND FINISH GRADE ELEVATIONS FOR CONSTRUCTION REFERENCE.
 3. CONTRACTOR MAY REPLACE BITUMINOUS PAVING SECTION WITH TWO (2) 1-1/2" LIFTS OF 12.5mm SUPERPAVE MIX. SUBMIT PAVEMENT MIX DESIGN PRIOR TO CONSTRUCTION.




BLOCK RETAINING WALL
NOT TO SCALE


- NOTES:**
1. CONSTRUCT WALL AND FILL MATERIALS ON ENGINEER APPROVED, UNDISTURBED NATIVE SOILS. ANY REQUIRED BACKFILL DUE TO UNSUITABLE MATERIALS OR OVER EXCAVATIONS SHALL BE REPLACED WITH COMPACTED GRAVEL TO 95% MODIFIED PROCTOR DENSITY.
 2. PLACE GRANULAR BACKFILL IN MAX. 8" COMPACTED LIFTS TO MIN. OF 95% MODIFIED PROCTOR DENSITY. MOISTURE ADJUST BACKFILL TO ACHIEVE SPECIFIED DENSITY.
 3. PLACE CRUSHED STONE BACKFILL IN MAX 12" LIFTS AND CONSOLIDATE TO MAX 100% DRY-RODDED UNIT WEIGHT.
- PLACE BOTTOM COURSE OVER A CONTINUOUS MAT OF 3/4" CRUSHED STONE CONSOLIDATED WITH A VIBRATORY COMPACTOR, 9" DEEP BY 60" WIDE (MIN.). CONSTRUCT BASE LEVEL OR WITH BACK BATTER PER WALL BASE DETAIL ON R11. PLACE STONE ON UNDISTURBED NATIVE SOILS WITH A LAYER OF FILTER FABRIC (EQUAL TO MIRAFI 140N) @ BASE AND SIDES. DO NOT PLACE FILTER FABRIC BETWEEN STONE AND BLOCK.




TYPICAL TIPDOWN CURB INSTALLATION
NOT TO SCALE



BITUMINOUS SIDEWALK
NOT TO SCALE



TYPICAL TRENCH SECTION
NOT TO SCALE



DESIGNED	CHECKED
RLM	RLM
B RLM 04/13/18 SUBMIT LEVEL II SITE PLAN APPLICATION TO CITY	
A RLM 03/16/18 ISSUED FOR CLIENT REVIEW	
REV. BY:	DATE:
	STATUS:
THIS PLAN SHALL NOT BE MODIFIED WITHOUT WRITTEN PERMISSION FROM SEBAGO TECHNICS, INC. ANY ALTERATIONS AUTHORIZED OR OTHERWISE, SHALL BE AT THE USER'S SOLE RISK AND WITHOUT LIABILITY TO SEBAGO TECHNICS, INC.	



DETAILS
OF:
2018 PACKAGING EXPANSION
ALLAGASH BREWING COMPANY 50 INDUSTRIAL WAY
PORTLAND, MAINE
FOR:
50 INDUSTRIAL WAY, LLC
50 INDUSTRIAL WAY
PORTLAND, MAINE 04103

PROJECT NO.	SCALE
02249	N.T.S.
SHEET C.6.2	

02249b.dwg, 1486-D-2