## City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No:	Date Applied For:	CBL:
2013-00630	04/01/2013	326 B009001

<b>Location of Construction:</b>	Owner Name:	Owner Address:	Phone:		
50 INDUSTRIAL WAY	50 INDUSTRIAL WAY LLC	50 INDUSTRIAL WAY			
Business Name:	Contractor Name:	Contractor Address:	Phone		
Allagash Brewing	Landry/French Construction Corp	68 Mussey Rd Scarborough	(207) 730-5566		
Lessee/Buyer's Name	Phone:	Permit Type:			
Sean Diffley	6178995935	Amendment to Commercial			

Proposed Use:

Same: Industrial Brewing

Amend permit #201248397 interior layout to office/ retail space/boiler room

Dept: Zoning Status: Approved w/Conditions Reviewer: Marge Schmuckal Approval Date: 04/24/2013

Note: Ok to Issue: ✓

1) All conditions on the original approval are still in force.

Dept: Building Status: Approved w/Conditions Reviewer: Jeanie Bourke Approval Date: 05/08/2013

Note: Ok to Issue: ✓

- 1) Equipment and walk in cooler shall be installed in compliance with the manufacturer's specifications and the UL listing.
- 2) All previous conditions associated with BP #201248397 remain in effect
- 3) Permit approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.

 Dept:
 Fire
 Status:
 Approved w/Conditions
 Reviewer:
 Ben Wallace Jr
 Approval Date:
 05/13/2013

 Note:
 Ok to Issue:
 ✓

- 1) Notice: The first scheduled final inspection fee is at no charge. Additional inspections shall be billed at \$75 for each inspector.
- 2) \*\*The fire alarm system design shall be evaluated for the renovated areas by an NICET IV certified interior fire alarm designer or a licensed engineer for compliance with the code. A compliance letter is required prior to the final inspection.\*\*

  \*\*A current inspection sticker from an approved fire alarm inspection company is required prior to the final inspection.\*\*
- 3) Through-penetrations and membrane penetrations in fire walls, fire barrier walls, and fire resistance rated horizontal assemblies shall be protected by firestop systems or devices in conformance with NFPA 101:8.3.5 (ASTM E 814 or ANSI/UL 1479). Providing firestop labels at each firestop system or device and an onsite manual containing the detail for each firestop system or device used for the project will streamline final inspection approvals.
- 4) Fire walls, fire barriers, fire partitions, smoke barriers and smoke partitions or any other wall required to have protected openings or penetrations shall be effectively and permanently identified with signs or stenciling in accessible concealed floor, floor-ceiling or attic spaces at intervals not exceeding 30 feet with lettering not less than 0.5 inches in height.
- 5) Any cutting and welding done will require a Hot Work Permit from Fire Department.
- 6) Emergency lights and exit signs are required. Emergency lights and exit signs are required to be labeled in relation to the panel and circuit and on the same circuit as the lighting for the area they serve.
- 7) All means of egress to remain accessible at all times.
- 8) Fire extinguishers are required per NFPA 1.
- 9) A separate Suppression System Permit is required for all new suppression systems, including standpipe systems, and sprinkler work effecting more than 20 heads. This review does not include approval of system design or installation.
- 10 A separate Fire Alarm Permit is required for new systems; or for work effecting more than 5 fire alarm devices; or replacement of a fire alarm panel with a different model. This review does not include approval of fire alarm system design or installation.
- 11 Construction or installation shall comply with City Code Chapter 10.