

From: David Margolis-Pineo
To: Jean Fraser
CC: Barbara Barhydt; Benjamin Pearson; Helen Donaldson; Jeff Levine; Joh...
Date: 8/21/2015 9:32 AM
Subject: Wastewater Sewer Capacity Approval for 81 Industrial Way

August 21, 2015
Mr. Drew Sigfridson
One Canal Plaza
Portland, ME

RE: The Capacity to Handle Wastewater Flows from 81 Industrial Way

Dear Mr. Sigfridson:

The Department of Public Services which includes the Water Resource Division has reviewed and determined that the downstream sewers from 81 Industrial Way has the capacity to convey the estimated 500 gallons per day of wastewater which will be generated from this facility.

If the City can be of further assistance, please call 874-8850 or 400-6695.

Sincerely,

CITY OF PORTLAND

David Margolis-

Pineo

David Margolis-Pineo
Deputy City Engineer

Anticipated Wastewater Flows from the Proposed Office Complex:
25 Employees @ 20 gallons per person per day = 500 GPD

CC: Jeffrey Levine, Director, Department of Planning and Urban Development, City of Portland
Barbara Barhydt, Development Review Services Mgr., Dep't. of Planning and Urban
Development, City of Portland
Nell Donaldson, Department of Planning and Urban Development, City of Portland

Shukria Wiar, Planner, Department of Planning and Urban Development, City of Portland
Nancy Gallinaro, Water Resources Manager
Benjamin N. Pearson, E.I., Industrial Pretreatment Coordinator, City of Portland
John Emerson, Wastewater Coordinator, City of Portland