

... Fire Protection by Computer Design

CORNELIUSEN CONSULTING
11 CRICKET LANE
LITTLETON
MA 01460
781-248-7497

Job Name : 1844 Forest Ave Portlane Maine- 1st floor
Drawing :
Location : 1844 Forest Ave Portlane Maine- 1st floor
Remote Area : 1st FLOOR
Contract :
Data File : 1844 FOREST AVE- PORTLAND MAINE-1ST FLOOR.WXF

HYDRAULIC CALCULATIONS
for

Project name: z-dance
Location: 1844 Forest Ave Portlane Maine- 1st floor
Drawing no:
Date:

Design

Remote area number: 1st FLOOR
Remote area location: 1st FLOOR
Occupancy classification: OH2
Density: .15 - Gpm/SqFt
Area of application: - SqFt
Coverage per sprinkler: 200 - SqFt
Type of sprinklers calculated: SIDEWALL EXTENDED COVERAGE
No. of sprinklers calculated: 8
In-rack demand: - GPM
Hose streams: 0 - GPM
Total water required (including hose streams): 353.558 - GPM @ 57.4087 - Psi
Type of system:
Volume of dry or preaction system: - Gal

Water supply information

Date: 2012
Location: PROT LAND WATER DEPARTMENT
Source:

Name of contractor: CORNELIUSEN CONSULTING
Address: 11 CRICKET LANE / LITTLETON / MA 01460
Phone number: 781-248-7497
Name of designer:
Authority having jurisdiction:
Notes: (Include peaking information or gridded systems here.)

Water Supply Curve (C)


CORNELIUSEN CONSULTING
 1844 Forest Ave Portland Maine- 1st floor

City Water Supply:

C1 - Static Pressure : 68
 C2 - Residual Pressure: 66
 C2 - Residual Flow : 1087

Demand:

D1 - Elevation : 7.796
 D2 - System Flow : 353.558
 D2 - System Pressure : 57.914
 Hose (Demand) : 100
 D3 - System Demand : 453.558
 Safety Margin : 9.689



Flow Summary - NFPA 2007

CORNELIUSEN CONSULTING
1844 Forest Ave Portlane Maine- 1st floor

Page 3
Date

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
SOR	68.0	66	1087.0	67.603	453.56	57.914

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
500	18.0	8	30.0	43.82	
501	18.0	8	30.07	43.87	
502	18.0	8	30.33	44.06	
503	18.0	8	30.88	44.46	
504	0.0		39.85		
510	18.0	8	30.39	44.1	
511	18.0	8	30.46	44.16	
512	18.0	8	30.73	44.35	
513	18.0	8	31.29	44.75	
514	0.0		40.27		
520	0.0		41.96		
601	4.0		44.87		
603	4.0		45.16		
604	4.0		46.81		
605	0.0		49.65		
606	0.0		52.68		
607	0.0		56.55	100.0	
SOR	0.0		57.91		

Final Calculations - Hazen-Williams - 2007

CORNELIUSEN CONSULTING
1844 Forest Ave Portlane Maine- 1st floor

Page 4
Date


Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
500 to 501	18 18	8.00	43.82 43.82	2.5 2.635		0.0 0.0	11.500 0.0	120 0.0063	30.000 0.0			
										Vel =	2.58	
501 to 502	18 18	8.00	43.87 87.69	2.5 2.635		0.0 0.0	11.500 0.0	120 0.0226	30.072 0.0			
										Vel =	5.16	
502 to 503	18 18	8.00	44.06 131.75	2.5 2.635		0.0 0.0	11.500 0.0	120 0.0479	30.332 0.0			
										Vel =	7.75	
503 to 504	18 0	8.00	44.46 176.21	2.5 2.635	1E	8.237 0.0	6.000 8.237	120 0.0822	30.883 7.796			
										Vel =	10.37	
504 to 520	0 0		0.0 176.21	3 3.26	3E 1T	28.223 20.159	24.000 48.382	120 0.0291	39.849 0.0			
										Vel =	6.77	
520			0.0 176.21						41.958		K Factor =	27.20
510 to 511	18 18	8.00	44.10 44.1	2.5 2.635		0.0 0.0	11.500 0.0	120 0.0063	30.392 0.0			
										Vel =	2.59	
511 to 512	18 18	8.00	44.16 88.26	2.5 2.635		0.0 0.0	11.500 0.0	120 0.0229	30.465 0.0			
										Vel =	5.19	
512 to 513	18 18	8.00	44.34 132.6	2.5 2.635		0.0 0.0	11.500 0.0	120 0.0485	30.728 0.0			
										Vel =	7.80	
513 to 514	18 0	8.00	44.75 177.35	2.5 2.635	1E	8.237 0.0	6.000 8.237	120 0.0832	31.286 7.796			
										Vel =	10.43	
514 to 520	0 0		0.0 177.35	3 3.26	3E 1T	28.223 20.159	9.000 48.382	120 0.0295	40.266 0.0			
										Vel =	6.82	
520			0.0 177.35						41.958		K Factor =	27.38
520 to 601	0 4		353.56 353.56	3 3.26	2E 1T	18.815 20.159	5.000 38.974	120 0.1057	41.958 -1.732			
										Vel =	13.59	
601 to 603	4 4		0.0 353.56	4 4.26		0.0 0.0	10.000 0.0	120 0.0287	44.872 0.0			
										Vel =	7.96	
603 to 604	4 4		0.0 353.56	4 4.26	2E 1T	26.334 26.334	5.000 52.668	120 0.0287	45.159 0.0			
										Vel =	7.96	
604 to 605	4 0		0.0 353.56	4 4.26	2E	26.334 0.0	12.000 26.334	120 0.0287	46.815 1.732			
										Vel =	7.96	
605 to 606	0 0		0.0 353.56	4 4.26	1Avc 3E 1T	27.651 39.501 26.334	12.000 93.486 105.486	120 0.0287	49.648 0.0			
										Vel =	7.96	

Final Calculations - Hazen-Williams - 2007

CORNELIUSEN CONSULTING
 1844 Forest Ave Portlane Maine- 1st floor

Page 5
 Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
606 to 607	0 0		0.0 353.56	4 4.26	1Zac	0.0	12.000 0.0	120 0.0287	52.677 3.524		* Fixed loss = 3.524 Vel = 7.96	
607 to SOR	0 0	H100	100.00 453.56	6 6.065	2E 1B 1T	28.0 10.0 30.0	100.000 68.000 168.000	120 0.0081	56.545 0.0 1.369		Vel = 5.04	
SOR			0.0 453.56						57.914		K Factor = 59.60	



... Fire Protection by Computer Design

CORNELIUSEN CONSULTING
11 CRICKET LANE
LITTLETON
MA 01460
781-248-7497

Job Name : 1844 Forest Ave- Portland Maine- 2ND FLOOR
Drawing :
Location : 1844 Forest Ave- Portland Maine- 2ND FLOOR
Remote Area : 2ND FLOOR
Contract :
Data File : 1844 FOREST AVE- PORTLAND MAINE-2ND FLOOR.WXF

Water Supply Curve (C)


CORNELIUSEN CONSULTING
 1844 Forest Ave- Portland Maine- 2ND FLOOR

City Water Supply:

C1 - Static Pressure : 68
 C2 - Residual Pressure: 66
 C2 - Residual Flow : 1087

Demand:

D1 - Elevation : 12.127
 D2 - System Flow : 530.092
 D2 - System Pressure : 56.448
 Hose (Demand) : 100
 D3 - System Demand : 630.092
 Safety Margin : 10.822



Flow Summary - NFPA 2007

CORNELIUSEN CONSULTING
 1844 Forest Ave- Portland Maine- 2ND FLOOR

Page 2
 Date

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
SOR	68.0	66	1087.0	67.271	630.09	56.448

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
1	24.0	5.6	7.55	15.38	
2	20.0	5.6	9.92	17.64	
11	24.0	5.6	7.6	15.44	
12	20.0	5.6	9.97	17.69	
21	24.0	5.6	7.78	15.62	
22	20.0	5.6	10.17	17.86	
31	24.0	5.6	8.18	16.01	
32	20.0	5.6	10.6	18.23	
41	24.0	5.6	8.86	16.67	
42	20.0	5.6	11.33	18.85	
51	24.0	5.6	9.91	17.63	
52	20.0	5.6	12.47	19.77	
200	28.0	5.6	7.0	14.82	
201	24.0	5.6	9.67	17.41	
202	20.0	5.6	14.07	21.01	
211	28.0	5.6	7.01	14.83	
212	24.0	5.6	9.68	17.43	
213	20.0	5.6	14.09	21.02	
221	28.0	5.6	7.07	14.89	
222	24.0	5.6	9.74	17.48	
224	20.0	5.6	14.17	21.08	
231	28.0	5.6	7.17	15.0	
232	24.0	5.6	9.86	17.59	
233	20.0	5.6	14.32	21.19	
241	28.0	5.6	7.36	15.19	
242	24.0	5.6	10.07	17.77	
243	20.0	5.6	14.59	21.39	
251	28.0	5.6	7.64	15.48	
252	24.0	5.6	10.39	18.05	
253	20.0	5.6	15.0	21.69	
100	20.0		14.12		
101	20.0		14.19		
102	20.0		14.48		
103	20.0		15.08		
104	20.0		16.13		
105	20.0		17.75		
106	20.0		22.73		
300	20.0		17.32		
301	20.0		17.34		
302	20.0		17.43		
303	20.0		17.63		
304	20.0		17.96		

Flow Summary - NFPA 2007

CORNELIUSEN CONSULTING
1844 Forest Ave- Portland Maine- 2ND FLOOR

Page 3
Date

NODE ANALYSIS (cont.)

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
305	20.0		18.47		
306	20.0		19.9		
400	14.0		28.57		
601	4.0		33.27		
603	4.0		33.87		
604	4.0		37.38		
605	0.0		41.44		
606	0.0		47.84		
607	0.0		53.93	100.0	
SOR	0.0		56.45		

Final Calculations - Hazen-Williams - 2007

CORNELIUSEN CONSULTING
1844 Forest Ave- Portland Maine- 2ND FLOOR

Page 4
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
1 to 2	24 20	5.60	15.38	1		0.0	8.000	120	7.547			
						0.0	0.0		1.732			
			15.38	1.049		0.0	8.000	0.0801	0.641	Vel =	5.71	
2 to 100	20 20	5.60	17.64	1	2E 1T	4.0 5.0	3.750 9.000	120	9.920			
						0.0	12.750	0.3290	0.0			
			33.02	1.049					4.195	Vel =	12.26	
			0.0									
100			33.02						14.115	K Factor =	8.79	
11 to 12	24 20	5.60	15.44	1		0.0	8.000	120	7.598			
						0.0	0.0		1.732			
			15.44	1.049		0.0	8.000	0.0806	0.645	Vel =	5.73	
12 to 101	20 20	5.60	17.68	1	2E 1T	4.0 5.0	3.750 9.000	120	9.975			
						0.0	12.750	0.3309	0.0			
			33.12	1.049					4.219	Vel =	12.30	
			0.0									
101			33.12						14.194	K Factor =	8.79	
21 to 22	24 20	5.60	15.62	1		0.0	8.000	120	7.782			
						0.0	0.0		1.732			
			15.62	1.049		0.0	8.000	0.0825	0.660	Vel =	5.80	
22 to 102	20 20	5.60	17.86	1	2E 1T	4.0 5.0	3.750 9.000	120	10.174			
						0.0	12.750	0.3376	0.0			
			33.48	1.049					4.304	Vel =	12.43	
			0.0									
102			33.48						14.478	K Factor =	8.80	
31 to 32	24 20	5.60	16.01	1		0.0	8.000	120	8.176			
						0.0	0.0		1.732			
			16.01	1.049		0.0	8.000	0.0862	0.690	Vel =	5.94	
32 to 103	20 20	5.60	18.23	1	2E 1T	4.0 5.0	3.750 9.000	120	10.598			
						0.0	12.750	0.3519	0.0			
			34.24	1.049					4.487	Vel =	12.71	
			0.0									
103			34.24						15.085	K Factor =	8.82	
41 to 42	24 20	5.60	16.67	1		0.0	8.000	120	8.857			
						0.0	0.0		1.732			
			16.67	1.049		0.0	8.000	0.0929	0.743	Vel =	6.19	
42 to 104	20 20	5.60	18.85	1	2E 1T	4.0 5.0	3.750 9.000	120	11.332			
						0.0	12.750	0.3765	0.0			
			35.52	1.049					4.800	Vel =	13.19	
			0.0									
104			35.52						16.132	K Factor =	8.84	
51 to 52	24 20	5.60	17.63	1		0.0	8.000	120	9.912			
						0.0	0.0		1.732			
			17.63	1.049		0.0	8.000	0.1031	0.825	Vel =	6.54	
52 to 105	20 20	5.60	19.77	1	2E 1T	4.0 5.0	3.750 9.000	120	12.469			
						0.0	12.750	0.4144	0.0			
			37.4	1.049					5.283	Vel =	13.88	
			0.0									
105			37.40						17.752	K Factor =	8.88	

Final Calculations - Hazen-Williams - 2007

CORNELIUSEN CONSULTING
1844 Forest Ave- Portland Maine- 2ND FLOOR

Page 5
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
200 to 201	28 24	5.60	14.82	1	2E	4.0 0.0	8.500 4.000	120	7.000 1.732			
			14.82	1.049		0.0	12.500	0.0747	0.934	Vel =	5.50	
201 to 202	24 20	5.60	17.41	1		0.0 0.0	8.500 0.0	120	9.666 1.732			
			32.23	1.049		0.0	8.500	0.3146	2.674	Vel =	11.96	
202 to 300	20 20	5.60	21.00	1.25	2E 1T	6.0 6.0	3.500 12.000	120	14.072 0.0			
			53.23	1.38		0.0	15.500	0.2094	3.245	Vel =	11.42	
300			0.0 53.23						17.317	K Factor =	12.79	
211 to 212	28 24	5.60	14.83	1	2E	4.0 0.0	8.500 4.000	120	7.014 1.732			
			14.83	1.049		0.0	12.500	0.0749	0.936	Vel =	5.51	
212 to 213	24 20	5.60	17.43	1		0.0 0.0	8.500 0.0	120	9.682 1.732			
			32.26	1.049		0.0	8.500	0.3152	2.679	Vel =	11.98	
213 to 301	20 20	5.60	21.02	1.25	2E 1T	6.0 6.0	3.500 12.000	120	14.093 0.0			
			53.28	1.38		0.0	15.500	0.2097	3.250	Vel =	11.43	
301			0.0 53.28						17.343	K Factor =	12.79	
221 to 222	28 24	5.60	14.89	1	2E	4.0 0.0	8.500 4.000	120	7.065 1.732			
			14.89	1.049		0.0	12.500	0.0754	0.943	Vel =	5.53	
222 to 224	24 20	5.60	17.47	1		0.0 0.0	8.500 0.0	120	9.740 1.732			
			32.36	1.049		0.0	8.500	0.3169	2.694	Vel =	12.01	
224 to 302	20 20	5.60	21.08	1.25	2E 1T	6.0 6.0	3.500 12.000	120	14.166 0.0			
			53.44	1.38		0.0	15.500	0.2109	3.269	Vel =	11.46	
302			0.0 53.44						17.435	K Factor =	12.80	
231 to 232	28 24	5.60	15.00	1	2E	4.0 0.0	8.500 4.000	120	7.174 1.732			
			15.0	1.049		0.0	12.500	0.0765	0.956	Vel =	5.57	
232 to 233	24 20	5.60	17.58	1		0.0 0.0	8.500 0.0	120	9.862 1.732			
			32.58	1.049		0.0	8.500	0.3211	2.729	Vel =	12.09	
233 to 303	20 20	5.60	21.20	1.25	2E 1T	6.0 6.0	3.500 12.000	120	14.323 0.0			
			53.78	1.38		0.0	15.500	0.2134	3.307	Vel =	11.54	
303			0.0 53.78						17.630	K Factor =	12.81	
241 to 242	28 24	5.60	15.19	1	2E	4.0 0.0	8.500 4.000	120	7.360 1.732			
			15.19	1.049		0.0	12.500	0.0782	0.978	Vel =	5.64	

Final Calculations - Hazen-Williams - 2007

CORNELIUSEN CONSULTING
1844 Forest Ave- Portland Maine- 2ND FLOOR

Page 6
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
242 to 243	24 20	5.60	17.77 32.96	1 1.049		0.0 0.0	8.500 0.0	120	10.070 1.732			
						0.0	8.500	0.3280	2.788		Vel = 12.24	
243 to 304	20 20	5.60	21.39 54.35	1.25 1.38	2E 1T	6.0 6.0	3.500 12.000	120	14.590 0.0			
						0.0	15.500	0.2176	3.373		Vel = 11.66	
304			0.0 54.35						17.963		K Factor = 12.82	
251 to 252	28 24	5.60	15.48 15.48	1 1.049	2E	4.0 0.0	8.500 4.000	120	7.642 1.732			
						0.0	12.500	0.0811	1.014		Vel = 5.75	
252 to 253	24 20	5.60	18.05 33.53	1 1.049		0.0 0.0	8.500 0.0	120	10.388 1.732			
						0.0	8.500	0.3385	2.877		Vel = 12.45	
253 to 305	20 20	5.60	21.69 55.22	1.25 1.38	2E 1T	6.0 6.0	3.500 12.000	120	14.997 0.0			
						0.0	15.500	0.2240	3.472		Vel = 11.84	
305			0.0 55.22						18.469		K Factor = 12.85	
100 to 101	20 20		33.02 33.02	2 2.157		0.0 0.0	8.000 0.0	120	14.115 0.0			
						0.0	8.000	0.0099	0.079		Vel = 2.90	
101 to 102	20 20		33.12 66.14	2 2.157		0.0 0.0	8.000 0.0	120	14.194 0.0			
						0.0	8.000	0.0355	0.284		Vel = 5.81	
102 to 103	20 20		33.49 99.63	2 2.157		0.0 0.0	8.000 0.0	120	14.478 0.0			
						0.0	8.000	0.0759	0.607		Vel = 8.75	
103 to 104	20 20		34.24 133.87	2 2.157		0.0 0.0	8.000 0.0	120	15.085 0.0			
						0.0	8.000	0.1309	1.047		Vel = 11.75	
104 to 105	20 20		35.52 169.39	2 2.157		0.0 0.0	8.000 0.0	120	16.132 0.0			
						0.0	8.000	0.2025	1.620		Vel = 14.87	
105 to 106	20 20		37.40 206.79	2 2.157		0.0 0.0	17.000 17.000	120	17.752 0.0			
						0.0	17.000	0.2928	4.977		Vel = 18.16	
106 to 400	20 14		0.0 206.79	3 3.26	4E 1T	37.631 20.159	25.000 57.790	120	22.729 2.599			
						0.0	82.790	0.0392	3.243		Vel = 7.95	
400			0.0 206.79						28.571		K Factor = 38.69	
300 to 301	20 20		53.23 53.23	3 3.26		0.0 0.0	8.000 8.000	120	17.317 0.0			
						0.0	8.000	0.0032	0.026		Vel = 2.05	
301 to 302	20 20		53.28 106.51	3 3.26		0.0 0.0	8.000 8.000	120	17.343 0.0			
						0.0	8.000	0.0115	0.092		Vel = 4.09	

Final Calculations - Hazen-Williams - 2007

CORNELIUSEN CONSULTING
1844 Forest Ave- Portland Maine- 2ND FLOOR

Page 7
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
302 to 303	20 20		53.44 159.95	3 3.26		0.0 0.0	8.000 0.0	120 0.0244	17.435 0.0			
						0.0	8.000		0.195	Vel =	6.15	
303 to 304	20 20		53.78 213.73	3 3.26		0.0 0.0	8.000 0.0	120 0.0416	17.630 0.0			
						0.0	8.000		0.333	Vel =	8.22	
304 to 305	20 20		54.35 268.08	3 3.26		0.0 0.0	8.000 0.0	120 0.0632	17.963 0.0			
						0.0	8.000		0.506	Vel =	10.30	
305 to 306	20 20		55.22 323.3	3 3.26		0.0 0.0	16.000 0.0	120 0.0896	18.469 0.0			
						0.0	16.000		1.433	Vel =	12.43	
306 to 400	20 14		0.0 323.3	3 3.26	4E 1T	37.631 20.159	10.000 57.790	120 0.0895	19.902 2.599			
						0.0	67.790		6.070	Vel =	12.43	
400			0.0 323.30						28.571	K Factor =	60.48	
400 to 601	14 4		530.09 530.09	4 4.26		0.0 0.0	6.000 0.0	120 0.0607	28.571 4.331			
						0.0	6.000		0.364	Vel =	11.93	
601 to 603	4 4		0.0 530.09	4 4.26		0.0 0.0	10.000 0.0	120 0.0608	33.266 0.0			
						0.0	10.000		0.608	Vel =	11.93	
603 to 604	4 4		0.0 530.09	4 4.26	2E 1T	26.334 26.334	5.000 52.668	120 0.0607	33.874 0.0			
						0.0	57.668		3.503	Vel =	11.93	
604 to 605	4 0		0.0 530.09	4 4.26	2E	26.334 0.0	12.000 26.334	120 0.0608	37.377 1.732			
						0.0	38.334		2.329	Vel =	11.93	
605 to 606	0 0		0.0 530.09	4 4.26	1Avc 3E 1T	27.651 39.501 26.334	12.000 93.486 105.486	120 0.0607	41.438 0.0 6.407			
						0.0	12.000		47.845	* Fixed loss =	5.36	
606 to 607	0 0		530.09 530.09	4 4.26	1Zac	0.0 0.0	12.000 0.0	120 0.0608	5.360 0.729	Vel =	11.93	
						0.0	12.000		0.729	Vel =	11.93	
607 to SOR	0 0	H100	100.00 630.09	6 6.065	2E 1B 1T	28.0 10.0 30.0	100.000 68.000 168.000	120 0.0150	53.934 0.0 2.514			
						0.0	168.000		2.514	Vel =	7.00	
SOR			0.0 630.09						56.448	K Factor =	83.86	