



- NOTES:
1. BALANCING LINE SHOULD BE ONE SIZE SMALLER THAN SUPPLY AND RETURN LINES.
  2. PIPE RELIEF VALVES TO DRAIN, OR AS LOCAL CODES REQUIRE.
  3. FOR SYSTEM PURGE, OPEN VALVE B, CLOSE VALVE C, OPEN DRAIN VALVE.
  4. MINIMUM PIPE SIZE SHOULD BE EQUAL TO BOILER INLET/OUTLET.
  5. FLANGE SIZE ON PUMP IS NOT RELATED TO PIPE SIZE.
- OPTIONAL FLOW SWITCH LOCATION IF NOT INSTALLED AT FACTORY.

BOILER SHOWN REPRESENTS VARIOUS MODELS. SEE SPECIFIC BOILER INFORMATION FOR DETAILS BECAUSE MODELS WILL VARY IN DRAFT HOOD DESIGN AND SIZE.

MULTI-ZONE HEATING SYSTEM  
 WITH DIAPHRAGM EXPANSION TANK  
 ZONE VALVE SYSTEM  
 COMMERCIAL BOILER

