

CITY OF PORTLAND, MAINE Department of Building Inspection

Certificate of cupancy

LOCATION

61 Riverton Dr

CBL 327 B012001

Issued to

Portland Housing Authority/n/a

Date of Issue

04/29/2010

This is to certify that the building, premises, or part thereof, at the above location, built - altered - changed as to use under Building Permit No. 10-0319 has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for

occupancy or use, limited or otherwise, as indicated below. PORTION OF BUILDING OR PREMISES

Located @ 61 Riverton Dr.

APPROVED OCCUPANCY

Assembly "Residents Library"

Use Group: A/ R-2

Type: 5B

IBC, 2003

This is a temporary occupancy certificate, which expires on May 28, 2010. The door at the bottom of the stairwell shall be self-closing, and the magnetic hold open on the door shall be tied into all smoke alarms. The plumbing leak in the restroom and through penetrations in the boiler room must be repaired.

This certificate supersedes certificate issued

Limiting Conditions:

Approved:

Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from wher to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar