STATE OF MAINE - DEPARTMENT OF PUBLIC SAFETY
OFFICE OF STATE FIRE MARSHAL
45 COMMERCE DR STE 1
AUGUSTA, ME 04333-0001

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 05/27/16

Construction Permit

No. 23652

In accordance with the provisions of M.R.S.A. Title 25, Chapter 317, Sec.317 and Title 5, Section 4594-F, permission is hereby granted to construct or alter the following referenced building according to the plans hitherto filed with the Commissioner and now approved. No departure from application form/plans shall be made without prior approval in writing. Nothing herein shall excuse the holder of this permit for failure to comply with local ordinances, zoning laws, or other pertinent legal restrictions.

Each permit issued shall be displayed at the site of construction.

Building: INTERIOR RENOVATIONS FOUNDATION BREWING COMPANY EXPANSION
Location: UNITS 1 3 4 5 & 7, 1 INDUSTRIAL WAY, PORTLAND, ME 04103-1072
Owner: JOHN BONNEY
Owner Address: 1 INDUSTRIAL WAY STE 5, PORTLAND, ME 04103-1072

Occupancy Type: Assembly Class <300
Secondary Use: Storage
Use Layout: Mixed Use
Sprinkler System
Fire Alarm System
Barrier Free
Construction Mode: Renovation
Unprotected Noncombustable: Type II (000)
Final Number of Stories: 1

Permit Date: 05/18/2016 **Expiration Date:** 11/17/2016

Notes and additional requirements:
Boiler Room door to be 45 min rated min, self-closing and positive latching

John E Morris

COMMISSIONER OF PUBLIC SAFETY

Copy 1 - Owner

STATE OF MAINE - DEPARTMENT OF PUBLIC SAFETY
OFFICE OF STATE FIRE MARSHAL
45 COMMERCE DR STE 1
AUGUSTA, ME 04333-0001

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 05/27/16

Construction Permit

No. 23652

In accordance with the provisions of M.R.S.A. Title 25, Chapter 317, Sec.317 and Title 5, Section 4594-F, permission is hereby granted to construct or alter the following referenced building according to the plans hitherto filed with the Commissioner and now approved. No departure from application form/plans shall be made without prior approval in writing. Nothing herein shall excuse the holder of this permit for failure to comply with local ordinances, zoning laws, or other pertinent legal restrictions.

Each permit issued shall be displayed at the site of construction.

Building: INTERIOR RENOVATIONS FOUNDATION BREWING COMPANY EXPANSION
Location: UNITS 1 3 4 5 & 7, 1 INDUSTRIAL WAY, PORTLAND, ME 04103-1072
Owner: JOHN BONNEY
Owner Address: 1 INDUSTRIAL WAY STE 5, PORTLAND, ME 04103-1072

Occupancy Type: Assembly Class <300
Secondary Use: Storage
Use Layout: Mixed Use
Sprinkler System
Fire Alarm System
Barrier Free
Construction Mode: Renovation
Unprotected Noncombustable: Type II (000)
Final Number of Stories: 1

Permit Date: 05/18/2016 **Expiration Date:** 11/17/2016

Notes and additional requirements:
Boiler Room door to be 45 min rated min, self-closing and positive latching

John E Morris

COMMISSIONER OF PUBLIC SAFETY

Copy 2 - Architect