Reviewed for Code Compliance
Inspections Division
Date: 09/20/16

1. One hour fire door required. Seee Table 6.1.14.4.1 (a)
2. Means of Egress shall be Illuminated in accordance with Section 7.8- Exit sign

AUSTIN STREET BREWERY STORAGE LAYOUT PLAN