Reviewed for Code Compliance
Inspections Division
Date: 09/20/16

AUSTIN STREET BREWERY LAYOUT PLAN
2626 TOTAL SQ FEET

1/4"=1'-0" 4' 2' 0 4' 8'

1. One hour fire doors required, See Table 6.1.14.4.1(a)
2. Means of Egress shall be Illuminated in accordance with Seaction 7.8