





6 SLAB REINFORCING DETAILS
1/2"=1'-0"




5 MANHOLE COLOR SCHEDULE
1/4"=1'-0"







4 CONCRETE TAG AND MARKER DETAILS
1/2"=1'-0"



3 SAW CUT DETAILS
1/8"=1'-0"



1 FUEL AREA SLAB LAYOUT AND DIMENSIONAL PLAN
1/8"=1'-0"





2 JOINT DETAILS
3/8"=1'-0"

KEY NOTES

- CONCRETE SLAB. REF CIVIL DRAWINGS FOR TOS ELEVATIONS. ALL MANHOLES WITHIN THE TANK SLAB AREA TO BE RAISED 1" ABOVE THE NORMAL GRADE OF CONCRETE. SLOPE CONCRETE TO MANHOLES 1/4" PER FT. CROWN CONCRETE AS TO NOT INHIBIT WATER DRAINAGE OFF THE TANK SLAB (NO POOLING).
- GASOLINE RESISTANT JOINT SEALING COMPOUND - REF SPEC SECTION V CONCRETE / PART 2 - PRODUCTS / 2.1.9.
- UNDISTURBED SOIL OR COMPACTED BACK FILL NOT LESS THAN 95% OF MODIFIED PROCTOR DENSITY (AASHTO-T-180).
- 1/2" THICK ASPHALT IMPREGNATED EXPANSION JOINT MATERIAL.


Rev. #	Date	Description

7-ELEVEN, INC.
3200 HACKBERRY ROAD, IRVING, TEXAS 75063
7-11 #32541
1917 FOREST AVE
PORTLAND, ME 04103
FUELING DIMENSIONAL PLAN
Proto 2nd Qtr 04-03-15



Job#: SEL-16380.0222
Scale: AS NOTED
Date: 01/21/16
Drawn By: JMR
Checked By: CPS

Documents prepared by Core States Group are to be used only for the specific use for which they are intended. Any extension of use to other projects, by owner or otherwise, without the written consent of Core States Group is prohibited. Core States Group is not responsible for any claims or losses resulting from the use of these documents for any purpose other than that specifically intended, user will hold Core States Group harmless from all claims and losses.



SHEET:
G6.1
FUELING - USA