Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 03/29/16

7-ELEVEN PORTLAND MAINE
PYRO-CHEM UL 1254 GAS ISLAND FIRE SUPPRESSION SYSTEM INSTALLATION

PROJECT
7-ELEVEN #32541

OWNER
7-ELEVEN INC.
1722 ROUTH STREET
DALLAS, TX 75221

Interstate FIRE PROTECTION
PEACE OF MIND

P.O. BOX 1005
NORTH CONWAY, NH 03860-1005

SALES: 1.800.717.6454
SERVICE: 1.800.717.6454
WEBSITE: www.interstatefire.com

Pyro-Chem
ISO 9001 Registered

TABLE OF CONTENTS

SHEET NO.	TITLE
01	COVER SHEET
02	MECHANICAL DETAIL
03	ELECTRICAL PLAN
04	PANEL PROGRAMMING

NOTES:
1. THIS INSTALLATION SHALL BE MADE IN STRICT ACCORDANCE WITH THE DRAWINGS, SPECIFICATIONS AND APPLICABLE NATIONAL FIRE PROTECTION ASSOCIATION STANDARDS. ALL EQUIPMENT AND DEVICES USED SHALL BE LISTED IN THE UL FIRE EQUIPMENT DIRECTORY.
2. DESIGN AND INSTALLATION OF THE DRY CHEMICAL GAS ISLAND FIRE SUPPRESSION SYSTEM WILL BE IN STRICT ACCORDANCE WITH THE FOLLOWING GUIDELINES AND REGULATORY AGENCIES:
   - 2.1. NFPA 17 STANDARD FOR DRY CHEMICAL FIRE EXTINGUISHING SYSTEMS, 2013 EDITION
   - 2.2. NFPA 72 NATIONAL FIRE ALARM AND SIGNALING CODE, 2013 EDITION
   - 2.3. NFPA 70 NATIONAL ELECTRIC CODES, 2011 EDITION
   - 2.4. AMERICANS WITH DISABILITIES ACT, TITLE 24, LATEST EDITION
   - 2.5. THE LOCAL AUTHORITY HAVING JURISDICTION

System Information:
PYRO-CHEM ATTENDANT II UL 1254
DRY CHEMICAL FIRE SUPPRESSION
SYSTEM PROTECTING A SELF-SERVICE
GASOLINE FUELING FACILITY

Owner/Site:
7-ELEVEN INC.
7-ELEVEN #32541
1917 FOREST AVENUE
PORTLAND, ME 04101

Interstate FIRE PROTECTION
P.O. BOX 1005
NORTH CONWAY, NH 03860
P.O. BOX 187
GARDINER, ME 04345

PYRO-CHEM GAS ISLAND FIRE SUPPRESSION SYSTEM
COVER SHEET

Proj. no.:	
CAD File:	7-11ForestAvePortME.dwg
Drawn By:	M. STEWARD
Created on:	02/16/2016
Designed by:	M. STEWARD
Checked by:	B. TWOMBLY
Approved by:	B.TWOMBLY
Project Lead:	J. MOONEY
Scale:	SCALE AS NOTED

Revisions:	Date:
ii	02/16/2016

SHEET : 01