Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 04/03/17

38 Evergreen Drive - Permit Application 2016 02382

Inbox x

Brian Stephens Mar 17

Hello David, I am in the process of reviewing this project for building code ...

5 older messages

Brian Stephens <bstephens@portlandmaine.gov> 8:27 AM (1 hour ago)

to Peter

Hi Peter,

In order to comply with 2010 ADA Standards for Accessible Design, a minimum of 5% of your indoor seating (or 3 table places) need to be at a height between 28 and 34 inches.

Please confirm your intention to provide such seating.

Thanks, Brian

...

Peter Brown 9:27 AM (31 minutes ago)

to jesse, Pete, me

Hi Brian,

One of the pallet tables will be kept inside to ensure compliance, and a minimum of 3-table places around this will be kept clear/open.

Thanks,

Peter